




## Americans with Disabilities Act Transition Plan Update



Broward County Board of County Commissioners

**BROWARD COUNTY, FLORIDA  
ADA TRANSITION PLAN UPDATE  
MARCH, 2007**

**TABLE OF CONTENTS**

Executive Summary	iv
Overview	1
Comparison of Structural and Programmatic Approaches to Compliance	2
Economic Advantages of Programmatic Approach	3
Legal Mandate	4
1. Establishment of Disability Affairs Section and Position of ADA Coordinator	5
2. Issue Notice of ADA Requirement	5
3. Establishment of Grievance Procedures	5
4. Conduct a Self-Evaluation	5
• Policies and Procedures	
• Communications	
• Employment	
• Program and Facility Accessibility	
5. Develop a Transition Plan	6
Methodology	6
<b>Phase I: Planning and Self-Evaluation</b>	<b>7</b>
ADA Task Force	7
A. Facility Inventory	
B. Survey Tools	
• Exterior Accessibility	
• Interior Accessibility	
• Program Accessibility	
Transition Plan Update Team	10

Self-Evaluation/Data Collection	11
A.    Establishment of Disability Affairs Section and Position of ADA Coordinator	11
B.    Issue Notice of ADA Requirements	12
C.    Grievance Procedures for County Services, Programs and Activities	12
D.    Policies and Procedures Review	12
E.    ADA Communications Review	13
F.    Employment Policies and Practices Review	14
<b>Phase II: Recommendations and Prioritization</b>	<b>16</b>
Data Analysis	16
Policy and Procedures Survey Recommendations	16
Communications Survey Recommendations	16
A.    Auxiliary Aids and Services	17
B.    Sign Language Interpreter Services	17
C.    Telecommunications Access	17
D.    Inclusion of Braille services in County Agencies	19
Employment Recommendations	19
Priority System Development	20
Operational, Non-structural and Structural Recommendations	21
Database and Intranet Website	22
Cost Estimates	22
Streets and Sidewalk Accessibility	23
Lighting and Traffic Signals	24
Community involvement and Outreach	25

<b>Phase III: Adoption and Implementation</b>	<b>26</b>
Public Outreach	26
Training	27
Communication and Training Budget Recommendations	28
<b>Summary</b>	<b>29</b>
<b>Recommendations</b>	<b>30</b>

**BROWARD COUNTY, FLORIDA  
ADA TRANSITION PLAN UPDATE  
MARCH, 2007**

**EXECUTIVE SUMMARY**

The Americans with Disabilities Act (ADA) is a comprehensive civil rights act that prohibits discrimination and ensures equal opportunity for persons with disabilities. In accordance with the requirements set forth by Title II of the Americans with Disabilities Act, This report describes the process by which Broward County's policies, practices, programs and facilities were evaluated, and describes how prioritization for accessibility improvements, including the facility surveys detailing physical barriers, occurred. This Plan further describes the process by which the County will continue to evaluate its physical facilities and remain in compliance with the Act.

**Program Background**

Broward County has a long history of efforts to improve the accessibility of its programs, services, and facilities to individuals with disabilities. Upon the enactment of the Americans with Disabilities Act in 1990, Broward County mobilized to comply with the new law's multi-faceted requirements. The County worked on the ADA Transition Plan from 1992-1994, and began implementation soon after. Over the next 10 years, the scope and extent of Broward County's programs increased. Bond initiatives were undertaken to fund new parks and libraries. Existing agencies expanded services and offered new services to the community. In light of new construction of County facilities, frequent shifting in programs assigned to existing facilities, and a general increase in the number and scope of programs and services offered to the public by Broward County, the County began work on its ADA Transition Plan Update process.

Section 35.150(b)(1) of the Americans with Disabilities Act requires that the County operates each program so that, when viewed in its entirety, the program is readily accessible to and usable by individuals with disabilities. This is known as the program accessibility standard, and it is one of the most important concepts in ADA Compliance planning. It allows programmatic adjustments—those not requiring physical modification to the structure—to be taken into consideration as a primary response to ADA facility compliance. Structural adjustments, which involve physical modification of a structure, are generally cost-intensive, disruptive to work flows, and time-consuming, and, most importantly, not always required.

Programmatic adjustments identified in this report will save the County significantly in terms of budgetary resources necessary to bring County facilities into compliance, over structural solutions. While less costly and more efficient, the programmatic approach does require a knowledgeable staff qualified in ADA compliance to review all program placements prior to decisions being made. ADA compliance is a complex process that affects an entity at many levels.

Experience indicates that compliance activities are best approached in a coordinated manner. Furthermore, success in implementing permanent changes depends to great extent on the quality of the planning process itself and the degree to which compliance becomes integrated in on-going operations.

### **ADA Task Force**

In December 2005, the County Administrator, through the Office of Equal Opportunity, directed the establishment of an ADA Task Force to discuss ways to expedite the development and implementation of the Transition Plan Update.

This Task Force was comprised of the Assistant County Administrator, and the Directors of Public Works and Transportation Department, Community Services Department, Human Services Department, Finance and Administrative Services Department, Urban Planning and Redevelopment Department, the Office of Management and Budget and the Office of Equal Opportunity. The Office of Equal Opportunity was given the assignment to develop a proposed work plan for the Task Force's discussion, which was to include a phased-in approach to the completion of a transition plan update. The Task Force met on numerous occasions to discuss the strategic work plan being proposed, the facility accessibility survey tools, and resource requirements being requested.

### **Three-Phase Process**

The ADA Transition Plan Update process consists of three phases:

- *Phase I: Planning and Self-Evaluation Phase* – The first phase involved planning and assessment, including the formation of the ADA Task Force, the facility inventory, the creation of survey tools, the hiring of staff for the effort, and subsequent data collection.
- *Phase II: Recommendations and Prioritization* – review of Phase I findings and the development of recommendations.
- *Phase III: Adoption and Implementation* - Phase III includes the approval of recommended actions by the Broward County Board of County Commissioners, and the start of implementation of the ADA Transition Plan Update.

During Phase I of the ADA Transition Plan Update, the ADA Transition Team completed reviews of the County's policies and procedures, communication resources and all County programs (215), and facilities (141). In order to expedite this project and maintain the integrity of the Transition Plan Update, the concept of Facility/Program Assessment Teams was established; each team was to consist of at least three persons to accomplish the facilities reviews. Each Team included an ADA Specialist, a Facilities Manager, and a person knowledgeable about the programs housed in each facility. Under the direction of the County's ADA Administrator, the ADA Specialists served as leaders of the

survey teams and conducted the facility access reviews of all County owned, operated and leased facilities. As the assessment proceeded through the County, department by department, relevant staff members in each agency were given comprehensive training sessions on the Americans with Disabilities Act and principles of compliance.

In total, there were over 150 unique teams, with varying program and facility members, required to perform the reviews in Phase I. With the assistance of the County's directors, each team approached the process in a direct and effective manner, and completed its review in four months—a time period that would not have been possible had County staff not been involved.

Phase II focused on the development of programmatic recommendations for ensuring accessibility to County programs and facilities. The ADA Team conducted a detailed analysis of the data collected during Phase I and developed recommendations to correct identified deficiencies in each of the four major areas. In addition, cost estimates for removing barriers were generated by the appropriate County facility management agencies.

During Phase III, upon approval of the ADA Transition Plan Update by the Board of County Commissioners, recommendations developed during Phase II to bring the County into compliance with the Americans with Disabilities Act will be implemented.

Public outreach, accountability, and transparency are all crucial to the success of the ADA Transition Plan Update. To this end, the Office of Equal Opportunity has made the use of technology a major part of the update effort from its inception. The intranet site, created during Phase II, has been central to the County's ability to complete this difficult process accurately and efficiently. The site will form the basis of the public outreach website, slated for development and deployment during Phase III.

### **Cost Estimates**

Based on the information obtained during the Transition Plan Update process, the ADA Transition Plan Update team is able to provide estimates of the costs associated with bringing the County into full compliance with the Americans with Disabilities Act in terms of its programs and facilities.

The following budget summary reflects current cost estimates, by priority rank, for implementing the recommendations developed during the ADA facility/program review process:

<b>Priority Group</b>	<b>Public Works</b>	<b>Port Everglades</b>	<b>Parks</b>	<b>Operational</b>	<b>Totals</b>
<b>Priority 1</b>	\$629,751	\$0	\$3,285,200	\$135,250	<b>\$4,050,201</b>
<b>Priority 2</b>	\$2,356,464	\$0	\$833,700	\$0	<b>\$3,190,164</b>
<b>Priority 3</b>	\$29,400	\$276,050	\$402,100	\$0	<b>\$707,550</b>
<b>Final Estimated Costs</b>	<b>\$3,015,615</b>	<b>\$276,050</b>	<b>\$4,521,000</b>	<b>\$135,250</b>	<b>\$7,947,915</b>

Phase III implementation of the recommendations will also include a considerable emphasis on broad-based training of County staff on the ADA, and significant public outreach. Costs associated with requirements for communications enhancements include \$62,244 for TTY systems, \$100,000 for sign language interpreter services, and \$250,000 for a specialized countywide training program, for a total of \$412,244. The ADA Transition Plan Update Team recommends the County Commission consider funding for additional Braille machines, to provide enhanced service at strategic locations for the disable community; these machines are estimated to cost \$164,360.

### **Outcome of the ADA Transition Plan Update Process**

Upon approval and adoption of the ADA Transition Plan Update, the County will be in compliance with the requirements of Title II of the Americans with Disabilities Act. But beyond the legal requirements, Broward County and its Board of County Commissioners are demonstrating, through this Transition Plan Update, their commitment to inclusion of all County citizens in public programs and facilities, as well as a dedication to transparency in government and to sustaining a high quality of life for residents. The institution of an ongoing ADA compliance monitoring system, coupled with increased community outreach and involvement, will ensure that Broward County will be a leader in the effort to comply with the Americans with Disabilities Act, and continue the County's commitment to inclusion.

**BROWARD COUNTY, FLORIDA  
ADA TRANSITION PLAN UPDATE  
MARCH, 2007**

<b>Overview</b>
-----------------

The Americans with Disabilities Act (ADA) is a comprehensive civil rights act that prohibits discrimination and ensures equal opportunity for persons with disabilities. The ADA Transition Plan Update is being prepared according to the requirements set forth in Title II of the Americans with Disabilities Act. This report describes the process by which policies, practices, programs and facilities were evaluated, and describes how prioritization for accessibility improvements, including the facility surveys detailing physical barriers, occurred. This Plan further describes the process by which the County will continue to evaluate its physical facilities and remain in compliance with the Act.

Broward County has a long history of efforts to improve the accessibility of its programs, services, and facilities to individuals with disabilities. Well before the passage of the Americans with Disabilities Act, Broward County established a committee of representatives from County agencies and the local disabled community to implement the requirements of Section 504 of the Rehabilitation Act of 1973.

Upon the enactment of the Americans with Disabilities Act in 1990, Broward County mobilized to comply with the new law's multi-faceted requirements. At that time, the County undertook the development of the required ADA Transition Plan. The original evaluations of compliance with the Act were made on a departmental basis, with each department responsible for coordination and implementation of the ADA Transition Plan recommendation applicable to its own programs and facilities. While the approach taken under the original ADA Transition Plan was decentralized, the Office of Equal Opportunity maintained one staff position for Americans with Disabilities Act compliance support.

The County worked on the ADA Transition Plan from 1992-1994, and began implementation soon after. Throughout the remainder of the 1990s and into the current decade, departments implemented the recommendations of the original Transition Plan. Requests for funding of remedial actions were made by each department, directly to budget, based in part on issues identified during the initial assessment, for barriers identified in the plan.

Over the next 10 years, the scope and extent of Broward County's programs increased. Bond initiatives were undertaken to fund new parks and libraries. Existing agencies expanded services and offered new services to the community. Because the obligations under Title II of the ADA are ongoing and any change in the use or placement of programs and services triggers further evaluation for compliance with the ADA, an update of the County's original effort was

necessary. In 2004, the County began revisiting its compliance with the Americans with Disabilities Act.

### **Comparison of Structural and Programmatic Approaches to Compliance**

In light of new construction of County facilities, frequent shifting in programs assigned to existing facilities, and a general increase in the number and scope of programs and services offered to the public by Broward County, the County began work on its ADA Transition Plan Update process in May, 2004. At that time, Broward County entered into an agreement with an architecture and engineering consultant to survey facilities owned and leased by the County to identify all existing structural barriers to persons with disabilities, and the costs associated with remediation of such barriers. This approach was to involve a technical assessment of all County facilities, with remedial actions of a structural nature to follow the assessment.

During the first 1½ years of this structural approach (May 2004 through November 2005), the consultant completed surveys of five (5) County facilities: the Government Center, the Main Library, and the North, South, and West Regional Courthouses. The County's cost for this approach for the 1½ years was \$250,000. While the consultant approach would have eventually surveyed all buildings, using this structural approach, it would have taken several years; when the surveys were completed, the County would still have had the task of bringing the buildings into compliance structurally. Throughout the process, the County would have remained open to legal action on its compliance issues with the Americans with Disabilities Act.

It became readily apparent that change was needed in the County's approach to the ADA Transition Plan Update process. The County was using a structural approach to bringing facilities into compliance with the Act. While this approach is acceptable under the Act, the reviews and resulting remedial actions are expensive and time-intensive.

Section 35.150(b)(1) of the Americans with Disabilities Act requires that the County operates each program so that, when viewed in its entirety, the program is readily accessible to and usable by individuals with disabilities. This is known as the program accessibility standard, and it is one of the most important concepts in ADA Compliance planning. It allows programmatic adjustments—those not requiring physical modification to the structure—to be taken into consideration as a primary response to ADA facility compliance. Structural adjustments, which involve physical modification of a structure, are generally cost-intensive, disruptive to work flows, and time-consuming, and, most importantly, not always required. The County's contract with the consultant was for structural evaluation, and did not allow for programmatic evaluation, which is more cost-effective and efficiently implemented.

Programmatic adjustments identified in this report will save the County significantly in terms of budgetary resources necessary to bring County facilities into compliance, over structural solutions. Under the Act, programmatic approaches are to be taken first—programs can be moved, or other minor adjustments made—with structural approaches being taken only as a last resort.

While less costly and more efficient, the programmatic approach does require a knowledgeable staff qualified in ADA compliance to review all program placements prior to decisions being made. The approach also requires teamwork—staff working together to learn the regulations, the programs, and the facilities, and to develop recommendations to meet the requirements of the law at maximum benefit for cost. Training, to elevate the level of ADA knowledge among program and facility managers, is also critical to the long term effectiveness of the programmatic approach.

Finally, the process as originally designed did not make effective use of County staff resources, particularly those of the County’s departmental executives. As a result, a potentially invaluable resource in marshalling agency-level resources and establishing work priority at the agency level was being overlooked.

**Economic Advantages of Programmatic Approach**

As noted previously, the use of programmatic approaches, instead of the structural approaches which had been exclusively employed by the outside consultant, results in significant cost savings to the County. The following chart details the results of the surveys of the first five buildings, using the structural approach employed by the County in its consultant-driven process, compared with the programmatic approaches employed by the County during its review.

Facility	Programmatic Approach (County)	% of Total Cost	Structural Approach (Consultant)	% of Total Cost	Cost Savings	% Savings
Government Center	\$543,900	37.9%	\$585,755	18.6%	\$41,855	7.1%
Main Library North	\$341,070	23.8%	\$880,730	28.0%	\$539,660	61.3%
Regional Courthouse South	\$166,145	11.6%	\$584,771	18.6%	\$418,626	71.6%
Regional Courthouse West	\$219,625	15.3%	\$540,201	17.1%	\$320,576	59.3%
Regional Courthouse	\$162,585	11.3%	\$309,589	9.8%	\$147,004	47.5%
Subtotal (Estimated Costs)	\$1,433,325	100.0%	\$2,901,046	92.1%	\$1,467,721	50.6%
Consultants Fees	\$0	0.0%	\$250,000	7.9%	\$250,000	100.0%
<b>Total Cost</b>	<b>\$1,433,325</b>	<b>100.0%</b>	<b>\$3,151,046</b>	<b>100.0%</b>	<b>\$1,717,721</b>	<b>54.5%</b>

The cost savings exhibited by the comparisons above are striking. The average cost savings on each building is \$293,544 (an average of \$580,209 for the structural approach, and \$286,665 for the programmatic approach). For these buildings, the County is projected to save approximately 54.5% by utilizing a unified programmatic approach, over the structural approach originally taken by the County. There are savings in the case of each building, from the Government Center, which requires the greatest percentage of structural adjustments (7.1%) to the North Regional Courthouse, where the Transition Plan Update's approach will save the County an estimated \$418,626, or 71.6%.

Data from the consultant regarding estimated structural costs only exists for five buildings of the County's 141 facilities; this makes generalization, from the comparisons seen here, difficult. While it would not be appropriate to extrapolate from these data a total estimated savings resulting from the use of programmatic approaches, the potential savings of programmatic approaches over structural approaches is unmistakable. This savings extends to the balance of the County's facilities, given that the programmatic approach has been similarly applied across all County facilities.

### **Legal Mandate**

The American with Disabilities Act (ADA) was signed into law on July 26, 1990, and provides a comprehensive mandate of the rights of individuals with disabilities. The signing of the ADA into law was a momentous public policy initiative, because approximately 20% of all Americans (or about 54 million people) have some type of disability that affects their daily lives. The ADA has three titles that address information pertaining to employment and the accessibility of programs, services, and facilities.

Title II of the ADA covers public entities including Broward County Government and all its programs, services and activities. The regulations contained in Title II of the Americans with Disabilities Act prohibit public entities from discriminating against or excluding individuals with disabilities from programs, services, or activities on the basis of disability.

The provisions of Title II fall into four broad areas:

- 1) General non-discrimination
- 2) Equal effective communication
- 3) Employment
- 4) Program and facility accessibility

Equal opportunity must be provided through reasonable modification in policies, practices, or procedures; effective communication must be ensured through the provisions of auxiliary aids and services; nondiscriminatory employment practices are required; and programs must be made accessible through programmatic or architectural modifications.

Title II of the ADA requires that public entities take systemic steps to examine their programs and establish a plan for ensuring compliance with the law. Five action steps must be taken to bring a public entity into compliance with Title II regulations:

1. *Establishment of Disability Affairs Section and Position of ADA Coordinator:* The ADA requires a public entity with fifty or more employees to designate at least one employee to coordinate ADA compliance. Section 35.107 (a)
2. *Issue Notice of ADA Requirement:* All public entities, regardless of size, must provide information to applicants, participants, beneficiaries, employees, and other interested parties regarding the rights and protections afforded by Title II of the ADA, including information about how the Title II requirements apply to its particular programs, services, and activities. This notice also serves to notify the public of the ADA Coordinator's contact information. Section 35.106
3. *Establishment of Grievance Procedures:* Public entities with fifty or more employees must adopt and publish grievance procedures providing for prompt and equitable resolution of grievances arising under Title II of the ADA. The purpose of this grievance is to provide a mechanism for the resolution of discrimination issues at the County level, rather than requiring the complainant to resort to the federal complaint process. Section 35.107 (b)
4. *Conduct a Self-Evaluation: A self- evaluation is a comprehensive review of the following four major areas:* Section 35.105
  - a. *Policies and Procedures* - The self-evaluation involves thorough review of general policies and procedures to ensure non-discrimination.
  - b. *Communications* - The purpose of this survey is to assess the County's ability to provide communication for individuals with disabilities that is as effective as the communication provided to individuals without disabilities.
  - c. *Employment* - The County does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under Title I of the Americans with Disabilities Act (ADA).
  - d. *Program and Facility Accessibility* - Title II of the ADA prohibits public entities from excluding individuals with disabilities from programs, services, or activities because of inaccessible facilities.

In order to ensure that our programs are accessible, when viewed in their entirety, we are required to conduct a facility access review.

5. *Develop a Transition Plan:* The ADA Transition Plan flows logically from the Self-Evaluation. If the self-evaluation for programs and facilities reveals that barriers cannot be removed through nonstructural program changes, Title II requires that public entities develop a transition plan. The regulation requires that, at a minimum, the transition plan:
- a. List physical obstacles that limit the accessibility of the public entity's programs, services, or activities to people with disabilities;
  - b. Describe the methods to be used to make the facilities accessible;
  - c. Provide cost estimates;
  - d. Provide a schedule for making the access modifications—a yearly schedule for making the modifications if the transition plan is more than one year long;
  - e. Name a person responsible for implementation of the transition plan.

In addition, Section 35.150 (d)(2) requires that if the public entity has responsibility or authority over streets, roads or walkways, its transition plan shall include a schedule for providing curb ramps or other sloped areas where pedestrian walks cross curbs.

The ADA does not require a public entity to take any action that it can demonstrate would result in a fundamental alteration in the nature of a program or activity, would create a hazardous condition for other people, or would represent an undue financial and administrative burden.

## **Methodology**

ADA compliance is a complex process that affects the entity at many levels. Experience indicates that compliance activities are best approached in a coordinated manner. Furthermore, success in implementing permanent changes depends to great extent on the quality of the planning process itself and the degree to which compliance becomes integrated in on-going operations.

Broward County's Transition Plan Update process was organized into three main phases that incorporated the five general requirements of Title II regulations.

*Phase I: Planning and Self-Evaluation Phase* – The first phase involved planning and assessment, including the formation of the ADA Task Force, the facility

inventory, the creation of survey tools, the hiring of staff for the effort, and subsequent data collection.

*Phase II: Recommendations and Prioritization* - Phase II of the Transition Plan Update included the following activities:

- Data Analysis;
- Development of recommendations associated with the policies and procedures survey;
- Development of recommendations associated with the communications survey;
- Development of program/facility recommendations and priority system;
- Creation of database and internal website;
- Cost estimate by facility management agencies;
- Review of streets, sidewalks and traffic signals compliance; and
- Community involvement and outreach.

*Phase III: Adoption and Implementation* - Phase III includes the approval of recommended actions by the Broward County Board of County Commissioners, and the start of implementation of the ADA Transition Plan Update.

## **Phase I: Planning and Self-Evaluation**

### **ADA Task Force**

In December 2005, the County Administrator, through the Office of Equal Opportunity, directed the establishment of an ADA Task Force to discuss ways to expedite the development and implementation of the Transition Plan Update.

This Task Force was comprised of the Assistant County Administrator, and the Directors of Public Works and Transportation Department, Community Services Department, Human Services Department, Finance and Administrative Services Department, Urban Planning and Redevelopment Department, the Office of Management and Budget and the Office of Equal Opportunity. The Office of Equal Opportunity was given the assignment to develop a proposed work plan for the Task Force's discussion, which was to include a phased-in approach to the completion of a transition plan update. The Task Force met on numerous occasions to discuss the strategic work plan being proposed, the facility accessibility survey tools, and resource requirements being requested.

Task force members, given the influence of their positions in the County, have played a valuable role in the completion of the ADA Transition Plan Update process. Their participation and positive influence on the workforce helped to carry the project through the initial reviews, through the analysis phase, and will be instrumental in the implementation phase over the next several years. This participation ensured that ADA compliance was a priority, and that staff and resources were mobilized to meet the need.

After reviewing the outcome of the structural approach for the first five facilities, and examining the potential cost savings and greater efficiency that might be realized by taking the programmatic approach, the County Administrator directed that the Office begin mobilizing to perform the programmatic reviews.

Upon this direction, the Office began putting together its ADA Transition Plan Update Team and developing a plan for implementing the programmatic approach to compliance under the Act.

In order to expedite this project and maintain the integrity of the Transition Plan Update, the concept of Facility/Program Assessment Teams was established; each team was to consist of at least three persons to accomplish the facilities reviews. Each Team included an ADA Specialist, a Facilities Manager, and a person knowledgeable about the programs housed in each facility. Under the direction of the County's ADA Administrator, the ADA Specialists served as leaders of the survey teams and conducted the facility access reviews of all County owned, operated and leased facilities. As the assessment proceeded through the County, department by department, relevant staff members in each agency were given comprehensive training sessions on the Americans with Disabilities Act and principles of compliance.

It was the unique combination of expertise in the Facility/Program Assessment Teams that allowed the County to proceed with great efficiency and accuracy. This specialized knowledge, of facilities and programs, could not have been expected from consulting groups which, while experts on the law, are not experts on our facilities or programs. In total, there were over 150 unique teams, with varying program and facility members, required to perform the reviews in Phase I. With the assistance of the County's directors, each team approached the process in a direct and effective manner, and completed its review in four months—a time period that would not have been possible had County staff not been involved.

#### A. Facility Inventory

The facility inventory is a management tool for organizing and monitoring access reviews. Departments and divisions were asked to provide a list of all buildings and facilities occupied by department; a list of facilities used by each activity or program, including: 1) address; 2) a facility contact person; 3) the year of construction; and 4) capital planning information (e.g. planned alterations, closings or other plans for each facility, etc.); description of the program, including the purpose, scope of activities, number and type of participants, any unique features of each facility that are necessary for the operation of programs provided at that location, and other key information about the program. The resultant facility inventory is a comprehensive inventory of programs and services offered by Broward County. (*Exhibit I – Facility Inventory Listing*)

## B. Survey Tools

In order to create a format for collecting the facility information that would form the basis of the update, the Transition Plan Team developed survey tools. These survey tools were provided to the Task Force members for approval. In designing the facility survey tool, the main goal was to understand how an individual with a particular disability “navigates” through a facility. The facility survey tool is divided into three broad categories:

- *Exterior Accessibility* – Once they arrive at a facility site, individuals with disabilities should be able to approach a building and enter the building as freely as everyone else. For instance, at least one accessible route must be provided within the boundary of the site connecting elements such as accessible parking, sidewalks and or public transportation stops, to an accessible building entrance.
- *Interior Accessibility* - The interior accessible route connects the accessible entrance with the program and services area. Typically, interior accessible routes are made up of hallways, corridors, and interior rooms and spaces. The accessible route is essential for people who have difficulty walking or who use wheelchairs or other mobility aids to access the services and programs areas. Additionally, people who are blind or have low vision may walk along any route to access the programs and services areas, not just the accessible routes. As such, routes open to or leading to the service area, such as hallways, corridors and service and program spaces, must be free of objects that cannot be detected by a person who is blind or visually impaired.
- *Program Accessibility* - A public entity may not deny the benefits of its programs, activities, and services to individuals with disabilities because its facilities are inaccessible. A public entity's services, programs, or activities, when viewed in their entirety, must be readily accessible to and usable by individuals with disabilities. This standard, known as "program accessibility," applies to all existing facilities of a public entity. Public entities, however, are not necessarily required to make each of their existing facilities accessible.

The results of these surveys form the basis of this transition plan update and strategy for remediation or resolution of identified barriers. (*Exhibit II – Program/Facility Survey*)

Surveys were also created for policy/procedure and communication compliance. These surveys solicited information on how County agencies communicate with the public, and how policies and procedures might adversely affect the disabled community, or provide for their inclusion in County programs and services as required under the Americans with Disabilities Act. This portion of the review provides important context to the detail of the program and facility assessment surveys. (*Exhibit III - Policies and Practices Survey* and *Exhibit IV – Communications Survey*)

## ADA Transition Plan Update Team

The Office was given discretion to expeditiously hire ADA Specialists for the reviews. This mobilization effort, and the development of all the necessary survey tools, occurred in January, 2006, within six weeks of the Task Force's direction. Four ADA Specialists were hired to work with the County's ADA Administrator on the assessment process.

The resulting Broward County ADA Transition Update Team has been instrumental in undertaking and completing the review of County facilities and programs required under the Americans with Disabilities Act. Through their hard work and dedication during the update's first phase, the team has provided the County with the raw facility and program data necessary to review ADA compliance countywide.

The Transition Plan Update Team is headed by *Maria A. Colon*, the County's ADA Administrator. Ms. Colon is responsible for coordinating the ADA Transition Plan Update process, and supervising the transition plan team in its activities, from the initial program and facility surveys, to completion of the Transition Plan Update report and monitoring of compliance during its implementation. Ms. Colon is a graduate of American International College in Springfield, Massachusetts, and Cambridge College, in Cambridge, Massachusetts, and has a wealth of experience in compliance activities associated with the Americans with Disabilities Act and equal opportunity. She is a tireless advocate for the disabled community in Broward County and a champion of equal opportunity.

The Transition Plan Update Team included the following specialist staff:

*Brandon Jewell* is a graduate of Purdue University, and also holds a J.D. degree from Capital University Law School in Columbus, Ohio. His legal expertise has proven a great asset to the smooth operation of the Transition Plan Update process. He is also an outstanding ADA advocate in his own right.

*Enrique Madrinan* has a comprehensive understanding of the Americans with Disabilities Act, and has previously served as an ADA Coordinator in California. A graduate of California State University—Hayward with dual Bachelor's degrees, Mr. Madrinan brings practical experience in support of the ADA law, and dedication to the team's mission.

*Glenn McCormick* is an accomplished attorney and legal affairs manager. Mr. McCormick, who holds a J.D. degree from Stetson University, has worked tirelessly in support of the Transition Plan Update process, and has been a model of dedication to his work on the project. His analyses of compliance with the ADA show a remarkable depth of understanding and expertise.

*Andrea Pantoja* is a graduate of Central University of Puerto Rico, and has served as the Director of a regional office of the Puerto Rican Ombudsmen for Persons with Disabilities, Protection and Advocacy Center of Puerto Rico. Ms.

Pantoja's experience and understanding of ADA compliance has been of great importance to the team's successful completion of its survey work.

The Team also benefited greatly from the services of the Office of the County Attorney, and in particular the support of *Ben Salzillo*. Mr. Salzillo's expertise and capacity for understanding the work of the ADA Transition Plan Update in legal terms proved to be a consistently valuable resource.

### **Self-Evaluation/Data Collection**

The development of an ADA Transition Plan Update requires the County to complete a number of requirements. While the requirements are broadly defined to apply evenly across all public entities, the resulting ADA Transition Plan Update, once completed, is a unique document of the specific entity's effort to achieve inclusion for its disabled community.

The general requirements of Title II of the Americans with Disabilities Act are as follows:

#### **A. Establishment of Disability Affairs Section and Position of ADA Coordinator**

The passage of the Americans with Disabilities Act in 1990 led to the establishment of the County's disability affairs compliance program in 1992. The program was initially decentralized to all County using agencies, with the Office of Equal Opportunity acting as a coordinator in support of the primary efforts of the agencies. The determination was made at the time that, given the size of the agencies and the scope of their programs, remedial actions necessary for compliance under the Americans with Disability Act would be best handled by the agencies themselves, given their understanding of their program requirements and facilities.

The Office of Equal Opportunity has, under this Transition Plan Update, been directed to centralize its oversight role and see to the full implementation of this transition program countywide. The Office of Equal Opportunity, through its Disability Affairs section, has assumed the management and coordination of the County's ADA compliance program for all general fund programs. In the case of the Aviation Department and the Office of Transportation, the Office of Equal Opportunity will provide a limited coordination role, with technical assistance provided to said agencies on an as-requested basis, as these agencies will continue to be decentralized due to their size and the nature of their functional responsibilities

The Disability Affairs section of the Office of Equal Opportunity is responsible for tracking the County's compliance with the Americans with Disabilities Act and other state and local regulations governing equal access, such as the Florida Accessibility Code, and the Broward County Human Rights Ordinance. The section is also focused on effective implementation of countywide initiatives for improving access for those with disabilities.

This section is headed by the ADA Coordinator, who in Broward County is the ADA Administrator/HIPAA Privacy Officer. A more detailed description of the Disability Affairs section and the responsibilities of the ADA Administrator/HIPAA Privacy Officer are included as an exhibit to this report (Exhibit V – ADA Administrator Job Description)

#### B. Issue Notice of ADA Requirements

In accordance with Section 35.106 of the ADA, during the initial self-evaluation process conducted in 1992, the County reviewed the requirements of issuance of the ADA notice of compliance. The Broward County notice is in keeping with the letter and spirit of the ADA legislation, and has therefore not been subject to revision by the Office of Equal Opportunity under this Transition Plan Update. (*Exhibit VI – Notice of Compliance with the Americans with Disabilities Act*)

#### C. Grievance Procedures for County Services, Programs and Activities

As required under Title II of the ADA, in 1992, Broward County reviewed its Grievance Procedures for adherence to both the letter and intent of the Americans with Disabilities Act. The only adjustment necessary under this update was the deletion of outdated language for internal routing of grievances involving County employment. (*Exhibit VII – ADA Grievance Procedures*)

#### D. Policies and Procedures Review

The goal of the ADA is to integrate people with disabilities into existing programs instead of creating separate programs. An entity cannot require an individual to participate in a separate program nor can it restrict an individual from participating in general programs and activities. Individuals with disabilities must be assured an equal opportunity to participate in the programs, services and activities offered by a public entity. Programs, services and activities are required to be delivered in the most integrated and appropriate setting possible.

Under the ADA, public entities are required to “make reasonable modifications in policies, practices, or procedures when the modifications are necessary to avoid discrimination on the basis of disability.” They are required to do so in every situation, unless they can demonstrate “that making the modifications would fundamentally alter the nature of the service, program, or activity.”

The Reasonable Modification requirement is perhaps the most important element of a programmatic access infrastructure. It states that says every policy, procedure, and practice is potentially subject to modification. This means that the County will do whatever is reasonable to ensure that a person qualified to participate in a program or receive a service receives as effective a service as any other qualified individual.

Section 35.130(b)(7) of the ADA requires a thorough review of both the County's formal written policies and the actual operating practices of each program, service, or activity in relation to the general prohibitions against discrimination contained in Title II of the ADA. Consistent with this requirement, a General Policies and Practices Survey was sent to all Offices and Departments on June, 2006. Survey questions addressed a broad range of issues related to internal program operations and external relationships. (*Exhibit III - Policies and Procedures Survey*)

#### E. ADA Communications Review

In accordance with Section 36.160(a) of Title II of the ADA, a public entity is required to ensure effective communication with people with disabilities. Equally effective communication means communication access that is equally effective as that provided to people without disabilities. This includes the requirement that a public entity provide auxiliary aids and services upon the request of a qualified person with a disability.

The effective communication requirement of the ADA is targeted largely at barriers faced by people with sensory impairments; essentially, a requirement to reasonably modify the way information is communicated. What distinguishes the effective communication requirement from the general reasonable modification requirement of the ADA is the specificity of the modifications it mandates:

- For people with vision impairments: written material must be provided/accepted in large print, auditory or tactile (Brailled) form;
- For people with hearing impairments: oral communication must be provided/accepted in visual or amplified aural form;
- For people with speech impairments: oral communication must either be provided/accepted in written form, or the person must be allowed sufficient time to communicate whatever must be communicated.

It is important to note that the effective communication requirement applies to all communications, and it requires programs to do whatever is necessary to ensure that their communications are accessible to all people with disabilities, including people with cognitive disabilities, developmental disabilities, memory disabilities, brain injuries that result in confusion, various psychiatric disabilities, and others.

Broward County's self-evaluation included a complete assessment of policies, procedures, and resources necessary to ensure that people with disabilities are not excluded, segregated, or restricted in any way as the result of communication barriers. The purpose of this review was to assess the County's ability to provide communications to individuals with disabilities that is as effective as the communication provided to individuals who do not have disabilities. (*Exhibit IV – Communications Survey*)

## F. Employment Policies and Practices Review

Title II of the Americans with Disabilities Act prohibits a public entity from discriminating against a qualified applicant or employee with a disability. It is unlawful for a public entity to discriminate in any aspect of employment including: application, testing, interviewing, hiring, evaluation, discipline, compensation, promotion, termination and benefits.

To ensure compliance with the provisions of Title II of the ADA, the County is required to conduct a review of its employment policies and practices, including the protocol for handling requests for reasonable accommodations and the essential job functions associated with each job category.

Reasonable accommodation is a critical component of the ADA's assurance of nondiscrimination. Reasonable accommodation is any change in the work environment or in the way tasks are usually done that results in equal employment opportunity for an individual with a disability.

Essential job functions are those fundamental or critical job duties of the employment position the individual with a disability holds or desires. The term does not include the marginal tasks of the position. The ADA requires an employer to focus on the essential functions of a job to determine whether a person with a disability is qualified to do the job, with or without reasonable accommodation.

The regulations list several reasons why a function could be considered essential:

- The position exists to perform the function.
- There are a limited number of other employees available to perform the function, or among whom the function can be distributed.
- A function is highly specialized, and the person in the position is hired for special expertise or ability to perform it.

To identify essential job functions under the ADA, a job analysis should focus on the purpose of the job and the importance of actual job functions in achieving this purpose.

In the initial self-evaluation conducted in 1992, Broward County reviewed the applicable employment requirements of Title II of the Americans with Disabilities Act. As a result of this process, the County established the necessary procedures to handle requests for reasonable accommodations. (*Exhibit VIII – Reasonable Accommodations Request Procedures*)

Although significant changes are not required during this update, a review of the current applicable policies and practices revealed that County job descriptions do

not identify the essential job functions. The essential job functions are currently determined on an as-needed basis when a request for a reasonable accommodation is received by the Office of Equal Opportunity. This process may adversely impact the requirement to provide accommodations without unnecessary delay and can result in a violation of the ADA.

## **Phase II: Recommendations and Prioritization**

### **Data Analysis**

During Phase I of the ADA Transition Plan Update, the ADA Transition Team completed reviews of the County's policies and procedures, communication resources and all County programs (215), and facilities (141). The activities of the Team during this Phase generated approximately 10,000 pieces of paper, in reports and survey documents. During Phase II, the ADA Team conducted a detailed analysis of the data collected during Phase I and developed recommendations to correct identified deficiencies in each of the four major areas. In addition, cost estimates for removing barriers were generated by the appropriate County facility management agencies.

### **Policy and Procedures Survey Recommendations**

The results of the Policies and Procedures survey revealed that the County requires improvement in its ADA policies and procedures, and improvements to its disability training programs. Specifically:

- Employees are only generally familiar with the requirement to make "reasonable modifications" to the policies, practices and procedures in order to avoid discrimination.
- Employees need additional training and information about their obligations under Title II of the ADA.

In order to clearly outline the County's expectations to employees with regards to compliance with the Reasonable Modifications requirements of the ADA, the Transition Plan Update team developed a Reasonable Modifications Policy and associated procedures. This policy and its procedures have been reviewed by the Policy and Procedures subcommittee and recommended for the approval of the County Commission. (*Exhibit IX – Reasonable Modifications Policy and Procedures*)

### **Communications Survey Recommendations**

As previously indicated, Broward County's self-evaluation included a complete assessment of policies, procedures, and resources necessary to ensure that people with disabilities are not excluded, segregated, or restricted in any way as the result of communication barriers. The purpose of this survey was to assess the County's ability to provide communications to individuals with disabilities that is as effective as the communication provided to individuals who do not have disabilities.

A review of the survey results revealed that:

- Many County agencies are aware of the requirements to provide auxiliary aids and services to individuals with disabilities, upon their request, but this understanding is limited to a few individuals who are trained in ADA compliance.
- Written material prepared for public distribution is not readily available in accessible formats, such as large print, Braille or audiotape.
- Many agencies that provide a public service or work primarily with the public do not have Telecommunications Devices for Deaf, as required by the ADA.

#### A. Auxiliary Aids and Services

In order to be in compliance with Section 35.160(b)(1) of Title II of the ADA, the County is required to provide specific communication access in the form of auxiliary aids and services upon request of a qualified individual with a disability.

When it comes to basic communications, accessibility often can be created on the spot. For example, to explain written instructions to individuals who have vision impairments, employees can simply read the instructions out loud. In many basic transactions, such as paying bills or filing applications, communications provided through such simple methods will be as effective as the communications provided to other individuals in similar transactions. However, in situations that involve extensive, complex, or very significant communication, creating access may require the use of a communication device or a person with expertise in a certain form of communication, such as an American Sign Language interpreter. These devices and experts are referred to as "auxiliary aids and services," and under the ADA, programs are required to furnish them whenever their use will create equal access.

#### B. Sign Language Interpreter Services

When sign language interpretation is necessary for effective communication, Section 35.104 of the ADA requires that it be provided by a "qualified interpreter." Under the ADA, the term "qualified interpreter" is defined as an individual who is "able to interpret effectively, accurately, and impartially, both receptively and expressively, using any necessary specialized vocabulary". In order to satisfy this requirement, it is recommended that a pre-qualified library of eligible Sign Language Interpreter Services providers be established for this purpose.

#### C. Telecommunications Access

Section 35.161 of Title II of the ADA, requires that where communication by telephone is a major function of a particular agency within the County, TTY's should be available.

Under the ADA, programs that communicate with the public by telephone are required to also use an equally effective system for communicating with people who have hearing or speech impairments. This applies to incoming as well as outgoing calls, which means that if a program has a practice of allowing members of the public to use its phones to make outgoing calls, it must provide an equally effective alternative to members of the public with hearing or speech disabilities.

The most common device used to create telecommunications access is a teletype machine (TTY), which is a device that allows a user to send typed messages over standard telephone lines. Additionally, the state of Florida operates a free public service, called the Florida Relay Service (FRS), which connects a person using a TTY to a person using a standard telephone via a third party that also uses a TTY. There is also a new service through which a caller can connect to a third party via a video screen and thus communicate in sign language. However, because of the involvement of a third party, the FRS and the newer video relay services are only "equally effective" in circumstances in which privacy is not a concern. Therefore, people with hearing and speech disabilities often prefer direct TTY communication over communication by other means.

The Communications survey results identified 92 programs that are required to have TTY's in accordance with Section 35.161 of Title II of the ADA. The programs identified as requiring TTY's are:

- Programs where communication by telephone is a major function of the program and, as such, must provide direct access to individuals who rely on TTY's for telephone communication, such as Consumer Affairs, Human Resources/Staffing, County Records, Libraries, Regional Parks, etc. ;
- Programs that typically receive confidential information over the telephone, such as Sexual Assault hotline, Counseling unit, Child Protection, Substance Abuse Services, etc. ;
- Programs that provide telephones to members of the public for making outgoing calls, such as Family Success Centers, Homeless Shelters, etc.

Agencies that are not required to provide direct access to communications will be directed to utilize the Florida Relay Service to provide effective communication to persons with hearing or speech impairments.

To ensure access in telecommunications, it is recommended that TTY's be purchased for the 92 programs identified as requiring TTY's. Additionally, training must be provided to employees on the use of TTY's as well as the Florida Relay System. (*Exhibit X – List of Programs Requiring TTY's*)

#### D. Inclusion of Braille services in County agencies

One of the auxiliary aids that must be provided upon request is material in Braille. This service is currently offered in the Office of Equal Opportunity; requests are filled by the Office, for the County as a whole, as the need arises. This often results in significant delays in the delivery of services; therefore, it is not consistent with the requirement that materials should be readily available in alternative formats for distribution upon request. In order to ensure that all communications are accessible, including communication in the context of regular services and communication in public meetings and special events, and that County agencies are prepared to fulfill any request they might receive with minimum delay, it is recommended that Braille embossers be purchased and distributed to those agencies where the likelihood for this type of request is greatest. This decentralized distribution of the equipment will facilitate requests for Braille materials by individuals with visual impairments.

In order to clearly outline the County's expectations to employees with regard to compliance with the effective communication requirement of the Americans with Disabilities Act, the Transition Plan Update team developed an effective communication policy and associated procedures for requesting auxiliary aids and services. The policy and its procedures have been reviewed and approved by the Communications subcommittee and are recommended for the approval of the County Commission. (*Exhibit XI – Communications Policy and Procedures*)

The proposed Communications policies and procedures will bring necessary consistency and clarity to the delivery of services for individuals with disabilities. Additionally, the purchase of communication technology and equipment will ensure minimum delays in removing communication barriers and will ensure that employees have what they need to provide the individual service that is critical to programmatic and communication access.

#### **Employment Recommendations**

To ensure compliance with the provisions of Title II of the ADA, the County is required to conduct a review of its employment policies and practices, including the protocol for handling requests for reasonable accommodations and the essential job functions associated with each job category. As previously indicated, the essential job functions are currently determined on an as-needed basis when a request for a reasonable accommodation is received by the Office of Equal Opportunity. This process may adversely impact the requirement to provide accommodations without unnecessary delay and can result in a violation of the ADA.

The Equal Employment Opportunity Commission cites the following relevant factors in determining whether there has been an unnecessary delay in responding to a request for reasonable accommodation: (1) the reason(s) for the delay, (2) the length of the delay, (3) how much the individual with a disability and the employer each contributed to the delay, (4) what the employer was doing

during the delay, and (5) whether the required accommodation was simple or complex to provide.

In order to fully comply with the primary employment provisions of the ADA and avoid unnecessary delays in responding to requests for reasonable accommodations, it is recommended that within 90 days of adoption of the Transition Plan Update, the Human Resources Division submits to the Board of County Commissioners a plan outlining the manner upon which a review of all job categories to identify essential functions will be conducted. In the interim, it is recommended that positions associated with pending reasonable accommodation requests be evaluated on a priority basis, with other positions being evaluated as they become vacant and prior to commencement of a recruitment.

### **Priority System Development**

After Phase I was completed, the ADA Transition Plan Update team reviewed all program and facility assessment data. The intent of this initial review was to prepare for the process of making recommendations and prioritizing the recommendations to address identified deficiencies.

The Department of Justice recommends that a priority system be instituted to implement all recommendations for barrier removal. The primary prioritization system, meaning criteria by which recommendations are ordered, is at the discretion of the County. As part of Phase II, recognizing that the County has limited funds and cannot immediately make all buildings and facilities fully accessible, the ADA Transition Plan Update team recommended that the following primary criteria be used as the basis for prioritizing the removal of identified barriers:

- Priority One: Critical nature of the service provided: Facilities providing essential services related to health and safety and programs that are unique to a building, facility, or park and cannot occur at another location.
- Priority Two: Level of use by the public: Facilities that receive a high level of public use.
- Priority Three: Geographic distribution: by selecting a range of facilities that are distributed throughout the County, the County can ensure maximum access for all residents.

A secondary prioritization system—for program-based barrier removal actions—has been put forward by the Department of Justice for use by all entities in their prioritization of remedial actions. The Department of Justice criteria listed below are used to assist in the determination of specific program-based barrier removal actions within a building or facility, on a secondary basis to the primary criteria noted above.

- Priority One: The highest priority is placed on those barrier removal items that provide accessibility at the main entrance of a facility or improve a path of travel to the portion of the facility where program activities take place (e.g., parking, walks, ramps, stairs, doors, corridors, etc.).
- Priority Two: A second level priority is placed on those barrier removal items that improve or enhance access to program use areas (e.g., transaction counters, conference rooms, public offices, restrooms, etc.).
- Priority Three: A third level priority is placed on those barrier removal items that improve access to amenities serving program areas (e.g., drinking fountains, telephones, site furnishings, vending machines).

Based on the data collected during Phase I, the Phase II evaluations sought to prioritize recommendations based on priority as noted above.

### **Operational, Non-structural and Structural Recommendations**

As noted previously, the ADA Transition Plan Update Team completed reviews of all County programs (215) and facilities (141) during Phase I. During Phase II, 3072 recommendations were generated as a result of the Phase I survey review process. Recommendations developed during Phase II were sorted into three key categories, for ease in the management of data:

- OPERATIONAL: Modifications which require minimal or no cost. These may include moving furniture, adjusting or clearing reception areas, moving offices, and similar changes of this nature. 316 of the 3,072 recommendations were operational (10.3%).
- NON-STRUCTURAL: Modifications requiring effort beyond simple operational changes, that do not rise to the level of physical modification of existing facilities. Examples include door knobs, mirrors, signs, grab bars, and other control and operating mechanisms. 2,368 of the 3,072 recommendations involved non-structural recommendations (77%).
- STRUCTURAL: Modifications requiring changes to the physical construction of a facility, or work of similar scope. For Broward County, most structural changes involve work on parking lots and restrooms. 388 of the 3,072 recommendations involved structural recommendations (12.7%).

This categorization allowed for smooth dissemination of the recommendations to the agencies or individuals responsible for the implementation, whether the department heads themselves, in the case of operational recommendations, the Port Everglades and Parks and Recreation facilities teams, for their respective agencies, or the Public Works/Facility Management team for general fund non-structural and structural implementation and budget cost estimation.

## Database and Intranet Website

Each recommendation required review by County agencies, or by the facilities teams at Port Everglades, Parks & Recreation Division, or the Facilities Management team of Public Works. This presented problems for the team in getting information out to the agencies and receiving their responses regarding the compliance recommendations, prioritization and cost estimates of projects.

To solve this problem, a comprehensive database and internal website were created to handle the large volume of information. The database tracked programs and facilities and held the information required for analysis by the update team. Through the ADA Transition Plan Update Intranet website, agencies were able to access the surveys for their offices, departments, and divisions, review, and complete if necessary, the required information, and submit them to the team for processing on line.

Agency Directors were notified by the County Administrator via memorandum and were directed to examine the survey reports/recommendations, cost estimates and priority grouping information. Additionally, a section of the Intranet Website was designed to allow for collecting, calculating and reporting the cost estimates associated with the non-structural and structural recommendations from the Facilities Management Team.

## Cost Estimates

Based on the information obtained during the Transition Plan Update process, the ADA Transition Plan Update team is able to provide estimates of the costs associated with bringing the County into full compliance with the Americans with Disabilities Act in terms of its programs and facilities. The following budget summary reflects current cost estimates, by priority group, for implementing the recommendations developed during the ADA facility/program review process (see budget details in Attachment A):

<b>Priority Group</b>	<b>Public Works</b>	<b>Port Everglades</b>	<b>Parks</b>	<b>Operational</b>	<b>Totals</b>
<b>Priority 1</b>	\$629,751	\$0	\$3,285,200	\$135,250	<b>\$4,050,201</b>
<b>Priority 2</b>	\$2,356,464	\$0	\$833,700	\$0	<b>\$3,190,164</b>
<b>Priority 3</b>	\$29,400	\$276,050	\$402,100	\$0	<b>\$707,550</b>
<b>Final Estimated Costs</b>	<b>\$3,015,615</b>	<b>\$276,050</b>	<b>\$4,521,000</b>	<b>\$135,250</b>	<b>\$7,947,915</b>

*Note: Estimates are based on current pricing information and do not account for inflation or fluctuations in the cost of materials associated with implementation of these recommendations.*

Broward County presently has several facilities that are scheduled for closing within two years. All programs and services will be relocated from these facilities; as a result, no remediation efforts are necessary to bring these facilities into compliance with the Americans with Disabilities Act. While the Transition Plan Update Team did include these facilities in its review, the budget summary does not include those facilities that are scheduled for closing within the next two years, as no remedial costs are applicable. (*Exhibit XII– Facilities Closing*)

Additionally, the budget summary does not include the cost associated with bringing the Broward County Main Courthouse into compliance with the ADA. The Supreme Court of Florida has directed chief judges across the state to establish a Court Accessibility Team of persons with expertise on the ADA, individuals with disabilities, Clerk of Circuit Court, Court ADA Coordinator and County representatives, to survey the court facilities and develop updated transition plans. This initiative is expected to be completed by May 2008 and the Main Courthouse will be included in this effort.

### **Streets and Sidewalk Accessibility**

The ADA requires all public entities to install curb ramps at intersections where road constructions and alterations are done and to ensure that all curb ramps installed after January 26, 1992, are accessible to and usable by individuals with disabilities (28 C.F.R. § 35.151(b) and (e)). In addition, the ADA also requires that a schedule for providing curb ramps or other sloped areas be included in the transition plan.

Broward County Highway Construction and Engineering Division is responsible for maintaining records of streets and sidewalk accessibility. Since its initial ADA Transition Plan, the County has administered an aggressive curb ramp retrofit program. Of the original inventory of 326 intersections, 287 have been completed (or 88% of the original inventory). 39 remain pending (*Exhibit XIII – List of Intersections* )

The curb ramps installed were built in compliance with then existing State and Federal standards. However, since the standards have evolved, and are continuing to evolve, previously installed curb ramps should be re-evaluated for compliance with current accessibility standards. For instance, in 1994, the U.S. Access Board temporarily suspended the requirements for detectable warnings at curb ramps due to concerns raised about the specifications, the availability of complying products, usefulness and safety. As a result, the requirements were temporarily removed from the ADA standards. The suspension expired on July 26, 2001. Consequently, the requirements for detectable warnings at curb ramps and other areas are again part of the Americans with Disabilities Act Accessibility Guidelines (ADAAG) and the enforceable standards.

It is therefore recommended that within 90 days of adoption of this ADA Transition Plan Update, the Broward County Highway Construction and Engineering Division establishes a formal process and schedule to re-evaluate

previously installed curb ramps for compliance with current accessibility standards.

Additionally, in its Title II Technical Assistance Manual, the Department of Justice advises that to achieve or maintain program accessibility, it may be appropriate to establish an on-going procedure for installing curb ramps, upon request, in areas frequented by individuals with disabilities. It is recommended that the Broward County Highway Construction and Engineering Division develops such a procedure within 90 days of adoption of this ADA Transition Plan Update.

### **Lighting and Traffic Signals**

As required by 28 CFR Part 35 Subpart D, Title II of the Americans with Disabilities Act (ADA), municipalities and states must make their programs accessible if no undue hardship is imposed by the changes. Since pedestrian circulation is considered a program, accessible pedestrian signals (APS) may be necessary to provide access to certain types of existing intersections. Also, the ADA's effective communication requirement stipulates that information shall be communicated as effectively to people with disabilities as to all others.

In contrast to the requirements for streets and sidewalks, lighting and traffic signal requirements are less clearly defined by the ADA law. However, Broward County takes seriously the general requirements for accessibility and effective communication with regard to pedestrian safety for its citizens, and has instituted a process of review in keeping with its commitment to intersection safety.

To ensure that a resident is not denied use of sidewalks and street crossings because of a disability, a community may need to retrofit an existing signalized intersection with accessible pedestrian signals (APS) if it has been identified by one or more people as needing accessible crossing information. An accessible pedestrian signal (APS) provides the information that is conveyed in visual WALK signals in an audible, verbal, and/or vibrotactile manner indicating the crossing phase.

Broward County's current policy is to proactively address lighting and signal issues at intersections under its jurisdiction. Disabled individuals are encouraged to contact the County with regard to specific instances where retrofitting may be required to ensure safety of those with disabilities. Such contacts and requests may be directed to:

Jean Hanna, Systems Engineer  
Broward County Traffic Engineering Division  
2300 West Commercial Boulevard  
Fort Lauderdale, Florida 33309  
Telephone: 954-847-2600  
E-mail: [jhanna@broward.org](mailto:jhanna@broward.org)

Upon request, the Traffic Engineering Division may conduct a preliminary study that will take into consideration traffic and pedestrian volumes, vehicular speeds,

accident history, visibility, signal spacing, and other conditions. The data collected will then be analyzed according to Federally-mandated guidelines.

This process takes some time to complete, but it provides traffic engineers with enough information to reach decisions that will be in the best interests of public safety and efficient street operation. A study will take approximately 12 weeks. If the installation of a traffic signal or accessible pedestrian signal, or other retrofitting is deemed appropriate, it will be scheduled for installation, and will be prioritized based on our analysis of the data.

### **Community involvement and Outreach**

One of the key elements of the Transition Plan Update development is the participation of the disabled community. The participants from the disabled community can identify key issues that may not be readily apparent to staff members of the County. Their perspective on the impact of the barriers to program access is essential to the accuracy of our findings. To this end, interested persons, including individuals with disabilities or organizations representing individuals with disabilities, have had and will have the opportunity to comment on the proposed plan, at various opportunities and through various means:

- Status reports of the ADA Transition Plan Update were presented at Advisory Board of Individuals with Disabilities meetings.
- Special presentations on the ADA Transition Plan Update have been made to representatives of interested agencies, such as the Center for Independent Living, Paralyzed Veterans Association, National Federation of the Blind, and others.
- The County's Advisory Board for Individuals with Disabilities has indicated its support of the team's efforts, recommending that the barrier removal efforts proceed with main priorities of the health and safety of citizens, as well as facilities with a high level of public access.
- The Office of Equal Opportunity will continue to solicit public input through public presentations and forums hosted by the County's Advisory Board for Individuals with Disabilities. In addition, information about the County's Transition Plan Update, will be posted in an accessible ADA website which will allow the public to e-mail their input.

Moving forward, and upon Commission approval, the Office of Equal Opportunity will develop additional plans to inform the community about the Transition Plan Update, its processes and outcomes, and how the plan benefits the community and improves accessibility. The Office of Equal Opportunity will issue public notices in both print, electronic media and accessible formats, advising the public of upcoming events, and coordinate logistics associated with holding the presentations. A major goal of this process will be the ongoing solicitation and

acceptance of feedback, and the implementation of improvements to the County's approach to ADA compliance that may arise from these meetings.

### ***Phase III: Adoption and Implementation***

Upon approval and adoption of the ADA Transition Plan Update, the County will be in compliance with the requirements of Title II of the Americans with Disabilities Act. But beyond the legal requirements, Broward County and its Board of County Commissioners are demonstrating, through this Transition Plan Update, their commitment to inclusion of all County citizens in public programs and facilities, as well as a dedication to transparency in government and to sustaining a high quality of life for residents. The institution of an ongoing ADA compliance monitoring system, coupled with increased community outreach and involvement, will ensure that Broward County will be a leader in the effort to comply with the Americans with Disabilities Act, and continue the County's commitment to inclusion.

#### **Public Outreach**

Public outreach, accountability, and transparency are all crucial to the success of the ADA Transition Plan Update. To this end, the Office of Equal Opportunity has made the use of technology a major part of the update effort from its inception. The intranet site, created during Phase II, has been central to the County's ability to complete this difficult process accurately and efficiently.

During Phase III, this intranet site will be expanded to include additional functionality. Some of the functions to be included are:

- C. An interface with the facility management system, for tracking of changes in facilities and their use;
- D. A lease review component; and
- E. A mechanism for tracking inspections of new facilities, and modifications to existing facilities.

Upon completion of the intranet website, and subject to the Board of County Commissioners approval, an ADA accessible external website will be developed for public use. This external website will be an important point of contact for citizens interested in information about the County's Transition Plan Update, its compliance with the Americans with Disabilities Act, and its status in implementing the recommendations developed through the update process.

This user-friendly website will have a vast array of information available, including facility and program information, recommended changes developed during this update process, timelines, and status reports. The Office of Equal

Opportunity intends for this website to set a positive precedent in outstanding customer service and high quality e-government. It is anticipated that the website will be deployed by the beginning of FY 2008.

### **Training**

Training and other internal communication is critical to the effectiveness of the program accessibility approach. Appropriate training and communication will maximize the level of ADA knowledge among program and facility managers and help ensure that violations do not occur because of lack of knowledge of the policies and procedures governing accessibility. For example, continuous staff training in the use of TTY's is necessary to ensure effective communication. Similarly, training addressing the requirements to modify County policies and practices is essential in ensuring that individuals with disabilities have an equal opportunity to participate in the programs, services and activities offered by the County.

The ADA Transition Plan Update team recommends the development of an ongoing training program for managers and supervisors. The model should account for the training of new employees; specialized training for County architects, engineers, facility managers, and park managers; and the need for keeping employees current on changes in the law and in County policies.

In addition, front line personnel should be trained as well, because they set the tone for the agency's interaction with the public, and they often have an enormous impact on access to services for individuals with disabilities.

During last year's budget process, \$100,000 was approved for a countywide ADA training program. However, it is expected that an aggressive ADA education and awareness campaign, of the sort envisioned for the roll-out of the ADA Transition Plan to the County and the community as a whole, would necessitate a budget of \$250,000. Enhancing inclusiveness through training will also help avoid the costs associated with litigation, as well as problems of exclusion that have long-term financial and organizational impacts.

## Communication and Training Budget Recommendations

The following chart represents the budget requirements for implementation of the Communications and Training recommendations resulting from the Phase II survey review. (Attachment B includes budget detail on Auxiliary aids and services, and Attachment C focuses on ADA Training Subjects).

Priority Group	TTY's	Sign Language Interpreters and other Contract Services	Braille Embossers and Software	Training	TOTALS
Priority 1	\$62,244	\$100,000	\$0	\$250,000	<b>\$412,244</b>
Priority 2	\$0	\$0	\$164,360	\$0	<b>\$164,360</b>
Priority 3	\$0	\$0	\$0	\$0	<b>\$0</b>
<b>Final Estimated Costs</b>	<b>\$62,244</b>	<b>\$100,000</b>	<b>\$164,360</b>	<b>\$250,000</b>	<b>\$576,604</b>

Communications recommendations noted as “Priority I” include the TTY and Interpretation Services noted above. The County Commission has the option of directing the inclusion of Braille embossers into the communications program throughout the County. The ADA Transition Plan Update team recommends the presence of Braille embossers in County agencies where the need is greatest, as not having them requires that County agencies requests the service from the Office of Equal Opportunity. This often results in significant delays in the delivery of services; therefore, it is not consistent with the requirement that materials should be readily available in alternative formats, upon request. Having a Braille embosser in the agency providing the service requires no extra time, and provides a high level of service to the citizen.

The amount of \$250,000 is a recommendation for a training budget for ADA issues throughout the County. The ADA Transition Plan Update team recommends that all County employees receive ADA training, but that Supervisors/Managers receive special training that addresses the issues they are likely to encounter as management staff. The team also recommends that specialized training be provided to County architecture and engineering staff, with the expectation of the development of countywide architectural standards in support of the Americans with Disabilities Act, and the County’s continued ADA compliance over the long-term.

## Summary

In light of new construction of County facilities, frequent shifting in programs assigned to existing facilities, and a general increase in the number and scope of programs and services offered to the public by Broward County, the County began work on its ADA Transition Plan Update process in May, 2004. The consultant-based approach taken by the County was attempted for a period, but it became clear that a different approach—one that drew directly on the expertise of County staff—was a more appropriate path to take.

The resulting programmatic approach involved the creation of a task force model, and a three phase approach: data collection, analysis, and implementation. With the Phase I program and facility surveys being handled directly by the ADA Transition Plan Update Team, the County saw a more advantageous use of its resources. This allowed the ADA Transition Plan Update reviews to be successfully completed in an expedited fashion.

Given the programmatic approach taken by the ADA Transition Plan Update Team, Broward County will pay much less than anticipated to attain and maintain ADA compliance. The County currently has capital reserve funds, already in place, to handle the vast majority of tasks required to attain compliance, through the implementation of the recommendations put forward by the ADA Transition Plan Update team. By working together, County agencies have seen the importance of the ADA Update and the cost savings associated with handling most of the remedial programmatic actions within the County.

However, while this programmatic approach has been shown to be less costly and more efficient, the caveat is that program and facility managers must be knowledgeable in ADA compliance. In order to maintain acceptable levels of compliance with the requirements of the Americans with Disabilities Act, it is essential that Managers and Supervisors continue to receive ADA training that addresses the issues they are likely to encounter. Additionally, architectural and engineering staff must receive specialized training with the expectation that county wide architectural design standards be developed.

The County will ensure the highest level of compliance with the requirements of the ADA, through technology and the integration of systems to interface with the facility management system, for tracking of changes in facilities and their use; inspections of new facilities; and modifications to existing facilities.

In approving this ADA Transition Plan Update, the Broward County Board of County Commissioners is emphasizing its commitment to program and service accessibility for all of its citizens. Upon approval, implementation of the program, with its focused enhancements to facilities and programs, inclusion of additional policy and communication enhancements, and accent on community outreach and training, will commence.

## Recommendations

In order to achieve full compliance with the requirements of Title II of the Americans with Disabilities Act, the ADA Transition Plan Update Team recommends the following:

- That the ADA Transition Plan Update be adopted by the Board of County Commissioners.
- That the Policy and Procedures recommended as a result of the policy/procedures review be approved for implementation.
- That the Policy and Procedures governing County communications be approved for implementation.
- That a pre-qualified library of eligible Sign Language Interpretation providers be established.
- That the communications budget for TTY's and Sign Language Interpretation Services be approved.
- That the County Commission consider optional funding for additional Braille equipment throughout the County at high-impact locations, to provide enhanced service to the disabled community.
- That within 90 days of adoption of the Transition Plan Update, the Human Resources Division submits to the Board of County Commissioners a plan to review all job categories, to identify essential functions of each position, and that in the interim, positions associated with pending reasonable accommodation requests be evaluated on a priority basis, with other positions being evaluated as they become vacant and prior to commencement of a recruitment.
- That the recommendations governing operational, non-structural, and structural modifications be implemented.
- That the recommended prioritization criteria for the removal of identified barriers be adopted.
- That the ADA facility cost estimates be approved.
- That the following implementation schedule for barrier removal be implemented:
  - ✓ Operational modification: 12 months from adoption of Transition Plan Update;

- ✓ Non-structural modifications: 24 months from adoption of Transition Plan Update, or if out sourced, from contract award and;
  - ✓ Structural Modification: 24 months from contract award, if out sourced.
- 
- That within 90 days of adoption of the Transition Plan Update, the Broward County Highway Construction and Engineering Division establishes a formal process to re-evaluate previously installed curb ramps for compliance with current accessibility standards, and an on-going procedure for installing curb ramps, upon request, in areas frequented by individuals with disabilities.
  - That an additional \$150,000 budget be approved for a comprehensive Americans with Disabilities Act training program for County managers, supervisors, front line personnel, architects and engineers.
  - That the development of architectural Design Standards for Broward County be approved.
  - That an external website for public use be developed to keep Citizens informed about the County's progress with the implementation of the ADA Transition Plan Update.

**Broward County, Florida  
ADA Transition Plan Update**

**EXHIBITS**

Exhibit I	Facility Inventory Listing
Exhibit II	Program/Facility Survey
Exhibit III	Policies and Practices Survey
Exhibit IV	Communications Survey
Exhibit V	ADA Administrator Job Description
Exhibit VI	Notice of Compliance with the Americans with Disabilities Act
Exhibit VII	ADA Grievance Procedures
Exhibit VIII	Reasonable Accommodations Request Procedures
Exhibit IX	Reasonable Modifications Policy And Procedures
Exhibit X	List of Programs Requiring TTYs
Exhibit XI	Communications Policy and Procedures
Exhibit XII	Facility Closings
Exhibit XIII	List of Intersections Pending Assessment and Retrofitting
Attachment A	List of Attachments <ul style="list-style-type: none"><li>• Cost Estimates Summary</li></ul>
Attachment B	Structural and Programmatic Details Cost Estimates <ul style="list-style-type: none"><li>• Public Works</li><li>• Port Everglades</li><li>• Parks and Recreation</li><li>• Structural and Programmatic Recommendations</li></ul>
Attachment C	Agency/ Program Operational Cost Estimates <ul style="list-style-type: none"><li>• Operational Recommendations</li></ul>
Attachment D	Auxiliary Aids and Services Cost Estimates by Program
Attachment E	Training Subject Areas
Attachment F	Program List by Department

# ADA Programmatic Assessment By Facility

## 1 ANIMAL CARE AND REGULATION - NORTH

3100 NW 19 TERR	District 2	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
POMPANO BEACH	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Sam Katzen	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-831-1401		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

## 2 ANIMAL CARE AND REGULATION - SOUTH

1871 SW 40TH ST	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Craig Schuler	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-680-0002		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>
Note: Facility scheduled for closing			

## 3 BROWARD ADDICTION RECOVERY CENTER - BOOHER BUILDING

3275 NW 99 WAY	District 3	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
CORAL SPRINGS	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Paul Jaquith	Year Built: 1986	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5444		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

## 4 BROWARD ADDICTION RECOVERY CENTER - CENTRAL

1011 SW 2 CT	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input checked="" type="checkbox"/>
Contact Name: Paul Jaquith	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5444		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>
Note: Facility scheduled for closing			

## 5 BROWARD ADDICTION RECOVERY CENTER - DAVIE

4175 DAVIE ROAD	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
DAVIE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Paul Jaquith	Year Built: Not Available	County Owned:	<input type="checkbox"/>
Contact Phone: 954-357-5444		County Responsible for ADA Compliance:	<input type="checkbox"/>
Note: Leased County Cost			

**6 BROWARD ADDICTION RECOVERY CENTER - SOUTH**

5701 HOLLYWOOD BLVD District 6 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 1 Has Special Features Report   
Contact Name: Paul Jaquith Year Built: 1974 County Owned:   
Contact Phone: 954-357-5444 County Responsible for ADA Compliance:

**7 BROWARD EMERGENCY SERVICES BUILDING**

2601 W BROWARD BLVD District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 1 Has Special Features Report   
Contact Name: Anne Rawlings Year Built: 1965 County Owned:   
Contact Phone: 954-577-4613 County Responsible for ADA Compliance:

**8 BROWARD SHERIFF OFFICE - DISTRICT 5**

200 NE 27 AVENUE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Peter Arida Year Built: Not Available County Owned:   
Contact Phone: 954-831-8945 County Responsible for ADA Compliance:

**9 BUILDING CODE SERVICES**

955 S FED HIWAY District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 1 Has Special Features Report   
Contact Name: Gloria Miller Year Built: Not Available County Owned:   
Contact Phone: 954-357-6480 County Responsible for ADA Compliance:   
Note: Facility scheduled to be sold

**10 CASE MANAGMENT SERVICES (HUMAN SERVICES)**

4200 NW 16 ST District 9 Priority Group 1,3,4 Completed   
LAUDERHILL Priority 1 Has Special Features Report   
Contact Name: Paul Jaquith Year Built: 1965 County Owned:   
Contact Phone: 954-357-5444 County Responsible for ADA Compliance:   
Note: Leased at Non-County Cost

**11 CENTRAL DISTRICT PARKS**

2555 NW 21ST AVENUE District 9 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Chester Pruitt Year Built: Not Available County Owned:   
Contact Phone: 954-497-1658 County Responsible for ADA Compliance:

12	CENTRAL HOMELESS SHELTER
----	--------------------------

920 NW 7 AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input checked="" type="checkbox"/>
Contact Name: Gloria Miller	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6480		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

13	CLERK OF COURT ARCHIVES
----	-------------------------

529 SW 2 AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Katrina Jackson	Year Built: 1968	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

14	CONVENTION CENTER
----	-------------------

1950 EISENHOWER BLVD	District 4	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Carlos Puentes	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-765-5925		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

15	EMERGENCY OPERATIONS CENTER
----	-----------------------------

201 NW 84TH AV	District 1	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
PLANTATION	Priority 1	Has Special Features Report	<input checked="" type="checkbox"/>
Contact Name: Peter Arida	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-831-8945		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

16	EMPLOYMENT ASSISTANCE PROGRAM (HUMAN RESOURCES)
----	-------------------------------------------------

1317 SE 4 AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Gloria Miller	Year Built: 1940	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6480		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

17	ENVIRONMENTAL MONITORING FACILITY
----	-----------------------------------

3211 COLLEGE AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
DAVIE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Nancy Grossman	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-519-1487		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

18	<b>EXTENSION EDUCATION SERVICE</b>
----	------------------------------------

3245 COLLEGE AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
DAVIE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Henry Tarquine	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-370-3725		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

19	<b>FAMILY SUCCESS ADMINISTRATION DIVISION</b>
----	-----------------------------------------------

2995 N DIXIE HIGHWAY	District 4	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
OAKLAND PARK	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Fred Murry	Year Built: 1972	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6333		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

20	<b>FORT LAUDERDALE HEALTH CENTER</b>
----	--------------------------------------

2421-A SW 6 AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Audrey Cohen	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-7419		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

21	<b>FORT LAUDERDALE SATELLITE CENTER (HUMAN SERVICES)</b>
----	----------------------------------------------------------

333 SW 28 ST	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Audrey Cohen	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-7419		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

22	<b>GOVERNMENTAL CENTER ANNEX</b>
----	----------------------------------

115 SOUTH ANDREWS AV	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Gloria Miller	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6480		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

23	<b>GOVERNMENTAL CENTER EAST</b>
----	---------------------------------

115 SOUTH ANDREWS AV	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Gloria Miller	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6480		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

24 GOVERNMENTAL CENTER WEST

1 N UNIVERSITY DRIVE District 1 Priority Group 1,3,4 Completed   
PLANTATION Priority 2 Has Special Features Report   
Contact Name: Gloria Miller Year Built: 1984 County Owned:   
Contact Phone: 954-357-6480 County Responsible for ADA Compliance:

25 GREATER FORT LAUDERDALE CONVENTION AND VISITORS BUREAU - ADMINISTRATIVE

100 E BROWARD BLVD, SUITE 200 District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Carlos Puentes Year Built: Not Available County Owned:   
Contact Phone: 954-765-5925 County Responsible for ADA Compliance:

26 HISTORICAL COMMISSION

151 SW 2 ST District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Gloria Miller Year Built: 1992 County Owned:   
Contact Phone: 954-357-6480 County Responsible for ADA Compliance:

27 HOUSING AND COMMUNITY DEVELOPMENT

110 NE 3RD ST, SUITE 300 District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Norm Howard Year Built: 1990 County Owned:   
Contact Phone: 954-765-5311 County Responsible for ADA Compliance:

28 JUVENILE ASSESSMENT CENTER

2600 SW 4 AVENUE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 1 Has Special Features Report   
Contact Name: Dave Ratliff Year Built: Not Available County Owned:   
Contact Phone: 954-765-4152 County Responsible for ADA Compliance:

29 LANIER JAMES EDUCATION CENTER

1050 NW 7 COURT District 8 Priority Group 1,3,4 Completed   
HALLANDALE Priority 2 Has Special Features Report   
Contact Name: Year Built: Not Available County Owned:   
Contact Phone: County Responsible   
Note: School board property for ADA Compliance:

30 LIBRARY - AFRICAN AMERICAN RESEARCH

2650 NW 6TH STREET District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Julie Hunter Year Built: 2002 County Owned:   
Contact Phone: 954-625-2800 County Responsible   
for ADA Compliance:

31 LIBRARY - ALVIN SHERMAN

3100 RAY FERRERO JR BLVD District 7 Priority Group 1,3,4 Completed   
DAVIE Priority 2 Has Special Features Report   
Contact Name: Molly Kinney Year Built: 2001 County Owned:   
Contact Phone: 954-262-4601 County Responsible   
for ADA Compliance:

32 LIBRARY - BEACH BRANCH

221 POMPANO BEACH BLVD District 4 Priority Group 1,3,4 Completed   
POMPANO BRACH Priority 2 Has Special Features Report   
Contact Name: William Fritz Year Built: 1986 County Owned:   
Contact Phone: 954-786-2197 County Responsible   
for ADA Compliance:

33 LIBRARY - CARVER RANCHES

4735 SW 18 ST District 8 Priority Group 1,3,4 Completed   
WEST PARK Priority 2 Has Special Features Report   
Contact Name: Elizabeth Lindley Year Built: 1982 County Owned:   
Contact Phone: 954-985-1945 County Responsible   
for ADA Compliance:

34 LIBRARY - CENTURY PLAZA

1890 W HILLSBORO BLVD District 2 Priority Group 1,3,4 Completed   
DEERFIELD BEACH Priority 2 Has Special Features Report   
Contact Name: Elizabeth Lambert Year Built: 1995 County Owned:   
Contact Phone: 954-360-1330 County Responsible   
for ADA Compliance:

35 LIBRARY - COLLIER CITY

2800 NW 9 CT District 9 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 2 Has Special Features Report   
Contact Name: Debra Floyd Year Built: 1977 County Owned:   
Contact Phone: 954-968-3820 County Responsible for ADA Compliance:

36 LIBRARY - DANIA BEACH

255 E. DANIA BEACH BLVD District 4 Priority Group 1,3,4 Completed   
DANIA BEACH Priority 2 Has Special Features Report   
Contact Name: Coleen Thorson Year Built: 2001 County Owned:   
Contact Phone: 954-926-2420 County Responsible for ADA Compliance:   
Note: Leased at Non-County Cost

37 LIBRARY - DAVIE COOPER CITY

4600 SW 82 AVE District 7 Priority Group 1,3,4 Completed   
DAVIE Priority 2 Has Special Features Report   
Contact Name: Neil Pollack Year Built: 1982 County Owned:   
Contact Phone: 954-680-0050 County Responsible for ADA Compliance:

38 LIBRARY - DEERFIELD BEACH

837 E HILLSBORO BLVD District 4 Priority Group 1,3,4 Completed   
DEERFIELD BEACH Priority 2 Has Special Features Report   
Contact Name: Lisa Manners Year Built: 1969 County Owned:   
Contact Phone: 954-360-1380 County Responsible for ADA Compliance:

39 LIBRARY - FORT LAUDERDALE BRANCH (HOLIDAY PARK)

1300 E SUNRISE BLVD. District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: William Elliott Year Built: 1991 County Owned:   
Contact Phone: 954-765-4263 County Responsible for ADA Compliance:

40 LIBRARY - GALT OCEAN MILE

3403 GALT OCEAN DR District 4 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Marlene Barnes Year Built: 1992 County Owned:   
Contact Phone: 954-537-2877 County Responsible for ADA Compliance:   
Note: Leased at Non-County Cost

41 LIBRARY - HALLANDALE

300 S FEDERAL HWY District 6 Priority Group 1,3,4 Completed   
HALLANDALE Priority 2 Has Special Features Report   
Contact Name: Carol French Year Built: 1981 County Owned:   
Contact Phone: 954-457-1750 County Responsible   
Note: Leased County Cost: Non-renewal 9-30-2009 for ADA Compliance:

42 LIBRARY - IMPERIAL POINT

5985 NORTH FEDERAL HWY District 4 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Becky Peters Year Built: 1988 County Owned:   
Contact Phone: 954-492-1881 County Responsible   
for ADA Compliance:

43 LIBRARY - LAUDERDALE LAKES

3521 NW 43 AVE District 9 Priority Group 1,3,4 Completed   
LAUDERDALE LAKES Priority 2 Has Special Features Report   
Contact Name: Greg Sidberry Year Built: 1969 County Owned:   
Contact Phone: 954-497-3627 County Responsible   
Note: Leased County Cost for ADA Compliance:

44 LIBRARY - LAUDERHILL

6399 W OAKLAND PARK BLVD District 1 Priority Group 1,3,4 Completed   
LAUDERHILL Priority 2 Has Special Features Report   
Contact Name: Elzbieta Pileszcza Year Built: 2005 County Owned:   
Contact Phone: 954-497-1630 County Responsible   
for ADA Compliance:

45 LIBRARY - LAUDERHILL MALL

4257 NW 12 ST District 9 Priority Group 1,3,4 Completed   
LAUDERHILL Priority 2 Has Special Features Report   
Contact Name: Mary-Alice Gage Year Built: 1986 County Owned:   
Contact Phone: 954-791-1000 County Responsible   
Note: Leased - No renewal 9-30-2008 for ADA Compliance:

46 LIBRARY - MAIN

100 S ANDREWS AVE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Cindy Shulman Year Built: 1984 County Owned:   
Contact Phone: 954-357-7444 County Responsible   
for ADA Compliance:

47 LIBRARY - MARGATE

5810 PARK DRIVE District 2 Priority Group 1,3,4 Completed   
MARGATE Priority 2 Has Special Features Report   
Contact Name: Susan Hodos Year Built: 1978 County Owned:   
Contact Phone: 954-968-3800 County Responsible for ADA Compliance:

48 LIBRARY - NORTH LAUDERDALE

6901 KIMBERLY BLVD District 9 Priority Group 1,3,4 Completed   
NORTH LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Joan Hinton Year Built: 2007 County Owned:   
Contact Phone: 954-968-3840 County Responsible for ADA Compliance:

49 LIBRARY - NORTH REGIONAL

1100 COCONUT CREEK BLVD District 2 Priority Group 1,3,4 Completed   
COCONUT CREEK Priority 2 Has Special Features Report   
Contact Name: Debbie Passalacqua Year Built: 1972 County Owned:   
Contact Phone: 954-201-2600 County Responsible for ADA Compliance:   
Note: Leased County Cost/Shared

50 LIBRARY - NORTH WEST POMPANO

1580 NW 3 AVE District 2 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 2 Has Special Features Report   
Contact Name: Rhonda Walker Year Built: 1994 County Owned:   
Contact Phone: 954-786-2186 County Responsible for ADA Compliance:

51 LIBRARY - NORTH WEST REGIONAL

3151 N UNIVERSITY DRIV District 3 Priority Group 1,3,4 Completed   
CORAL SPRINGS Priority 2 Has Special Features Report   
Contact Name: Barbara Schumach Year Built: 2002 County Owned:   
Contact Phone: 954-341-3900 County Responsible for ADA Compliance:

52 LIBRARY - PEMBROKE PINES

955 NW 129 AVE District 5 Priority Group 1,3,4 Completed   
PEMBROKE PINES Priority 2 Has Special Features Report   
Contact Name: Essie Denoms Year Built: 1999 County Owned:   
Contact Phone: 954-437-2635 County Responsible for ADA Compliance:   
Note: Leased County Cost/Shared

53 LIBRARY - POMPANO BEACH

1213 E ATLANTIC BLVD District 2 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 2 Has Special Features Report   
Contact Name: Janice Rolle Year Built: 1952 County Owned:   
Contact Phone: 954-786-2181 County Responsible   
Note: Leased County Cost for ADA Compliance:

54 LIBRARY - RIVERLAND

2710 DAVIE BLVD District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Frances Addison- Year Built: 1974 County Owned:   
Contact Phone: 954-791-1085 County Responsible   
for ADA Compliance:

55 LIBRARY - SOUTH WEST REGIONAL

16835 SHERIDAN STREET District 8 Priority Group 1,3,4 Completed   
PEMBROKE PINES Priority 2 Has Special Features Report   
Contact Name: Ellen Lindenfeld Year Built: 2000 County Owned:   
Contact Phone: 954-538-9956 County Responsible   
for ADA Compliance:

56 LIBRARY - STIRLING ROAD

3151 STIRLING ROAD District 7 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 2 Has Special Features Report   
Contact Name: Elaine Wise Year Built: 2003 County Owned:   
Contact Phone: 954-985-2689 County Responsible   
for ADA Compliance:

57 LIBRARY - SUNRISE

10550 W OAKLAND PARK BLVD District 3 Priority Group 1,3,4 Completed   
SUNRISE Priority 2 Has Special Features Report   
Contact Name: Ann Miller Year Built: 1995 County Owned:   
Contact Phone: 954-749-2521 County Responsible   
for ADA Compliance:

58 LIBRARY - SUNSET STRIP

6600 SUNSET STRIP District 9 Priority Group 1,3,4 Completed   
SUNRISE Priority 2 Has Special Features Report   
Contact Name: Robert Stearns Year Built: 1975 County Owned:   
Contact Phone: 954-749-2525 County Responsible   
Note: Leased Non-County Cost for ADA Compliance:

59 LIBRARY - TAMARAC

8701 W COMMERCIAL BLVD District 3 Priority Group 1,3,4 Completed   
TAMARAC Priority 2 Has Special Features Report   
Contact Name: Linda Kamin Year Built: 2004 County Owned:   
Contact Phone: 954-720-2284 County Responsible for ADA Compliance:

60 LIBRARY - TYRONE BRYANT

2230 NW 21 AVE District 9 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Kara McGowan Year Built: 1980 County Owned:   
Contact Phone: 954-497-1675 County Responsible for ADA Compliance:

61 LIBRARY - WEST ATLANTIC

10641 W ATLANTIC BLVD District 3 Priority Group 1,3,4 Completed   
CORAL SPRINGS Priority 2 Has Special Features Report   
Contact Name: Rita Talchick Year Built: 1994 County Owned:   
Contact Phone: 954-341-3912 County Responsible for ADA Compliance:   
Note: Leased Non-County Cost

62 LIBRARY - WEST REGIONAL

8601 W BROWARD BLVD District 1 Priority Group 1,3,4 Completed   
PLANTATION Priority 2 Has Special Features Report   
Contact Name: Terry Kutolowski Year Built: 2007 County Owned:   
Contact Phone: 954-831-3311 County Responsible for ADA Compliance:   
Note: New library opened since assessment

63 LIBRARY - WESTON

4205 BONAVENTURE BLVD District 8 Priority Group 1,3,4 Completed   
WESTON Priority 2 Has Special Features Report   
Contact Name: Mary Ellen Euban Year Built: 2006 County Owned:   
Contact Phone: 954-389-2098 County Responsible for ADA Compliance:

64 MAIN COURTHOUSE

201 SE 6TH ST District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Katrina Jackson Year Built: 1968 County Owned:   
Contact Phone: 954-357-5711 County Responsible for ADA Compliance:

65 MASS TRANSIT ADMINISTRATION

3201 COPANS RD District 2 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 2 Has Special Features Report   
Contact Name: James Fourcade Year Built: 1988 County Owned:   
Contact Phone: 954-357-8441 County Responsible for ADA Compliance:

66 MASS TRANSIT MAIN TERMINAL

101 N.W. 1ST AVENUE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: James Fourcade Year Built: Not Available County Owned:   
Contact Phone: 954-357-8441 County Responsible for ADA Compliance:

67 MASS TRANSIT TRANSFER FACILITY

100 N PINE ISLAND RD District 1 Priority Group 1,3,4 Completed   
PLANTATION Priority 2 Has Special Features Report   
Contact Name: James Fourcade Year Built: Not Available County Owned:   
Contact Phone: 954-357-8441 County Responsible for ADA Compliance:

68 MEDICAL EXAMINER

5301 SW 31 AVE District 7 Priority Group 1,3,4 Completed   
DANIA BEACH Priority 1 Has Special Features Report   
Contact Name: George Danz Year Built: 1974 County Owned:   
Contact Phone: 954-327-6500 County Responsible for ADA Compliance:

69 MENTAL HEALTH

2677 NW 19 ST District 9 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 1 Has Special Features Report   
Contact Name: Paul Jaquith Year Built: Not Available County Owned:   
Contact Phone: 954-357-5444 County Responsible for ADA Compliance:

70 MIDRISE OFFICE

540 SE 3 AVE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Katrina Jackson Year Built: 1990 County Owned:   
Contact Phone: 954-357-5711 County Responsible for ADA Compliance:

71 NORTH FAMILY SUCCESS CENTER

2011 NW 3 AVE District 2 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 1 Has Special Features Report   
Contact Name: Fred Murry Year Built: Not Available County Owned:   
Contact Phone: 954-357-6333 County Responsible for ADA Compliance:

72 NORTH HOMELESS ASSISTANCE CENTER

1700 BLOUNT ROAD District 9 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 1 Has Special Features Report   
Contact Name: Steve Werthman Year Built: Not Available County Owned:   
Contact Phone: 954-357-6167 County Responsible for ADA Compliance:

73 NORTH REGIONAL COURTHOUSE

1600 W HILLSBORO BLVD District 2 Priority Group 1,3,4 Completed   
DEERFIELD BEACH Priority 2 Has Special Features Report   
Contact Name: Sam Katzen Year Built: 1978 County Owned:   
Contact Phone: 954-831-1401 County Responsible for ADA Compliance:

74 NORTH REGIONAL HEALTH CENTER (HUGES BUILDING)

205 NW 6 AVENUE District 9 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 1 Has Special Features Report   
Contact Name: Audrey Cohen Year Built: 1991 County Owned:   
Contact Phone: 954-357-7419 County Responsible for ADA Compliance:

75 NORTH REGIONAL HEALTH CENTER (HUNTER BUILDING)

601 W ATLANTIC BLVD District 9 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 1 Has Special Features Report   
Contact Name: Audrey Cohen Year Built: 1988 County Owned:   
Contact Phone: 954-357-7419 County Responsible for ADA Compliance:

76 NORTH WEST FAMILY SUCCESS CENTER

10077 NW 29 ST District 3 Priority Group 1,3,4 Completed   
CORAL SPRINGS Priority 1 Has Special Features Report   
Contact Name: Fred Murry Year Built: Not Available County Owned:   
Contact Phone: 954-357-6333 County Responsible for ADA Compliance:

77 NORTH WEST HEALTH CENTER AIDS CLINIC

624 NW 15 WAY District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 1 Has Special Features Report   
Contact Name: Audrey Cohen Year Built: 1968 County Owned:   
Contact Phone: 954-357-7419 County Responsible for ADA Compliance:

78 OUR HOUSE

408 NE 4TH STREET District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 1 Has Special Features Report   
Contact Name: Michael Elwell Year Built: 1950 County Owned:   
Contact Phone: 954-357-7880 County Responsible for ADA Compliance:

79 PARKS - BOATERS PARK

DANIA BEACH CUT OFF CANAL District 7 Priority Group 1,3,4 Completed   
DANIA BEACH Priority 1 Has Special Features Report   
Contact Name: Bill Gilmartin Year Built: 2000 County Owned:   
Contact Phone: 954-985-1980 County Responsible for ADA Compliance:

80 PARKS - BOULEVARD GARDENS PARK

304 NW 28 WAY District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Pamela Ali Year Built: Not Available County Owned:   
Contact Phone: 954-625-2988 County Responsible for ADA Compliance:

81 PARKS - BRIAN PICCOLLO PARK

9501 SHERIDAN ST District 5 Priority Group 1,3,4 Completed   
COOPER CITY Priority 1 Has Special Features Report   
Contact Name: Ray Lopez Year Built: 1989 County Owned:   
Contact Phone: 954-437-2600 County Responsible for ADA Compliance:

82 PARKS - CB SMITH PARK

900 N FLAMINGO RD District 5 Priority Group 1,3,4 Completed   
PEMBROKE PINES Priority 1 Has Special Features Report   
Contact Name: Jeannie Hildebran Year Built: 1982 County Owned:   
Contact Phone: 954-437-2657 County Responsible for ADA Compliance:

83 PARKS - CRYSTAL LAKE

3299 NE 3RD AVENUE District 2 Priority Group 1,3,4 Completed   
POMPANO BEACH Priority 3 Has Special Features Report   
Contact Name: Patti J. Hillebert Year Built: Not Available County Owned:   
Contact Phone: 954-360-1320 County Responsible for ADA Compliance:

84 PARKS - DEERFIELD ISLAND PARK

1720 DEERFIELD ISLAND District 4 Priority Group 1,3,4 Completed   
DEERFIELD BEACH Priority 1 Has Special Features Report   
Contact Name: Patti J. Hillebert Year Built: 1980 County Owned:   
Contact Phone: 954-360-1320 County Responsible for ADA Compliance:

85 PARKS - DELEVOE PARK

2520 N.W. 6TH STREET District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Rich Laudia Year Built: 1998 County Owned:   
Contact Phone: 954-791-1036 County Responsible for ADA Compliance:

86 PARKS - EASTERLIN PARK

1000 NW 38 ST District 9 Priority Group 1,3,4 Completed   
OAKLAND PARK Priority 2 Has Special Features Report   
Contact Name: Ross Dovey Year Built: 1965 County Owned:   
Contact Phone: 954-938-0610 County Responsible for ADA Compliance:

87 PARKS - FERN FOREST PARK

201 LYONS ROAD SOUTH District 2 Priority Group 1,3,4 Completed   
COCONUT CREEK Priority 2 Has Special Features Report   
Contact Name: Nikki Hochberg Year Built: 1985 County Owned:   
Contact Phone: 954-970-0150 County Responsible for ADA Compliance:

88 PARKS - FRANKLIN PARK

2501 FRANKLIN DRIVE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Michelle Welsh Year Built: 2000 County Owned:   
Contact Phone: 954-791-1037 County Responsible for ADA Compliance:

89 | PARKS - HILLSBORO PINELAND PARK

5591 NW 74 PLACE District 2 Priority Group 1,3,4 Completed   
COCONUT CREEK Priority 3 Has Special Features Report   
Contact Name: Patti J. Hillebert Year Built: 2004 County Owned:   
Contact Phone: 954-360-1320 County Responsible for ADA Compliance:

90 | PARKS - HOLLYWOOD NORTH BEACH PARK

3601 N OCEAN DR District 6 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 2 Has Special Features Report   
Contact Name: Jimmie Davis Year Built: 1986 County Owned:   
Contact Phone: 954-926-2480 County Responsible for ADA Compliance:

91 | PARKS - LAFAYETTE HART PARK

2851 NW 8TH ROAD District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Warren Powers Year Built: Not Available County Owned:   
Contact Phone: 954-791-1041 County Responsible for ADA Compliance:

92 | PARKS - LEWIS CHISM PARK

2620 NW 8TH STREET District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Michelle Welsh Year Built: 1966 County Owned:   
Contact Phone: 954-791-1037 County Responsible for ADA Compliance:

93 | PARKS - MARKHAM PARK

16001 W SR84 District 5 Priority Group 1,3,4 Completed   
SUNRISE Priority 1 Has Special Features Report   
Contact Name: Brian McLaughlin Year Built: 1973 County Owned:   
Contact Phone: 954-389-2000 County Responsible for ADA Compliance:

94 | PARKS - MCTYRE PARK

3500 SW 56 AVE District 8 Priority Group 1,3,4 Completed   
PEMBROKE PARK Priority 3 Has Special Features Report   
Contact Name: Chris Trujillo Year Built: 1994 County Owned:   
Contact Phone: 954-964-0283 County Responsible for ADA Compliance:

95 | PARKS - PLANTATION HERITAGE PARK

11S FIGTREE LANE District 7 Priority Group 1,3,4 Completed   
PLANTATION Priority 2 Has Special Features Report   
Contact Name: Bill Hartl Year Built: 1984 County Owned:   
Contact Phone: 954-791-1025 County Responsible for ADA Compliance:

96 | PARKS - QUIET WATERS PARK

401 S POWERLINE RD District 2 Priority Group 1,3,4 Completed   
DEERFIELD BEACH Priority 1 Has Special Features Report   
Contact Name: Erik Westberg Year Built: 1983 County Owned:   
Contact Phone: 954-360-1315 County Responsible for ADA Compliance:

97 | PARKS - ROOSEVELT GARDENS

2800 NW 11TH ST District 9 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Michelle Welsh Year Built: Not Available County Owned:   
Contact Phone: 954-791-1037 County Responsible for ADA Compliance:

98 | PARKS - SECRET WOODS NATURE CENTER

2701 SR84 District 7 Priority Group 1,3,4 Completed   
DANIA BEACH Priority 2 Has Special Features Report   
Contact Name: Victor Suarez Year Built: 1978 County Owned:   
Contact Phone: 954-791-1030 County Responsible for ADA Compliance:

99 | PARKS - SNAKE WARRIOR ISLAND

3600 SW 62 AVE District 8 Priority Group 1,3,4 Completed   
MIRAMAR Priority 3 Has Special Features Report   
Contact Name: Maureen O'Rourke Year Built: 2006 County Owned:   
Contact Phone: 954-985-1960 County Responsible for ADA Compliance:

100 | PARKS - SUN VIEW PARK

1500 SW 42ND AVE District 7 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 2 Has Special Features Report   
Contact Name: Gloria Augustine Year Built: 1963 County Owned:   
Contact Phone: 954-731-1040 County Responsible for ADA Compliance:



107	<b>PARKS - WOODMONT PINELAND</b>
-----	----------------------------------

7250 NW 80 AVENUE	District 3	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
TAMARAC	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Patti J. Hillebert	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-360-1320		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

108	<b>PARKS ADMINISTRATION BUILDING - NORTH</b>
-----	----------------------------------------------

950 NW 38 ST	District 9	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
OAKLAND PARK	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Melinda Carlisle	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-8112		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

109	<b>PERSONNEL - ANNEX B</b>
-----	----------------------------

115 SOUTH ANDREWS AV	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Gloria Miller	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6480		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

110	<b>PORT EVERGLADES - ADMINISTRATION</b>
-----	-----------------------------------------

1850 ELLER DRIVE	District 6	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Jennifer Ganary	Year Built: 1987	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-523-3404		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

111	<b>PORT EVERGLADES - BUILDING 1 (TERMINAL)</b>
-----	------------------------------------------------

1800 SE 18 STREET	District 4	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Jennifer Ganary	Year Built: 1958	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-523-3404		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

112	<b>PORT EVERGLADES - BUILDING 18 (TERMINAL)</b>
-----	-------------------------------------------------

1901 SE 32 STREET	District 4	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Jennifer Ganary	Year Built: 1964	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-523-3404		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

113 PORT EVERGLADES - BUILDING 19 (TERMINAL)

2019 ELLER DRIVE District 4 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1966 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

114 PORT EVERGLADES - BUILDING 2 (TERMINAL)

1801 SE 20 STREET District 4 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1957 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

115 PORT EVERGLADES - BUILDING 21 (TERMINAL)

2021 ELLER DRIVE District 4 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1967 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

116 PORT EVERGLADES - BUILDING 22 (TERMINAL)

2022 ELLER DRIVE District 4 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1968 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

117 PORT EVERGLADES - BUILDING 24 (TERMINAL)

2024 ELLER DRIVE District 4 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1968 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

118 PORT EVERGLADES - BUILDING 25 (TERMINAL)

2025 ELLER DRIVE District 6 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1987 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

119 PORT EVERGLADES - BUILDING 26 (TERMINAL)

2026 ELLER DRIVE District 6 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1987 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

120 PORT EVERGLADES - BUILDING 29 (TERMINAL)

2200 SE 35 STREET District 6 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1991 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

121 PORT EVERGLADES - BUILDING 4 (TERMINAL)

1800 SE 20 STREET District 4 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1987 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

122 PORT EVERGLADES - BUILDING 611 (OFFICE)

2550 EISENHOWER BLVD District 4 Priority Group 1,3,4 Completed   
FORT LAUDERDALE Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1964 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

123 PORT EVERGLADES - MIDPORT PARKING GARAGE

2020 ELLER DRIVE District 4 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: 1994 County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

124 PORT EVERGLADES - NORTHPORT PARKING GARAGE

2000 EISENHOWER BLVD District 4 Priority Group 1,3,4 Completed   
HOLLYWOOD Priority 3 Has Special Features Report   
Contact Name: Jennifer Ganary Year Built: Not Available County Owned:   
Contact Phone: 954-523-3404 County Responsible for ADA Compliance:

125	<b>PORT EVERGLADES - PUBLIC SAFETY OFFICES</b>
-----	------------------------------------------------

1901 ELLER DRIVE	District 4	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Jennifer Ganary	Year Built: 1988	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-523-3404		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

126	<b>PROPERTY APPRAISER EXTENSION</b>
-----	-------------------------------------

101 SW 1 AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Gloria Miller	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6480		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

127	<b>PUBLIC DEFENDER</b>
-----	------------------------

412 SE 6TH STREET	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Katrina Jackson	Year Built: 1978	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

128	<b>READING CENTER - HOLLYWOOD BEACH</b>
-----	-----------------------------------------

1301 S. OCEAN DRIVE	District 6	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 2	Has Special Features Report	<input checked="" type="checkbox"/>
Contact Name: Craig Schuler	Year Built: 1971	County Owned:	<input type="checkbox"/>
Contact Phone: 954-680-0002		County Responsible for ADA Compliance:	<input type="checkbox"/>
Note: Leased Non-County Cost			

129	<b>SEXUAL ASSAULT CENTER</b>
-----	------------------------------

400 NE 4 ST	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input checked="" type="checkbox"/>
Contact Name: Michael Elwell	Year Built: 1961	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-7880		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

130	<b>SOUTH BROWARD FIELD OFFICE</b>
-----	-----------------------------------

7999 W PEMBROKE ROAD	District 6	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
PEMBROKE PINES	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Audrey Cohen	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-7419		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

131	SOUTH FAMILY SUCCESS CENTER		
-----	-----------------------------	--	--

4733 SW 18 ST	District 8	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Fred Murry	Year Built: 1982	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-6333		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

132	SOUTH REGIONAL COURTHOUSE		
-----	---------------------------	--	--

3550 HOLLYWOOD BLVD	District 6	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Craig Schuler	Year Built: 1980	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-680-0002		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

133	SOUTH REGIONAL HEALTH CENTER		
-----	------------------------------	--	--

4105 PEMBROKE RD	District 6	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
HOLLYWOOD	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Audrey Cohen	Year Built: 1971	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-7419		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

134	STATE ATTORNEY		
-----	----------------	--	--

16 SE 6 ST	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Katrina Jackson	Year Built: 1956	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

135	TAG AGENCY		
-----	------------	--	--

815 NE 13 ST	District 9	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Sam Katzen	Year Built: 1961	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-831-1401		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

136	TRAFFIC ENGINEERING BUILDING		
-----	------------------------------	--	--

2300 W COMMERCIAL BLVD	District 9	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Sam Katzen	Year Built: 2004	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-831-1401		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

137	VINNETTE CAROL THEATER
-----	------------------------

503 SE 6 ST	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Katrina Jackson	Year Built: 1968	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

138	VOTING EQUIPMENT WAREHOUSE
-----	----------------------------

529 SW 2 AVE	District 7	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
FORT LAUDERDALE	Priority 3	Has Special Features Report	<input type="checkbox"/>
Contact Name: Katrina Jackson	Year Built: 1968	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

139	WATER AND WASTE WATER SERVICES
-----	--------------------------------

3701 N SR 7	District 9	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
LAUDERDALE LAKES	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Sam Katzen	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

140	WATER AND WASTE WATER SERVICES ENGINEERING DIVISION
-----	-----------------------------------------------------

2555 W COPANS ROAD	District 2	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
POMPANO BEACH	Priority 1	Has Special Features Report	<input type="checkbox"/>
Contact Name: Sam Katzen	Year Built: Not Available	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-357-5711		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

141	WEST REGIONAL COURTHOUSE
-----	--------------------------

100 N PINE ISLAND RD	District 1	Priority Group 1,3,4 Completed	<input checked="" type="checkbox"/>
PLANTATION	Priority 2	Has Special Features Report	<input type="checkbox"/>
Contact Name: Peter Arida	Year Built:	County Owned:	<input checked="" type="checkbox"/>
Contact Phone: 954-831-8945		County Responsible for ADA Compliance:	<input checked="" type="checkbox"/>

<b>Grand Total</b>	141
--------------------	-----

**PROGRAM/FACILITY SURVEY**

Facility Name		Address	
Facility Contact Person		Phone	
Program		Program Contact Person	
Phone		Email Address	
Worksheet Completed by		Date	

PRIORITY 1	ACCESSIBLE APPROACH/ENTRANCE		
Route of Travel			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Is there a route of travel that does not require the use of stairs?			
Is the route of travel stable, firm and slip resistant?			
Is the route at least 36 inches wide?			
Can all objects protruding into the circulation paths be detected by a person with a visual disability using a cane?  In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 80 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.			

## PROGRAM/FACILITY SURVEY

PRIORITY 1	ACCESSIBLE APPROACH/ENTRANCE			
Ramps	Technical Requirements	Comments	Yes	No
		Use this space to indicate actual dimensions of spaces and elements.		
	Do all ramps longer than 6 feet have railings on both sides.			
	Are railings sturdy, and between 34 and 38 inches high?			
	Is the width between railings or curbs at least 36 inches?			
	Are ramps non-slip?			
	Is there a 5 foot-long landing at every 30-foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?			
	Does the ramp rise no more than 30 inches between landings?			

## PROGRAM/FACILITY SURVEY

PRIORITY 1	ACCESSIBLE APPROACH/ENTRANCE																										
Parking and Drop-Off Areas																											
Technical Requirements	Comments	Yes	No																								
	Use this space to indicate actual dimensions of spaces and elements.																										
<p>Are the minimum number of accessible parking spaces provided, based on the total number of available parking spaces (see table below)?</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;"><u>Total Spaces</u></th> <th style="text-align: left;"><u>Require Minimum Number of Accessible Spaces</u></th> </tr> </thead> <tbody> <tr><td>1 to 25</td><td>1</td></tr> <tr><td>26 to 50</td><td>2</td></tr> <tr><td>51 to 75</td><td>3</td></tr> <tr><td>76 to 100</td><td>4</td></tr> <tr><td>101 to 150</td><td>5</td></tr> <tr><td>151 to 200</td><td>6</td></tr> <tr><td>201 to 300</td><td>7</td></tr> <tr><td>301 to 400</td><td>8</td></tr> <tr><td>401 to 500</td><td>9</td></tr> <tr><td>501 to 1000</td><td>2% of total</td></tr> <tr><td>1001 and over</td><td>20% plus 1 for each 100 over 1000</td></tr> </tbody> </table>	<u>Total Spaces</u>	<u>Require Minimum Number of Accessible Spaces</u>	1 to 25	1	26 to 50	2	51 to 75	3	76 to 100	4	101 to 150	5	151 to 200	6	201 to 300	7	301 to 400	8	401 to 500	9	501 to 1000	2% of total	1001 and over	20% plus 1 for each 100 over 1000			
<u>Total Spaces</u>	<u>Require Minimum Number of Accessible Spaces</u>																										
1 to 25	1																										
26 to 50	2																										
51 to 75	3																										
76 to 100	4																										
101 to 150	5																										
151 to 200	6																										
201 to 300	7																										
301 to 400	8																										
401 to 500	9																										
501 to 1000	2% of total																										
1001 and over	20% plus 1 for each 100 over 1000																										
Are the accessible spaces the ones closest to an accessible entrance?																											
Are the accessible parking spaces at least 12 feet wide, with a 5 feet wide access aisle?																											

## PROGRAM/FACILITY SURVEY

PRIORITY 1	ACCESSIBLE APPROACH/ENTRANCE		
Parking and Drop-Off Areas (Continued)	Comments	Yes	No
Technical Requirements	Use this space to indicate actual dimensions of spaces and elements.		
For van-accessible spaces, is there vertical clearance of at least 98 inches for vehicle route to the parking space, the parking space, the access aisle and along the vehicle route to the exit? Is one in every eight accessible parking spaces (but not less than one) designated "van assessable"?			
Are all accessible parking spaces, including access aisle, relatively level (1:50 or 2%) in all directions?			
Does each accessible parking space have a sign with the symbol of accessibility that is visible when a vehicle is parked in the space?			
If there is a curb between the access aisle and the accessible route to the building, is there a curb ramp that meets the following requirement: a) Is the ramp surface at least 36" wide excluding flared side? b) is the slope (up or down the ramp) no more than 1:12?			
Are all spaces located on an accessible route no less than 44 inches wide so that users will not be compelled to walk or wheel behind parked vehicles?			

## PROGRAM/FACILITY SURVEY

PRIORITY 1	ACCESSIBLE APPROACH/ENTRANCE		
Entrance	Comments	Yes	No
Technical Requirements	Use this space to indicate actual dimensions of spaces and elements.		
Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?			
Can the alternate accessible entrance be used independently?			
Does the entrance door have at least 32 inches clear opening? (for a double door, at least one 32-inch leaf)			
Is there at least 18 inches of clear wall space on the pull side of the door, next to the handle?			
Is the threshold edge ¼ inch high or less, or if beveled edge, no more than ¾ inch high?			
If provided, are carpeting or mats a maximum of ½ inch high?			
Are edges securely installed to minimize tripping hazards?			
Is the door handle no higher than 48 inches and operable with a closed fist?			

## PROGRAM/FACILITY SURVEY

PRIORITY 1	ACCESSIBLE APPROACH/ENTRANCE		
Entrance (Continued)	Comments	Yes	No
Technical Requirements	Use this space to indicate actual dimensions of spaces and elements.		
Can doors be opened without too much force? (exterior maximum of 8.5 lbf; maximum is 5 lbf for interior doors)			
If the door has a closer, does it take at least 3 seconds to close?			

## PROGRAM/FACILITY SURVEY

PRIORITY 2	ACCESS TO PROGRAMS AND SERVICES		
Horizontal Circulation			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Does the accessible entrance provide direct access to main floor, lobby, or elevator?			
Are public spaces on an accessible route of travel?			
Is the accessible route to all public spaces at least 36 inches wide?			
Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?			
Doors			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Do doors into public spaces have a least a 32 inch clear opening?			
On the pull side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?			
Can doors be open without too much force? (5 lbf maximum for interior doors)			
Are door handles 48 inches high or less and operable with a closed fits?			
Are all thresholds edges 1/4 –inch high or less, or if beveled edge, no more than 3/4 inch high?			

## PROGRAM/FACILITY SURVEY

Room #:

Service/Activity:

<b>PRIORITY 2</b>	<b>ACCESS TO PROGRAMS AND SERVICES</b>		
<b>Rooms and Spaces</b>			
<b>Technical Requirements</b>	<b>Comments</b>	<b>Yes</b>	<b>No</b>
	Use this space to indicate actual dimensions of spaces and elements.		
Do the Door have at least 32 inches clear opening?			
Are all the aisles and pathways to materials and services at least 36 inches wide?			
Is there a 5 foot circle or T-shaped space for turning a wheelchair completely?			
Is carpeting low-pile, tightly woven, and securely attached along edges?			
In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?			
<b>Emergency Egress</b>			
<b>Technical Requirements</b>	<b>Comments</b>	<b>Yes</b>	<b>No</b>
	Use this space to indicate actual dimensions of spaces and elements.		
If emergency systems are provided, do they have both flashing lights and audible signals?			

## PROGRAM/FACILITY SURVEY

PRIORITY 2	ACCESS TO PROGRAMS AND SERVICES		
<b>Signage for Services</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
<p>If provided, do signs and room numbers designating permanent rooms and spaces where services are provided comply with the following signage requirements?</p> <ul style="list-style-type: none"> <li>• Signs mounted with centerline 60 inches from floor.</li> <li>• Mounted on wall adjacent to latch side of door, or as close as possible.</li> <li>• Raise characters, sized between 5/8 and 2 inches high, with high contrast ( for room numbers, rest rooms, exits)</li> <li>• Braille text of the same information.</li> <li>• If pictogram is used, it must be accompanied by raised characters and Braille</li> </ul>			
<b>Directional and Informational Signage</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
If mounted above 80 inches, do they have letters at least 3 inches high, with high contrast, and non-glare-finish?			
Do directional and informational signs comply with legibility requirements?			

## PROGRAM/FACILITY SURVEY

PRIORITY 2	ACCESS TO PROGRAMS AND SERVICES		
Controls	Comments	Yes	No
Technical Requirements	Use this space to indicate actual dimensions of spaces and elements.		
<p>Are all controls that are available for use by the public located at an accessible height?</p> <p>Reach ranges: The maximum height for a side reach is 54 inches; for forward reach, 48 inches. The minimum reachable height is 15 inches for a front approach and 9 inches for a side approach</p>			
Are they operable with a closed fist?			

## PROGRAM/FACILITY SURVEY

PRIORITY 2	ACCESS TO PROGRAMS AND SERVICES		
Seats, Tables, and Counters			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Are the aisles between fixed seating at least 36 inches wide?			
Are the tops of tables or counters between 28 and 34 inches high?			
Are knee spaces at accessible tables at least 27 inches high, 30 inches wide, and 19 inches deep?			
Are the tops of tables or counters between 28 and 34 inches high?			
Vertical Circulation			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Are there ramps, lifts, or elevators to all public levels?			
On each level, if there are stairs between the entrance and/or elevator and essential public areas, is there an accessible alternate route?			

## PROGRAM/FACILITY SURVEY

PRIORITY 2	ACCESS TO PROGRAMS AND SERVICES		
<b>Stairs</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
The following questions apply to stairs connecting levels not serviced by an elevator, ramp, or lift:			
Do treads have a non-slip surface?			
Do stairs have continuous rails on both sides, with extension beyond the top and bottom stairs?			
<b>Elevators</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Are there both visible and verbal or audible door opening/closing and floor indicators? (one tone = up, two tones = down)			
Are the call buttons in the hallway no higher than 42 inches?			
Do the controls inside the cab have raised and Braille lettering?			

## PROGRAM/FACILITY SURVEY

PRIORITY 2	ACCESS TO PROGRAMS AND SERVICES		
<b>Elevators (Continued)</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Is there a sign on both door jambs at every floor identifying the floor in raised and Braille letters?			
If an emergency intercom is provided, is it usable without voice communications?			
Is the emergency intercom identified by Braille and raised letters?			
<b>Lift</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Can the lift be used without assistance? If not is a call button provided?			
Is there at least 30 by 48 inches of clear spaces for a person in a wheelchair to approach to reach the controls and use the lift?			
Are controls between 15 and 48 inches high? (up to 54 inches if a side approach is possible)			

## PROGRAM/FACILITY SURVEY

PRIORITY 3	USABILITY OF REST ROOMS		
<b>Getting to the Rest Rooms</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
If the rest rooms are available to the public, is at least one rest room (either one for each sex, or unisex) fully accessible?			
Are there signs at inaccessible rest rooms that give directions to accessible ones?			
<b>Doorways and Passages</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Is there tactile signage identifying rest rooms?  Mounting signs on the wall, on the latch side of the door, complying with the requirements for permanent signage.			
Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and Braille included below them?			
Is the doorway at least 32 inches clear?			
Are doors equipped with accessible handles (operable with a closed fist) 48 inches high or less?			
Can doors be opened easily (5lbf maximum force)?			

## PROGRAM/FACILITY SURVEY

PRIORITY 3	USABILITY OF REST ROOMS		
<b>Doorways and Passages (Continued)</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? <i>(A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)</i>			
Is there a 36-inch wide path to all fixtures?			
<b>Stalls</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Is the stall door operable with a closed fist, inside and out?			
Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, Or is there a stall that is less accessible but that provides greater access than a typical stall (either 36 by 69 inches or 48 by 69 inches)?			
Is the doorway at least 32 inches clear?			
Are doors equipped with accessible handles (operable with a closed fist) 48 inches high or less?			

## PROGRAM/FACILITY SURVEY

PRIORITY 3	USABILITY OF REST ROOMS		
<b>Stalls (Continued)</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Can doors be opened easily (5lbf maximum force)?			
Is the toilet paper dispenser mounted below the grab bar no more than 36 inches from the back wall and at least 19 inches from the floor?			
In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet?			
Is the toilet seat 17 to 19 inches high?			
<b>Lavatories</b>			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Does one lavatory have a 30 inch wide by 48 inch deep clear space in front?  A maximum of 19 inches of the required depth may be under the lavatory.			
Is the lavatory rim no higher than 34 inches?			
Is there at least 29 inches from the floor to the bottom of the lavatory apron (excluding pipes)?			
Can the faucet be operated with one closed fist?			

## PROGRAM/FACILITY SURVEY

PRIORITY 3	USABILITY OF REST ROOMS		
Lavatories (Continued)			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? No higher than 48 inches if forward approach; no higher than 54 inches if parallel approach.			
Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower?			

## PROGRAM/FACILITY SURVEY

PRIORITY 4	ADDITIONAL ACCESS		
Drinking Fountains			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?			
Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standards height spout (or a single “hi-lo” fountain)?			
Are controls mounted on the front or on the side near the front edge, and operable with one closed fist?			
Is each water fountain cane-detectable (located within 27 inches of the floor or protruding into the circulation space less than 4 inches from the wall?			
Telephones			
Technical Requirements	Comments	Yes	No
	Use this space to indicate actual dimensions of spaces and elements.		
If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one?			
Is the highest operable part of the phone no higher than 48 inches (up to 54 inches if a side approach is possible)?			
Does the phone protrude no more than 4 inches into the circulation space?			

## PROGRAM/FACILITY SURVEY

PRIORITY 4	ADDITIONAL ACCESS		
Telephones (Continued)	Comments	Yes	No
Technical Requirements	Use this space to indicate actual dimensions of spaces and elements.		
Does the phone have push-button controls?			
Is the phone adapted with volume control?			
Is the phone adapted with volume control identified with appropriate signage?			
If there are four or more public phones in the building, is one of the phones equipped with a text telephone (TTY)?			
Is the location of the text telephone identified by accessible signage bearing the international TTY Symbol?			

# AMERICANS WITH DISABILITIES ACT

## POLICIES AND PRACTICES SURVEY



Office of Equal Opportunity  
Disability Affairs Section

Public entities are required to review both written policies and the actual operating practices used in programs and activities, to ensure that people with disabilities are not discriminated against. Title II contains broad prohibitions against discrimination, addressing issues of equal opportunity, integration, eligibility, methods of administration, relationships with contractors, location of facilities, licensing, and others.

In order to facilitate the gathering of information and the communication of these complex legal requirements to program staff, this worksheet groups the majority of the prohibitions into four sets of questions addressing internal program operations and two sets of questions addressing external relationships. The topics covered are:

### Internal Program Operations

- Equal opportunity to benefit
- Reasonable program modifications
- Surcharges and additional requirements
- Integrated settings and separate programs

### External Relationships

- Contracting with external organizations
- Licensing and certification

NOTE: Whenever a question is not applicable, please note N/A

Department/Office: \_\_\_\_\_ Division/Section: \_\_\_\_\_

Worksheet Completed by: \_\_\_\_\_ Tel: \_\_\_\_\_ Date \_\_\_\_\_

---

**Location**

List all facilities or other locations where the program operates on a regular or incidental basis. (Use additional sheets if necessary)

---

**Description of Program**

Describe the purpose, scope, type of activities, number and type of participants, and other key information about the program (or attach existing descriptive information).

---

Sign-off: Program Manager: \_\_\_\_\_ Date: \_\_\_\_\_

ADA Specialist: \_\_\_\_\_ Date: \_\_\_\_\_

**INTERNAL PROGRAM OPERATIONS**

---

**Equal Opportunity to Participate and Benefit**

- a) A public entity may not deny a qualified individual with a disability and opportunity to participate in and benefit from any program. (Example: A public library may not refuse to allow a person with a cognitive disability the use of library facilities.)
  
- b) A public entity may not afford an opportunity that is not equal to or not as effective as that provided to others. (Example: A public recreation facility may not restrict the hours during which people with limited vision may use the facility to be less than the hours open to the general public.)
  
- c) A public entity may not impose eligibility criteria for participation in programs that screen out people with disabilities either directly or indirectly, unless such criteria are necessary for the provision of the program's activities. (Example: A scuba diving class cannot exclude people who use wheelchairs based on the assumption that people who use wheelchairs cannot swim well enough. However, the scuba call may require that all participants pass a swimming test if swimming is needed for safe participation in the class.)

Are there any circumstances in which the participation of a person with a disability in the program would be restricted or excluded?

If so, please describe.

Are any of these exclusions or restrictions necessary to the operation of the program or to the safety of the participants who do not have disabilities?

If so, please explain.

---

Sign-off: Program Manager: \_\_\_\_\_ Date: \_\_\_\_\_

ADA Specialist: \_\_\_\_\_ Date: \_\_\_\_\_

---

**Reasonable Program Modifications**

Public entities are required to make reasonable modifications to policies or practices in order to avoid discrimination towards people with disabilities. A modification is not required, however, if it would fundamentally alter the nature of the program or activity.

Is staff aware that it may be necessary to modify program policies or practices to enable people with disabilities to participate in and benefit from the program?

Is the public informed that the program is prepared to make reasonable modifications?

If so, please describe.

Does the program have a formal or informal process for responding to requests for modifications?

If so, please describe.

Does the program have a process for determining whether a policy or practice modification would fundamentally alter the nature of the program?

If so, Please describe.

---

**Surcharges and Additional Requirements**

Public entities may not impose extra charges upon people with disabilities to cover the costs of effective communication, program modifications, or access features, and may not impose any additional requirements or burdens on people with disabilities that they do not require of all other participants in the program. (Example: A public park may not require that a person with a disability bring a personal assistant in order to participate in a recreational program.)

Are there any circumstances in which a person with a disability would be asked to pay a fee or meet any other requirement not imposed on other program participants?

If so, please describe.

---

Sign-off: Program Manager: \_\_\_\_\_ Date: \_\_\_\_\_

ADA Specialist: \_\_\_\_\_ Date: \_\_\_\_\_

---

**Integrated Settings and Separate Programs**

Promoting integration is fundamental principle of the ADA and public entities are required to provide programs and activities in the most integrated settings appropriate to the needs of people with disabilities.

Separate programs or activities are permitted only when necessary to ensure equal opportunity. When separate programs are provided, qualified people with disabilities still cannot be excluded from participating in regular programs if they choose to do so. (Example: A county recreation program offers a swimming session once a week in which volunteer instructors provide individualized assistance to people with physical disabilities. People with physical disabilities may choose to participate in the assisted program or in the regular swim sessions where no individual assistance is provided.)

Does the program provide any separate activities for people with disabilities?

If yes, please describe how the separate activity contributes to affording people with disabilities an equal opportunity to benefit.

Are there any circumstances in which a person with a disability would be prohibited from participating in regular (non-separate) activities because of the provision of separate activities?

If yes, please describe.

---

Sign-off: Program Manager: \_\_\_\_\_ Date: \_\_\_\_\_

ADA Specialist: \_\_\_\_\_ Date: \_\_\_\_\_

**EXTERNAL RELTAIONSHIPS**

---

**Contacting with External Organizations**

When a public entity contracts with another organization to provide programs and services to the entity’s constituents the public entity retains responsibility for ensuring that the contractor provides the services and activities in a nondiscriminatory manner consistent with the requirements of Title II.

List any contractors who provide services, benefits, or activities on behalf of the program (or attach separate sheet if necessary).

Has the program notified each contractor of its responsibilities for providing contracted services in a nondiscriminatory manner and has the program required assurance from contractors of their fulfillment of Title II nondiscrimination and access requirements?

If so, please describe both the notification process and the process by which the entity will ensure compliance.

---

**Procurement Contracts**

In selecting procurement contractor, a public entity may not discriminate on the basis of disability. (Example: A food supplier could not be denied a contract to supply the entity’s cafeteria because a delivery person has AIDS.)

Are there any circumstances in which a consideration related to disability would influence the choice of a procurement contractor?

If so, please explain.

---

Sign-off: Program Manager: \_\_\_\_\_ Date: \_\_\_\_\_

ADA Specialist: \_\_\_\_\_ Date: \_\_\_\_\_

---

**Licensing and Certification1**

Public entities may not deny a license or certification to any person with a disability who meets the essential eligibility requirements for that license or certification. Eligibility requirements cannot include criteria that directly or indirectly screen out people with disabilities unless the criteria are necessary to the performance of the activity which is the object of the license or certification.

List any license or certifications that the program issues.

List any eligibility criteria that may tend to screen out people with disabilities-for example, criteria related to physical or mental fitness or performance, safety standards, or insurability requirements.

For each potentially exclusionary criterion, identify how the criterion is necessary to the performance of the activity to which the license or certificate applies.

---

Sign-off: Program Manager: \_\_\_\_\_ Date: \_\_\_\_\_

ADA Specialist: \_\_\_\_\_ Date: \_\_\_\_\_

# AMERICANS WITH DISABILITES ACT

## COMMUNICATION ACCESS SURVEY



Office of Equal Opportunity  
Disability Affairs Section

Title II of the Americans with Disabilities Act requires Governmental entities to provide effective means of communication to people with visual, hearing, speech and cognitive disabilities. The purpose of this survey is to assess the County's ability to provide communication for persons with disabilities that is as effective as the communication provided to persons who do not have disabilities. The information collected in this survey will allow the Disability Affairs Section to generate a summary of existing communications resources throughout the County and establish procedures for optimum sharing.

Department/Office: \_\_\_\_\_ Division/Section: \_\_\_\_\_  
 Worksheet Completed by: \_\_\_\_\_ Telephone: \_\_\_\_\_ Date: \_\_\_\_\_

Assess the current ability of the programs, services and activities to provide communication for persons with disabilities that are as effective as the communication provided to persons who do not have disabilities.

**Communication Access**

**Visual Communication**

Information that is communicated visually—such as through printed materials or visual displays—must be made accessible, upon request, to people with visual disabilities through auxiliary aids and services.

Does your operation involve information that is communicated visually?  Yes  NO

In the chart below, list each type of information that is communicated visually. Consider all aspects of the program, including, but not limited to outreach, advertising, public meetings or hearings, ceremonies, and communication with the general public, applicants, and other program participants. Examples may include brochures, forms, handbooks, textbooks, slide shows, videotapes, and visual displays.

For each type of information, place a √ below the auxiliary aids or services currently available to people with visual disabilities.

<b>Auxiliary Aids or Services</b>								
<i>Types of Information</i>	<i>Large Print</i>	<i>Braille</i>	<i>Audiotape</i>	<i>Readers</i>	<i>Verbal Descriptions</i>	<i>Computer Disk</i>	<i>Computer Adaptation</i>	<i>Other</i>

**Aural/Oral Communication**

(Note “Aural” refers to information that is heard; “Oral” refers to spoken information.)

Departments, Offices, Divisions and Sections that communicate information aurally to applicants or participants or that require an applicant or participant to use oral communication must make that information accessible to people who have hearing or speech disabilities by providing auxiliary aids and services.

Does your operation involve information that is communicated verbally? Yes NO

In the chart below, list each type of information that is communicated aurally/orally. Consider all communication involved in all aspects of the program activities. Consider all aspects of the operation, including but not limited to, outreach, advertising, public meetings or hearings, Interviews, counseling, ceremonies, and communication with the general public, applicants, and other participants. For instance, a variety of interpreters may be needed, from American Sign Language interpreters to oral interpreters for people who read lips or special interpreters for deaf-blind persons.

For each type of information, place a √ below the auxiliary aids or services currently available to people with hearing or speech disabilities.

<b>Auxiliary Aids or Services</b>								
<i>Types of Information</i>	<i>Interpreter</i>	<i>Assistive Listening Devices</i>	<i>Telephone Amplification</i>	<i>Note takers</i>	<i>Paper &amp; Pen</i>	<i>CART (real time)</i>	<i>Caption Decoder</i>	<i>Other</i>

## Primary Consideration

Title II's regulations require that public entities provide people with disabilities an opportunity to request the type of communication technology and assistance they prefer to use. In the ADA regulations, communication technology and assistance are called auxiliary aids and services.

An entity must give primary consideration to an individual's preference for an auxiliary aid or service and must honor it unless the entity can provide another effective means of communication.

Does the program inform people with disabilities that communication aids or services are provided upon request? Yes NO

If so, please explain.

Does the program have a procedure for deciding which auxiliary aid or service to provide? Yes NO

Does the procedure provide for consideration of an individual's preferred aid or service? Yes NO

Does the procedure include a mechanism for determining that an aid or service provided other than the requested aid or service is an effective means of communication? Yes NO

If the answer to any of these three questions is yes, please describe and/or attach procedure.

<b>TELECOMMUNICATIONS</b>
---------------------------

### Telephone Communications

When a public entity communicates with the public by telephone, Title II requires that Telecommunications Device for the Deaf (TDD) or equally effective means is used to communicate with people who have hearing or speech disabilities. Title IV of the ADA mandates that telephone companies develop telephone relay systems, which may be effective for short, uncomplicated communications. Public entities should use TDD's wherever telephone communication is a substantial part of a program's operation. Your answers to the following questions will help determine whether a TDD may be essential for your program.

Does the program communicate with the public over the phone? Yes NO

What kind of information is communicated by phone? Yes NO

Are telephone communications ever lengthy, complex, or technical? Yes NO

Does the program have a TTY? Yes NO

If so, has the staff been trained in the use of the TTY? Yes NO

Please describe training:

<b>OTHER COMMUNICATION</b>
----------------------------

**Emergency Warning and Evacuation**

Emergency evacuation procedures for the program, service, or activity must ensure that people with disabilities are made aware of emergencies and are aware of exit procedures.

Is there a means of ensuring that people who are hard of hearing or deaf are made aware of an activated alarm? Yes NO

Is there an established emergency evacuation procedure that addresses the needs of individuals with disabilities? Yes NO

If yes, provide a copy of procedure.

If no, please describe the procedures the program will use in facilities where means of egress are not accessible to provide safety and evacuation for people who cannot use stairs.

Do staff members receive training in emergency evacuation procedures? Yes NO

Please describe.

**Access Information**

The Title II regulation requires that public entities ensure that people with disabilities can obtain information about the availability and location of accessible programs, services, activities, and facilities. Information regarding location of accessible entrances, program sites, TTY's and other access features can be provided in a number of ways, such as in handbooks listings.

Explain how your program, service or activity provides access information to applicants, participants, and the general public.



---

Class Code: 8203

ADA ADMINISTRATOR/HIPAA PRIVACY OFFICER

NATURE OF WORK

This is highly responsible administrative planning work ensuring County compliance with the Americans with Disabilities Act (ADA) and monitoring County compliance with the Health Insurance Portability and Accountability Act (HIPAA).

Work involves developing and implementing policies and procedures to ensure that County programs and facilities are in compliance with ADA regulations. Work also involves the review of County agencies for compliance with and/or applicability of HIPAA regulations, and to ensure the privacy of protected health information (PHI) handled by the County as required by HIPAA. This may include program monitoring and problem resolution with regard to ADA and/or HIPAA compliance for accessibility to county programs, facilities, health care functions, social services, communications and transportation. Assignments are received in the form of broad policy statements and program goals. Performance is reviewed through conferences, written reports, and program results.

ILLUSTRATIVE TASKS

Develops policies to ensure that County programs and facilities comply with ADA; monitors ADA program and facility compliance activities of all County Offices, departments, and divisions.

Develops plans in compliance with federal regulations for submission to the County Administrator and the Board of County Commissioners for approval.

Coordinates county-wide self-evaluation surveys for assessing ADA compliance, and develops strategies for compliance implementation.

Coordinates planning efforts with municipalities in Broward County.

Serves as the County liaison with the Advisory Board for Persons with Disabilities.

Maintains appropriate administrative, technical and physical safeguards to protect the privacy of PHI.

Develops and maintains policies and procedures for appropriate response to individual requests for access, disclosure, correction and/or amendment of PHI.

Monitors the transmission of PHI between the covered and non-covered entities of County government.

Monitors federal regulations for updates in the HIPAA privacy rule.

Acts as central point of contact for HIPAA-related inquiries, information requests, and grievances; maintains appropriate records and information tracking systems regarding applicable HIPAA related inquiries.

Reviews contractual relationships between the County and HIPAA-defined business associates to insure the inclusion of HIPAA compliant policies and procedures.

Periodically reviews County programs for changes in HIPAA covered-entity status.

Supervises and directs the work of subordinate staff.

Perform related work as required.

#### KNOWLEDGE, ABILITIES AND SKILLS

Thorough knowledge of the principles and practices of organizational management and administration.

Thorough knowledge of all federal, state and local regulatory requirements applicable to ADA & HIPAA compliance.

Considerable knowledge of the functions and operations of the unit to which assigned.

Knowledge of supervisory principles and practices.

Ability to organize, plan implement and coordinate technical/administrative programs and activities.

Ability to express ideas effectively, both orally and in writing.

Ability to supervise employees in a manner conducive to full performance and high morale.

Ability to serve the public and fellow employees with honesty and integrity in full accord with the letter and spirit of Broward County's Ethics and Conflict of Interest policies.

Ability to establish and maintain effective working relationships with the general public, co-workers, elected and appointed officials and members of diverse cultural and linguistic backgrounds regardless of race, religion, age, sex, disability, political affiliation or sexual orientation.

#### REQUIRED EXPERIENCE AND TRAINING

Graduation from an accredited four year college or university with major course work in planning, Public or Business Administration or related field; six(6) years administrative experience in government and regulatory compliance, including HIPAA or other privacy laws; including two (2) years experience in working with disabled persons to ensure access in areas such as employment, public accommodations, transportation and communications; or any equivalent combination of relevant training and experience.

Broward County Board of County Commissioners



**NOTICE OF COMPLIANCE WITH  
THE AMERICANS WITH DISABILITIES ACT (28 CFR 35.106)**

In accordance with the requirements of Title II of the Americans with Disabilities Act (ADA) of 1990, Broward County does not discriminate on the basis of disability in the admission, access, or operations of its programs, services, activities or facilities. In accordance with Title II of the (ADA), when view in their entirety, Broward County government programs, services, activities and facilities are readily accessible to and usable by qualified individuals with disabilities.

**Employment:** The County does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under title I of the Americans with Disabilities Act (ADA).

**Effective Communication:** The County will generally, upon request, provide appropriate aids and services leading to effective communication for qualified individuals with disabilities so they can participate equally in the County's programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to individuals with speech, hearing, or vision impairments.

**Modifications to Policies and Procedures:** The County will make reasonable modifications to its policies, practices and programs to ensure that individuals with disabilities have an equal opportunity to enjoy all County programs, services, and activities. For example, individuals with service animals are welcomed in County offices, even where pets are generally prohibited.

The County will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids and services or reasonable modifications of policy, such as retrieving items from locations that are open to the public but are not accessible to persons who use Wheelchairs.

The ADA does not require the County to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.

The Office of Equal Opportunity Disability Affairs Section has been designated to

ensure the coordination of Broward County's compliance with the ADA, including the investigation of any complaint alleging Title II discrimination. Broward County has adopted an internal grievance procedure providing for prompt and equitable resolution of complaints alleging discrimination on the basis of disability in violation of the U.S. Department of Justice regulations implementing Title II of the ADA. This Procedure has been developed to comply with 28CFR35.107 (b).

Complaints that a County program, service, activity or facility is not accessible to individuals with disabilities should be directed to the County's ADA Administrator at 954-357-6500 or (954) 357-6181 (TTY).

**The Americans with Disabilities Act  
Grievance Procedure  
For County Services, Programs, Activities or Facilities**

Broward County established the following internal procedure to ensure the prompt and equitable resolution of complaints alleging discrimination on the basis of disability in the provision of programs, services, activities or benefits by the County. This grievance procedure is adopted pursuant to the regulations implementing Title II of the Americans with Disabilities Act (ADA). 28 C.F.R. Section 35.107.

Complaints related to County programs, services, activities or facilities should be address to:

Broward County ADA Administrator  
Office of Equal Opportunity  
Disability Affairs Section  
115 S. Andrews Ave., Room A680  
Ft. Lauderdale, FL 33301  
(954) 357- 6500  
(954) 357-6181 (TTY)

Complaints related to the County's Employment practices should be directed to the Broward County Office of Equal Opportunity Disability Affairs Section per established written procedures.

Grievance Procedure

1. All complaints shall include:
  - a) The name, address and telephone number of the person making the complaint;
  - b) The names, addresses and telephone numbers of witnesses;
  - c) A narrative and/or statement describing the alleged violation of the ADA, including date and time of the alleged violation and county program where the alleged violation occurred;
  - d) A narrative and/or statement identifying the recommended corrective actions to solve the alleged violation(s); and
  - e) Any other documentation to more fully explain or identify the alleged violation.

**Note:** *Alternative means of filing complaints, such as personal interviews or a tape recording of the complaint will be made available for persons with disabilities upon request.*

2. All complaints shall be filed no later than 30 days after the complainant becomes aware of an alleged violation.
3. Within 15 calendar days after receipt of the complaint, the ADA Administrator or designee will meet with the complainant to discuss the complaint and the possible resolutions.
4. Within 30 calendar days of the meeting, the ADA Administrator or designee will respond in writing, and where appropriate, in a format accessible to the complainant, such as large print, Braille, or audio tape. The response will explain the position of the County and offer options for substantive resolution of the complaint.
5. If the response does not satisfactorily resolve the issue, the complainant and/or his/her designee may appeal the decision within 15 calendar days after receipt of the response to the Director of the Office of Equal Opportunity or designee. The request must be submitted in writing.
6. Within 15 calendar days after receipt of the appeal, the Director of the Office of Equal Opportunity or designee will meet with the complainant to discuss the complaint and possible resolutions.
7. Within 15 calendar days after the meeting, the Director of the Office of Equal Opportunity or designee will respond in writing, and, where appropriate, in a format accessible to the complainant, with a final resolution of the complaint.

This Grievance Procedure shall be construed to protect the substantive rights of interested persons and to assure that the County meets the spirit and guidelines of the Americans with Disabilities Act (ADA).

## **Broward County ADA Reasonable Accommodation Process**

### **I. Employee Requests an Accommodation**

- In general, it is the responsibility of the employee with an impairment/disability to inform the employer that they are in need of an accommodation. When an employee notifies his/her supervisor of an impairment, associated difficulties performing job tasks, and the need for some type of change or modification, the supervisor should immediately refer the employee to the Disability Affairs Section in the Office of Equal Opportunity.
- If an employee with a known or obvious disability is having performance problems, a supervisor may suggest an accommodation, but only after making a preliminary determination that the performance problem is related to the employee's disability. *This is an exception to the general rule against inquiring about disabilities, and extends only to those with known or obvious disabilities.*

### **II. Employee Meets with a Representative of the Disability Affairs Section**

- Upon referral, a meeting will be scheduled with a representative of the Disability Affairs Section. Documentation of a "disability" and need for accommodation may be required (in most cases, it is required). The employee will receive an ADA Determination Questionnaire for his/her healthcare professional to complete.
- During the meeting it will be determined how the employee's impairment/disability limits his/her ability to perform the essential functions of his/her job, potential accommodations will be identified, and the effectiveness of such accommodations will be discussed. The meeting will also review any other issues that may be involved, i.e. labor relations issues, worker's compensation issues, requests for extended leaves of absence.
- The Division must provide a detailed, written job description to the Disability Affairs Section. This job description must delineate the "essential functions" of the position from the "marginal functions."

### **III. ADA Determination**

- After the initial interview and completion of the ADA Determination Questionnaire by the employee's healthcare professional, a "Determination Memo" will be sent to the employee's supervisor. The memo will state whether the employee is a "qualified individual with a disability," as defined by the ADA; it will outline the employee's essential functions needing accommodation; and will recommend methods of accommodation.
- Reassignment to a vacant position will be considered only when an accommodation is not possible in the employee's current position or when an accommodation in the employee's current position would cause an undue hardship. The employee must be qualified for, and able to perform the essential functions of the vacant position with or without reasonable accommodation.
- If reassignment is the accommodation, the employee will be given "a reasonable amount of time" in which to seek alternate employment within the County.
- If at the end of the specified period of time, the employee has not found alternate employment within the County, the Division has two options. The Division may, as a result of the employee not being qualified for any vacant position, opt to grant the employee an additional amount of time to seek alternate employment or they may separate the employee after consultation with the Human Resources Division.
- An employee is not required to accept an accommodation. However, if the employee refuses an accommodation necessary to perform the essential functions of his/her job, and as a result cannot perform those functions (and is no longer qualified), the individual may be separated from County employment.

### **IV. Review of Accommodations to Ensure Effectiveness**

- 4 - 6 weeks after the accommodations have been granted, the Division will assess the effectiveness of the accommodation(s) in enabling the employee to perform the essential functions of his/her job. If there is a need for additional accommodations, or changes to the existing accommodations, the Disability Affairs Section must be contacted to re-evaluate the accommodations
- If the accommodations are not effective and there are no other methods of accommodation that can assist the employee in performing the essential

functions of his/her job, then the accommodation of reassignment to a vacant position within the County will be discussed.

**Separation from Employment because of Inability to Perform Job Requirements**

- If, within a “reasonable amount of time” (determined on a case by case basis), the employee does not qualify for a vacant position, the employee will lose his/her protected status under the ADA (as only “qualified individuals with disabilities” are covered by Title I of the ADA).
- At this point, the employee who is not qualified for any vacant position, may be separated from county employment after consultation with the Human Resources Division.
- All efforts to provide reasonable accommodation, as well as conversations and meetings must be thoroughly documented.

**AMERICANS WITH DISABILITIES ACT  
REASONABLE MODIFICATIONS POLICY**

**Equal Opportunity**

Broward County shall provide equal opportunity to qualified individuals with disabilities. It shall not discriminate against qualified individuals on the basis of disability in any of its programs, services and activities. 28 C.F.R. § 35.130(b) (1) (i)-(iv), (vii)

The County shall not in any of its programs, services and activities:

- deny a qualified individual with a disability the opportunity to participate in and benefit from programs, services and activities, including volunteer opportunities, that are not equal to that afforded to others;
- otherwise limit a qualified individual with a disability in the enjoyment of any right, privilege, advantage or opportunity enjoyed by other individuals.

This policy does not require the County to undertake an action that would pose an undue financial or administrative burden or fundamentally alter the nature of programs, services and activities.

**Reasonable Modifications**

Broward County will make reasonable modifications to policies, practices and procedures when necessary to provide equal opportunity to qualified individuals with disabilities, so long as doing so does not pose an undue financial or administrative burden or cause a fundamental alteration to the program, activity or service. 28 C.F.R. § 35.130(b) (7)

**Eligibility Criteria and Safety Requirements**

Broward County will not impose eligibility or safety criteria that will limit or prohibit the participation of qualified individuals with disabilities unless such standards are necessary and essential to the operation of programs, services and activities. It is the responsibility of the ADA Administrator in any situation where eligibility and safety standards may limit or exclude the participation of individuals with disabilities to:

- Review the standards and their application;

- Ensure that mitigating measures are used to reduce the hazard or threat to the safety of individuals with disabilities and other participants in the program;

Provide for the participation of individuals with disabilities to the greatest extent possible. 28 C.F.R. § 35.130(b) (8)

### **Integrated Services**

Broward County shall provide all programs, activities and services in the most integrated setting appropriate to the needs of the person. This policy does not prohibit the establishment of separate programs for individuals with disabilities. However, it does prohibit the County from requiring that individuals participate in separate rather than integrated programs. 28 C.F.R. § 35.130(b) (2) ;( d)

### **Surcharges**

Broward County will not impose surcharges on individuals with disabilities, their families or organizations representing them for the provision of reasonable accommodation, communication aids and services, reasonable modification to policies, practices and procedures, the removal of structural barriers, or any other costs associated with the participation of individuals with disabilities in the County's programs, services and activities. 28 C.F.R. § 35.130(f)

### **Significant Assistance**

Broward County shall not give significant assistance, either financial or in-kind, to any organization that discriminates against individuals with disabilities. It is the County's responsibility to investigate any situation in which discrimination against individuals with disabilities may have occurred and take appropriate action, either to see that the discriminatory action is remedied or to recommend that the assistance be terminated. 28 C.F.R. § 35.130(b) (5)

The Office of Equal Opportunity Disability Affairs Section shall be responsible for the oversight, dissemination, coordination, and enforcement of procedures related to this policy.

## REASONABLE MODIFICATIONS PROCEDURES

In accordance with Section 35.130(b)(7) of the Americans with Disabilities Act of 1990, Broward County has adopted the following procedures for addressing requests for reasonable modifications of County policies, practices, or procedures made by Citizens with disabilities in order to participate in County services, activities, programs.

Requests for simple modifications that have no or little cost and pose no administrative burden, such as assistance in filling out a form for an individual who does not write because of a disability or providing a chair to an individual with a mobility disability who has difficulty standing in line, may be granted by the County agency responsible for the service, program or activity.

Citizens seeking/requesting more complex modifications should submit their request in writing to:

Office of Equal Opportunity  
Disability Affairs Section  
115 S. Andrews Avenue  
Suite A-680  
Ft. Lauderdale, Florida 33301  
(954) 357-6500  
TTY: (954) 357-6181

*(NOTE: For Request for Sign Language Interpreters, Braille and/ or other Auxiliary Aids and services see Sign Language Interpretation and Braille Request procedures)*

The request should contain the name, address and telephone number of the individual requesting the modification; location of the program, service, activity or facility where the accommodation is required and a description of why the accommodation is needed.

The request can be submitted in any written format. However, it is recommended that the "*Disability Accommodation Request Form*" is used. Alternative means of filing a request, such as personal interviews, phone calls, or taped requests, will be made available for persons with disabilities if unable to communicate their request in writing. This form is available by contacting the Office of Equal Opportunity Disability Affairs Section. Alternative means of filing a request will be made available, upon request.

If the Office of Equal Opportunity Disability Affairs Section grants the modification, the petitioner will be notified within 15 days of receipt of the request

and no further action will be required by the petitioner. The request will then be implemented by the appropriate County Agency. If the Office of Equal Opportunity Disability Affairs Section denies the modification request, the petitioner will be notified in writing of the decision, along with his or her rights to file a grievance under the County's Grievance Procedure, in a format acceptable to the petitioner. A copy of that procedure will be included in the correspondence to the petitioner.



# Disability Accommodation Request Form

Broward County does not discriminate on the basis of disability in admission to, or operation of its programs, services, or activities. This form may be used by a private citizen with a disability seeking access to a County program or facility.

## ACCOMMODATION REQUEST INFORMATION

Name: \_\_\_\_\_ Telephone (or TTY): \_\_\_\_\_

Address : \_\_\_\_\_ Date: \_\_\_\_\_

The program or facility to which I am requesting access is located

\_\_\_\_\_

I am requesting the following accommodation(s)

- Wheelchair Access
- Sign Language Interpretation
- Written Material in Alternate Format (Large Print, Computer Disc)
- Written Material in Braille
- Reader
- Modification of Policy Procedures
- Other

Please provide any other details or information necessary to process this request

## RETURN INFORMATION

Department: \_\_\_\_\_ Telephone: \_\_\_\_\_

Address: \_\_\_\_\_ TTY (if available): \_\_\_\_\_

## ADDITIONAL QUESTIONS MAY BE DIRECTED TO THE OFFICE OF EQUAL OPPORTUNITY DISABILITY AFFAIRS SECTION

115 S. Andrews Avenue, Room 426  
Fort Lauderdale, FL 33301  
(954) 357-6500  
TTY (954) 357-6181

**Programs Requiring for Teletypewriters (TTY)**

**Agency/Program**

**Facility Name**

**COMMUNITY SERVICES**

ANIMAL CARE & REGULATION	ANIMAL CARE AND REGULATION - NORTH
	ANIMAL CARE AND REGULATION - SOUTH
CONSUMER AFFAIRS	GOVERNMENTAL CENTER ANNEX
CULTURAL DIVISION	LIBRARY - MAIN
EXTENSION EDUCATION	EXTENSION EDUCATION SERVICE
LIBRARIES	LIBRARY - AFRICAN AMERICAN RESEARCH
	LIBRARY - ALVIN SHERMAN
	LIBRARY - BEACH BRANCH
	LIBRARY - CARVER RANCHES
	LIBRARY - CENTURY PLAZA
	LIBRARY - COLLIER CITY
	LIBRARY - DANIA BEACH
	LIBRARY - DAVIE COOPER CITY
	LIBRARY - DEERFIELD BEACH
	LIBRARY - FT LAUDERDALE BRANCH(HOLIDAY PARK)
	LIBRARY - GALT OCEAN MILE
	LIBRARY - HALLANDALE
	LIBRARY - IMPERIAL POINT
	LIBRARY - LAUDERDALE LAKES
	LIBRARY - LAUDERHILL
	LIBRARY - LAUDERHILL MALL
	LIBRARY - NORTH LAUDERDALE
	LIBRARY - NORTH WEST POMPANO
	LIBRARY - NORTH WEST REGIONAL
	LIBRARY - PEMBROKE PINES

---

**Agency/Program****Facility Name**

---

PARKS &amp; RECREATION

LIBRARY - POMPANO BEACH  
LIBRARY - RIVERLAND  
LIBRARY - SOUTH WEST REGIONAL  
LIBRARY - STIRLING ROAD  
LIBRARY - SUNRISE  
LIBRARY - SUNSET STRIP  
LIBRARY - TAMARAC  
LIBRARY - TYRONE BRYANT  
LIBRARY - WEST ATLANTIC  
LIBRARY - WESTON  
READING CENTER - HOLLYWOOD BEACHPARKS - BRIAN PICCOLLO PARK  
PARKS - CB SMITH PARK  
PARKS - MARKHAM PARK  
PARKS - QUIET WATERS PARK  
PARKS - SECRET WOODS NATURE CENTER  
PARKS - TOPEEKEEGEE PARK**COUNTY ADMINISTRATION**COUNTY ADMINISTRATOR  
EMERGENCY MANAGEMENT AGENCY  
OFFICE OF EQUAL OPPORTUNITY  
    Civil Rights  
    Small Business  
    Internal Investigations and Oversight  
OFFICE OF TRANSPORTATIONGOVERNMENTAL CENTER EAST  
EMERGENCY OPERATIONS CENTER

OFFICE OF PUBLIC COMMUNICATIONS

GOVERNMENTAL CENTER ANNEX  
GOVERNMENTAL CENTER ANNEX  
GOVERNMENTAL CENTER EAST  
MASS TRANSIT ADMINISTRATION (ADA Specialist)  
MASS TRANSIT MAIN TERMINAL  
MASS TRANSIT TRANSFER FACILITY  
GOVERNMENTAL CENTER EAST**COUNTY COMMISSION**

---

**Agency/Program****Facility Name**

---

COUNTY COMMISSION (BOARD MEMBERS)  
HISTORICAL COMMISSION

GOVERNMENTAL CENTER EAST  
HISTORICAL COMMISSION

---

**ENVIRONMENTAL PROTECTION**

ENVIRONMENTAL MONITORING FACILITY  
GOVERNMENTAL CENTER WEST

---

**FINANCE AND ADMINISTRATIVE SERVICES**

COUNTY RECORDS  
HUMAN RESOURCES

GOVERNMENTAL CENTER EAST  
EMPLOYMENT ASSISTANCE PROGRAM  
GOVERNMENTAL CENTER EAST  
PERSONNEL - ANNEX B

REVENUE COLLECTIONS

GOVERNMENTAL CENTER ANNEX  
GOVERNMENTAL CENTER EAST  
SOUTH REGIONAL COURTHOUSE  
TAG AGENCY

SUPPORT ENFORCEMENT

WEST REGIONAL COURTHOUSE  
MIDRISE OFFICE

---

**HUMAN SERVICES**

CHILDREN'S SERVICES ADMINISTRATION

FAMILY SUCCESS ADMINISTRATION DIVISION  
GOVERNMENTAL CENTER ANNEX  
OUR HOUSE

ELDERLY & VETERANS SERVICES

SEXUAL ASSAULT CENTER (HOTLINE)  
FAMILY SUCCESS ADMINISTRATION DIVISION  
NORTH REGIONAL COURTHOUSE  
SOUTH REGIONAL COURTHOUSE

FAMILY SUCCESS ADMINISTRATION

FAMILY SUCCESS ADMINISTRATION DIVISION  
NORTH FAMILY SUCCESS CENTER  
NORTH WEST FAMILY SUCCESS CENTER  
SOUTH FAMILY SUCCESS CENTER

HOMELESS INITIATIVE PARTNERSHIP

CENTRAL HOMELESS SHELTER

---

**Agency/Program****Facility Name**

---

MEDICAL EXAMINER TRAUMA SERVICES  
SUBSTANCE ABUSE & HEALTH CARE SERV.

GOVERNMENTAL CENTER EAST  
NORTH HOMELESS ASSISTANCE CENTER  
MEDICAL EXAMINER  
BROWARD ADDICTION RECOVERY CENTER - BOOHER  
BROWARD ADDICTION RECOVERY CENTER CENTRAL  
BROWARD ADDICTION RECOVERY CENTER - DAVIE  
BROWARD ADDICTION RECOVERY CENTER - SOUTH  
CASE MANAGMENT SERVICES (HUMAN SERVICES)  
GOVERNMENTAL CENTER EAST  
MENTAL HEALTH  
NORTH REGIONAL HEALTH CENTER (HUGES BLDG)

---

**PORT EVERGLADES**

PORT EVERGLADES

PORT EVERGLADES - ADMINISTRATION

---

**PUBLIC WORKS & TRANSPORTATION**

TRAFFIC ENGINEERING

TRAFFIC ENGINEERING BUILDING

---

**URBAN PLANNING & REDEVELOPMENT**

BUILDING CODE SERVICES  
PERMIT AND LICENSING

BUILDING CODE SERVICES  
GOVERNMENTAL CENTER ANNEX

**AMERICANS WITH DISABILITIES ACT  
COMMUNICATION POLICY**

It is the policy of Broward County to ensure that communications with participants and members of the public with disabilities are as effective as communications are with others. Broward County Government will furnish appropriate auxiliary aids and services where necessary to afford an individual with a disability an equal opportunity to participate in, and enjoy the benefits of, any program, service, or activity conducted by the Broward County Government. In determining what type of auxiliary aid or service is necessary, Broward County will give primary consideration to the requests of the individual with disabilities.

Auxiliary aids and services include: (1) qualified interpreters, note takers, transcription services, written materials, telephone handset amplifiers, assistive listening devices, assistive listening systems, telephones compatible with hearing aids, closed caption decoders, open and closed captioning, telecommunications devices for deaf person (TTYs), videotext displays, or other effective methods of making aurally delivered materials available to individuals with hearing impairments; and (2) qualified readers, taped texts, audio recordings, Brailled materials, large print materials, or other effective methods of making visually delivered materials available to individuals with visual impairments.

When an auxiliary aid or service is requested, Broward County will give primary consideration to the choice expressed by the individual with disabilities. Broward County will honor the choice unless:

1. it can show that another effective means of communication is available or,
2. it can show that the use of the means chosen would result in a fundamental alteration in the service, program, or activity or,
3. it can show that the use of the means chosen would result in undue financial burden to the department.

The County agency will consult with the individual with a disability to identify in what ways effective communication can be achieved with the individual in the context of the agency's program, service or activity.

The Office of Equal Opportunity Disability Affairs Section shall be responsible for the oversight, dissemination, coordination, and enforcement of procedures related to this policy.

## **BRaille AND OTHER ALTERNATE FORMAT REQUESTS PROCEDURES**

In accordance with Section 35.160(b)(1) of Title II of the Americans with Disabilities Act, Broward County must furnish auxiliary aids and services to individuals with disabilities when necessary to ensure effective communication. All County documents available to the public must be made available in an alternate, accessible format to people who are blind or visually impaired upon request. Types of alternate format include large print, audio-cassette, computer disc, Braille and readers.

The County may not place an extra charge on a person with a disability to cover the costs of auxiliary aids and services or other modifications designed to provide effective communication. For example, if members of the public are typically charged for photocopy costs, an individual who needs a document in Braille may only be charged for the equivalent photocopy cost, not for the greater cost of transferring the document to Braille.

*All Broward County employees who have direct contact with the public should be made aware of the County's obligation to provide material in alternate format upon request and should become familiar with the "Disability Accommodation Request Form" available from the Office of Equal Opportunity Disability Affairs Section.*

In many cases, people who are blind or visually impaired may simply require assistance to read or fill out a form or document. Such assistance should be provided by a County employee upon request. If the document is lengthy or of a personal nature, providing the form or document in an alternate format may be more appropriate.

**Braille:** To facilitate the provision of Braille materials, Braille equipment has been assigned to those County agencies where the likelihood for this type of request is greatest.

For Braille transcription services for publications/materials that cannot be produced in house due to a complex format (i.e., graphs, tables, mathematical equations etc.) will be provided externally from contractors and/or other outside providers. County agencies will be required to coordinate the procurement of these services through the Office of Equal Opportunity Disability Affairs Section.

**Large Print:** People with low vision may require materials in large print, which is defined as 18 point font size or larger. It may be possible to accommodate such requests by enlarging a document on a photocopier, or reprinting materials from a computer in the larger font size.

- This is an example of 18-point print size.

For enlarging print on publications, contact the Office of Public Communications.

**Computer Disc:** If the material requested is on computer in a compatible program, a disc may be provided as an alternate format.

**Audio Tape/ Personal Readers:** Audio tapes or personal readers must be provided to read the meeting agendas, or other materials, aloud to the requesting person(s) at the meeting itself. A representative of the County agency should be directed to either audio tape the materials in advance or be designated to read the materials to the requesting person(s) upon request.

Requests for Braille materials or other alternate format must be made to the County agency in advance of the meeting, hearing or other service or activity provided by the sponsoring agency. The best effort to fulfill the request will be made.

- For public meetings and events that are planned in advance, it is acceptable to require individuals to provide the County with advance notice of up to (10) working days of their request. However, to require advance notice for such a request, all public notices for the meeting or service in question must include the following statement:

“Individuals with disabilities requiring accommodations in order to participate in County programs, services and activities must contact (name of person) at (954) 357-XXXX or TTY (954) 357-XXXX (those agencies without TTY must include the Florida Relay System number) at least ten (10) business days prior to the scheduled meeting or event to request an accommodation.”

- For on-going services and programs, such as counseling services, group therapy etc., the agency should be notified at least 48 hours in advance.
- For emergencies or urgent requests, the agency should be notified immediately.

## **Alternative Formats Statement for Publications**

A statement informing readers that a publication is available in alternative formats should be included on publications that will be retained for a specified period of time. One example is the "*Broward County at Your Service*" booklet. A flyer announcing a one-time event does not require this statement.

The statement for alternative formats should read:

"This publication can be made available in large print, tape cassette, or Braille, upon request by contacting (division/department or program responsible for the publication) at (954) 357-XXXX (voice) or TTY/Relay.

Additional questions or concerns may be directed to the Office of Equal Opportunity Disability Affairs Section at: (954) 357-6500.

## **SIGN LANGUAGE INTERPRETATION REQUEST PROCEDURES**

In accordance with Section 35.160(b)(1) of Title II of the Americans with Disabilities Act, Broward County must furnish auxiliary aids and services to individuals with disabilities when necessary to ensure effective communication. All County information provided to the public orally must be made available in an alternate, accessible format to people who are deaf or hard of hearing, upon request. Types of alternate formats include written material, sign language interpretation, assistive listening devices and captioning services.

The County may not place an extra charge on a person with a disability to cover the costs of auxiliary aids and services or other modifications designed to provide effective communication. Insufficient funding is not a valid reason for refusing to provide auxiliary aids and services when requested.

*All County employees who have direct contact with the public and/or who organize meetings that are open to the public should be made aware of the County's obligation to provide auxiliary aids and services upon request and should become familiar with the "Disability Accommodation Request Form" available from the Office of Equal Opportunity Disability Affairs Section. If your agency is required to have a TTY, these employees should also be trained to properly operate it. If your agency is not required to have a TTY, these employees should be aware of the Florida Relay Service as a means of communicating by telephone with individuals who are deaf or hard of hearing.*

### **TYPES OF AUXILIARY AIDS AND SERVICES:**

#### **1. Verbal Communication**

Some people who are deaf or hard of hearing are able to read lips. When speaking to an individual who is deaf or hard of hearing under these circumstances, be sure to face the individual directly and speak clearly. Do not turn away or cover your mouth. This method should only be used for very brief encounters and only if the individual who is deaf or hard of hearing indicates that this method is effective.

#### **2. Written Communication**

In some cases, people who are deaf or hard of hearing may request that communications which are typically conducted verbally be conducted in writing instead. Such an accommodation should be provided upon request, and is usually appropriate for brief and/or casual exchanges.

Please keep in mind that not all people who are deaf are able to read written English.

### **3. Sign Language Interpretation**

Some people who are deaf or hard of hearing may require the services of a sign language interpreter. A qualified interpreter is necessary in any type of legal or quasi-legal proceedings, any type of health or medical proceeding (including questions about past medical conditions, symptoms, treatment, family history, etc.), any transaction where privacy is required, any public meeting or event, and any occasion where no other type of communication is effective for the individual. In these cases, it will be necessary for the County agencies to coordinate the procurement of these services through the Office of Equal Opportunity Disability Affairs Section.

The County may not require the individual to provide his or her own interpreter, because it is the responsibility of the County to provide a qualified interpreter. Also, requiring a friend or family member to interpret is not appropriate, because his or her presence at the transaction may violate the individual's right to confidentiality, or because the friend or family member may have an interest in the transaction that is different from that of the individual involved. The obligation to provide "impartial" interpreting services requires that, upon request, the County provides an interpreter who does not have a personal relationship to the individual with a disability.

Using County staff members who can sign "pretty well" as an interpreter for meetings with individuals who use sign language to communicate is neither appropriate nor acceptable. Signing and interpreting are not the same thing. Being able to sign does not mean that a person can process spoken communication into the proper signs, nor does it mean that he or she possesses the proper skills to observe someone signing and change their signed or finger spelled communication into spoken words. The interpreter must be able to interpret both receptively and expressively.

Requests for Sign Language Interpreters must be made to the County agency in advance of the meeting, hearing or other service or activity provided by the sponsoring agency. The best effort to fulfill the request will be made.

- For public meetings and events that are planned in advance, it is acceptable to require individuals who are deaf or hard of hearing to provide the County with advance notice of up to (10) working days of their request for a sign language interpreter. However, to require advance notice for such a request, all public notices for the meeting in question must include the statement:

“Individuals with disabilities requiring accommodations in order to participate in County programs, services and activities must contact (name of person) at (954) 357-XXXX or TTY (954) 357-XXX (those agencies without TTY must include the Florida Relay System number) at least ten (10) business days prior to the scheduled meeting or event to request an accommodation.”

- For on-going services and programs, such as counseling services, group therapy etc., the agency should be notified at least 48 hours in advance.
- For emergencies or urgent requests, the agency should be notified immediately.

Additional questions or concerns may be directed to the Office of Equal Opportunity Disability Affairs Section at: (954) 357-6500.

## Facility Closings

Facility	Approved	Schedule Date	Agenda Item	Commission District
----------	----------	---------------	-------------	---------------------

<b>ANIMAL CARE AND REGULATION - SOUTH</b>	<b>7</b>
-------------------------------------------	----------

1871 SW 40TH ST	Yes	10/6/2010	Page 2-54 Approved Capital	\$12,000,000
FORT LAUDERDALE			Budget	
<b>Additional Info</b> Funded for construction in 2009				

<b>BROWARD ADDICTION RECOVERY CENTER - CENTRAL</b>	<b>7</b>
----------------------------------------------------	----------

1011 SW 2 CT	Yes	12/6/2008	Page 2-58 2004 adopted	\$9,000,000
FORT LAUDERDALE			budget	
<b>Additional Info</b> Pending land deals.				

<b>BUILDING CODE SERVICES</b>	<b>7</b>
-------------------------------	----------

955 S FED HIGHWAY	No	12/6/2008	Will go to board for approval	\$0
FORT LAUDERDALE				
<b>Additional Info</b> Building will be sold off once the West Governmental Center is occupied. Sale will go to board for approval. Pending litigation at West Governmental Center.				

<b>Total Estimated Approved</b>	<b>\$21,000,000</b>
<b>Total Estimated Pending Approval</b>	<b>\$0</b>

<b>Final Estimated Total</b>	<b>\$21,000,000</b>
------------------------------	---------------------

**Intersections Pending Assessment and Retrofitting  
(ADA Curb Cuts and Curb Ramps)**

Fiscal Year	Project Location
2008	McNab Rd & North West 84 Ave Riverside Drive & Ramblewood Dr Commercial Blvd & North West 82 Ave Prospect Rd & North West 9 Ave Prospect Rd & Powerline Rd Racetrack Rd (Pompano Park Place) & Avondale Dr Copans Rd & SR 7 Coconut Creek Pkwy & Coconut Creek Blvd Peters Rd & Davie Blvd/ Peters Rd & South West 41 Ave
2009	Coral Springs Dr & Lakeview Dr Coral Springs Dr & North West 21 Manor Coral Springs Dr & North West 32 Ct Dixie Hwy & Hillsboro Blvd Dixie Hwy & North Eas 2 St Dixie Hwy & North East 2 Ave Davie Rd Ext & N 74 Ave Davie Rd Ext & North 72 Ave SW 56 Ave & SW 19 St North East 48 St & North West 3 Ave
2010	NW 27 Ave & NW 4 St NW 27 Ave & NW 4 Ct NW 27 Ave & NW 8 St NW 27 Ave & NW 8 Ct NW 27 Ave & NW 8 PI NW 27 Ave & NW 9 St NW 27 Ave & NW 9 Ct NW 27 Ave & NW 9 PI Nob Hill and Springtree Lakes Blvd NW 136th Ave and Sawgrass Corp Parkway Lyons Road and Vinkemulder Road

**BROWARD COUNTY, FLORIDA  
ADA TRANSITION PLAN UPDATE**

**LIST OF ATTACHMENTS**

**Attachment A: Cost Estimates Summary**

This summary provides detail of costs for each of the priority groups, for Public Works, Port Everglades, and the Parks & Recreation Division. The report then provides a cost estimate summary by County Commission district and priority, and a graph detailing relative costs associated with activities in the various Commission districts.

**Attachment B: Structural and Programmatic Details Cost Estimates**

This attachment includes information on costs associated with the ADA Transition Plan Update recommendations.

1. Public Works: The following section highlights Public Works Structural and Programmatic details. Organized by facility, this report notes both priority and district number, and provides coded recommendations for actions to be taken in each case, as well as the cost estimate. For additional detail on these recommendation codes, the code definitions may be found in the report titled "Structural and Programmatic Recommendations," at the close of Attachment B.

2. Port Everglades: Like the Public Works report, the Port Everglades Structural and Programmatic Details Cost Estimates report is organized by facility, with priority group and Commission district indicated. Cost estimates are provided, and recommendations associated with each facility follow the same coding framework as utilized in the Public Works report, noted above.

3: Parks & Recreation: The Parks & Recreation Division Structural and Programmatic Details Cost Estimates report follows, and is based on the same framework utilized for the Public Works and Parks & Recreation Division reports discussed previously.

4. Structural and Programmatic Recommendations: This document details the coding system structure used in the Public Works, Port Everglades, and Parks & Recreation reports noted above. Where a code is indicated on the agency report, this report has a detailed explanation of the recommendation.

Example: "#25 (2 X \$200)" in the recommendation section means that recommendation number 25 is applicable, and that there are two instances requiring the action described in recommendation number 25, at a cost of \$200 each.

The report is geared toward greater consistency in frequently used responses to similar ADA compliance issues across agencies, and allows for a more efficient approach to remedial action during Phase III.

### **Attachment C: ADA Agency/Program Operational Cost Estimates**

1. Operational Cost Estimates: This document contains the estimated costs associated with the operational recommendations to address barriers to accessibility. Operational recommendations are defined as adjustments and or modifications which can be implemented at the program/agency level by moving or rearranging furniture, implementing a procedure, or some other means not requiring remedial action on a larger scale.

2. Operational Recommendations: This document details the coding system used in the Operational Cost Estimates report noted above. Each code in the Operational Cost Estimate corresponds to a more detailed explanation contained in this report.

### **Attachment D: Auxiliary Aids and Services Cost Estimates by Program**

The agencies listed on these report are those where communication by telephone is a major function of the program, and as such must provide direct access to individuals who rely on a TTY for telephone communication. The agencies/programs that are not listed, either already have TTY's or are not required to provide direct access. As such, these agencies will be directed to utilize the Florida Relay Service to provide effective communication to persons with hearing or speech impairments.

Braille equipment has been requested for those agencies where the likelihood of requests for material in Braille is greatest. This distribution of equipment will facilitate requests for Braille materials by individuals with visual impairments.

Sign Language interpretation services as well as other services, such as readers, can most effectively be provided externally from contractors and/or other outside providers.

### **Attachment E: Training Subject Areas**

This report lists an overview of the identified areas of the proposed comprehensive ADA Training program, with content areas and applicable agencies/audiences.

## **Attachment F: Program List by Department**

This document is a list of programs assessed for ADA compliance by department. The report is organized by service locations, noting the applicable Commission District, and has overview information on priority group number, the applicability of structural or programmatic recommendations, and whether the service location has a special features report.


## Program/Facility Cost Estimate Summary Sheet

	Public Works	Port Everglades	Parks	Operational	Totals
Priority 1	\$629,751	\$0	\$3,285,200	\$135,250	\$4,050,201
Priority 2	\$2,356,464	\$0	\$833,700	\$0	\$3,190,164
Priority 3	\$29,400	\$276,050	\$402,100	\$0	\$707,550
<b>Final Estimated Costs</b>	<b>\$3,015,615</b>	<b>\$276,050</b>	<b>\$4,521,000</b>	<b>\$135,250</b>	<b>\$7,947,915</b>

## Cost Estimate Summary by District and Priority

District	Priority (1)	Priority (2)	Priority (3)	Totals
County-wide	\$135,250	\$0	\$200,000	\$335,250
1	\$350	\$198,460	\$8,600	\$207,410
2	\$237,200	\$312,070	\$7,400	\$556,670
3	\$10,500	\$25,350	\$400	\$36,250
4	\$29,150	\$386,755	\$96,950	\$512,855
5	\$1,763,900	\$8,500	\$0	\$1,772,400
6	\$1,363,800	\$228,275	\$179,100	\$1,771,175
7	\$404,551	\$1,546,029	\$33,850	\$1,984,430
8	\$10,400	\$14,650	\$152,100	\$177,150
9	\$95,100	\$470,075	\$29,150	\$594,325
<b>Final Estimated Costs</b>	<b>\$4,050,201</b>	<b>\$3,190,164</b>	<b>\$707,550</b>	<b>\$7,947,915</b>

**Cost Summary by Commission District**



## Public Works Structural and Programmatic Details Cost Estimates

Facility Name	Priority	District	Recommendations	Cost Estimates
---------------	----------	----------	-----------------	----------------

**ANIMAL CARE AND REGULATION - NORTH**

3100 NW 19 TERR POMPANO BEACH	1	2	#3(\$5000),#7(\$5000),#8(\$200),#18(\$600),#19(\$200),#26(\$100), #28(\$25000),#29(\$200),#30(\$200),#31(\$200),#32(\$200),#40(\$2 500),#54(\$200),#55(\$200),#62(\$500),#68(\$400),#70(\$400),#80( \$500)	\$41,600
----------------------------------	---	---	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------

	<b>Facility Cost Estimate:</b>	<b>\$41,600</b>
--	--------------------------------	-----------------

**BROWARD ADDICTION RECOVERY CENTER - BOOHER BUILDING**

3275 NW 99 WAY CORAL SPRINGS	1	3	#1(\$350),#25(\$200),#40(\$2500),#55(\$200),#70(\$400)  One in every eight designated accessible spaces, but not less than one, shall be designated as van accessible.  Other - Re-stripe the lot so that it has at least two compliant/accessible designated parking spaces with at least one of the spaces having the "van accessible" designation with compliant signage.	\$3,650  \$350  \$2,000
---------------------------------	---	---	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------

<b>Facility Cost Estimate:</b>	<b>\$6,000</b>
--------------------------------	----------------

<b>BROWARD ADDICTION RECOVERY CENTER - DAVIE</b>	Leased Non-County Cost
--------------------------------------------------	------------------------

4175 DAVIE ROAD                    1            7  
 DAVIE

#1(\$350),#3(\$5000),#5(\$5000),#8(\$200),#9(3X\$2500),#10(\$3000),#12(\$200),#18(3X\$600),#19(\$200),#25(\$200),#26(\$100),#28(\$25000),#32(\$200),#48(\$3000),#49(\$5000),#50(\$5000),#51(\$200),#52(\$7100),#54(2X\$200),#55(\$200),#60(\$5000),#62(\$500),#70(\$400),#80(\$500) \$0

Other - Provide an emergency intercom that is identified with Braille and raised lettering. \$0

Structural - Doors need to be widened and threshold modified. \$0

Structural - Fix landings for required dimensions.

Structural - Other - Make each restroom fully accessible or make a unisex restroom that is fully accessible \$0

Structural - Relocate the railings.

Structural - Restroom door entry configuration does not provide adequate maneuvering space for a person using a wheelchair.

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>BROWARD ADDICTION RECOVERY CENTER - SOUTH</b>
--------------------------------------------------

5701 HOLLYWOOD BLVD            1            6  
 HOLLYWOOD

#1(\$350),#23(\$2500),#25(\$200),#28(\$25000),#32(\$200),#54(\$200),#55(\$200),#62(\$500), #77(\$2000) \$31,150

Other - Install the toilet paper dispenser so that it is not more than 36" from the rear wall. \$200

Other - Re-stripe the lot so that it has at least two compliant/accessible designated parking spaces with at least one of the spaces having the "van accessible" designation with compliant signage. \$800

<b>Facility Cost Estimate:</b>	<b>\$32,150</b>
--------------------------------	-----------------

<b>BROWARD EMERGENCY SERVICES BUILDING</b>
--------------------------------------------

2601 W BROWARD BLVD                    1                    7  
 FORT LAUDERDALE

#1(\$350),#19(2X\$200),#25(\$200),#40(\$2500),#54(\$200)                    \$3,650

<b>Facility Cost Estimate:</b>	<b>\$3,650</b>
--------------------------------	----------------

<b>BROWARD SHERIFF OFFICE - DISTRICT 5</b>
--------------------------------------------

200 NE 27 AVENUE                    3                    7  
 FORT LAUDERDALE

#1(\$350),#19(\$200),#25(2X\$200),#39(\$2000),#54(\$200),#62(\$500),#70(\$400)                    \$4,050

<b>Facility Cost Estimate:</b>	<b>\$4,050</b>
--------------------------------	----------------

<b>CASE MANAGMENT SERVICES (HUMAN SERVICES)</b>	Leased at Non-County Cost
-------------------------------------------------	---------------------------

4200 NW 16 ST                    1                    9  
 LAUDERHILL







<b>Facility Cost Estimate:</b>	<b>\$10,475</b>
--------------------------------	-----------------

<b>EXTENSION EDUCATION SERVICE</b>
------------------------------------

3245 COLLEGE AVE                    2                    7  
 DAVIE

#15(\$1000), #19(\$200), #25(3X\$200), #26(\$100), #54(\$200), #73(\$1200)                    \$3,300

<b>Facility Cost Estimate:</b>	<b>\$3,300</b>
--------------------------------	----------------

<b>FAMILY SUCCESS ADMINISTRATION DIVISION</b>
-----------------------------------------------

2995 N DIXIE HIGHWAY            1                    4  
 OAKLAND PARK

#1(\$350), #8(\$200), #12(\$200), #18(3X\$600), #23(2X\$2500), #25(\$200), #26(\$100), #31(\$200), #39(\$2000), #53(\$200), #55(2X\$200), #69(\$1050)                    \$10,500

Other - Adjust the door closer so that the door takes at least three seconds to close, or replace the closer with a compliant/accessible door closer.                    \$100

Other - Install a stall door with compliant handles/latch inside and out that is operable with a closed fist.                    \$250

<b>Facility Cost Estimate:</b>	<b>\$10,850</b>
--------------------------------	-----------------

<b>FORT LAUDERDALE HEALTH CENTER</b>
--------------------------------------

2421-A SW 6 AVE                    1                    7  
 FORT LAUDERDALE



#18(38X\$600),#25(11X\$200),#26(5X\$100),#29(5X\$200),#30(20X\$200),#31(7X\$200),#32(5X\$200),#33(3X\$500),#39(2X\$2000),#40(5X\$2500),#49(\$5000),#53(9X\$200),#55(2X\$200),#68(2X\$400),#70(2X\$400),#74(5X\$4000)	\$79,700
Other - 42a. Install tactile signs to identify floor numbers at a height of 60" above the floor.	\$400
Other - Provide a new tax payment drop-off box at the correct height.	\$0
Other - Raise the call buttons.	\$1,500
Other - Re-install elevator call button to correct height.	\$1,500
Other - Re-install the elevator call button to correct height.	\$1,500
Other - Re-install the elevator floor designation to correct height.	\$1,500
Other - Re-install the elevator hall lanterns, the visible and audible signals to correct location and height.	\$1,500
Other - Re-install the elevator hall lanterns, the visible and audible signals to correct location and height.	\$1,500
Other - Re-install the elevator hall lanterns, the visible and audible signals to correct location and height.	\$1,500
Other - Re-install the elevator hall lanterns, the visible and audible signals to correct location and height.	\$1,500
Other - Re-install the elevator hall lanterns, the visible and audible signals to correct locations and heights.	\$1,500
Other - Re-install the elevator hall lanterns, the visible and audible signals to the correct location and height.	\$1,500
Other - Re-install the elevator to the correct height.	\$1,500
Other - Relocate the dispensers.	\$200

Other - Relocate the hook to a compliant height above the floor.	\$50
Other - Relocate the toilet paper dispenser so that it is within 36" from the rear wall.	\$200
Other - Relocate toilet paper dispenser (outer edge) to correct distance from the rear wall.	\$200
Other - Staff must make sure that patrons receive assistance, if necessary, opening doors.	\$0
Structural - Other - Provide new accessible unisex restroom at an adjacent area, the existing Library Bond program offices reception area; the existing restrooms floor elevation cannot be retrofitted. Provide new directional signage indicating its locatio	\$80,000
Structural - Other - Provide new accessible unisex restroom at an adjacent area, the existing Library Bond program offices reception area; the existing restrooms floor elevation cannot be retrofitted. Provide new directional signage indicating its locatio	\$80,000

<b>Facility Cost Estimate:</b>	<b>\$257,250</b>
--------------------------------	------------------

<b>GOVERNMENTAL CENTER EAST</b>
---------------------------------

115 SOUTH ANDREWS AV                    2                    7  
FORT LAUDERDALE

#10(26X\$3000),#12(4X\$200),#15(2X\$1500),#18(24X\$600),#19(\$200),#23(5X\$2500),#25(36X\$200),#26(11X\$100),#28(\$25000),#29(31X\$200),#30(10X\$200),#31(29X\$200),#33(11X\$500),#34(\$500),#39(18X\$200),#40(3X\$2500),#49(3X\$5000),#50(\$50)	\$272,000
Other - Mount toilet paper dispenser no farther than 36 inches from back wall.	\$200
Other - Provide accessible directional signage to direct people with disabilities to accessible elevator.	\$75

Other - Provide accessible directional/informational signage to direct people with disabilities to the accessible elevator.	\$75
Other - Provide an accessible emergency intercommunication system at the elevator control panel.	\$7,100
Other - Provide an emergency intercommunication system at the elevator control panel that is compliant/accessible.	\$7,100
Other - Public spaces are not all on an accessible route of travel. ( Operational )	\$0
Other - Relocate the existing shelf and the TTD to the correct height.	\$100
Other - Remove or relocate phone books to correct height.	\$0
Other - Staff must make sure patrons visiting Commissioners' offices receive assistance, if necessary, opening the doors.	\$0
Structural - Lowest drawer of file cabinets in the Public search section is too low for forward approach. - This is an operational issue.	\$0

<b>Facility Cost Estimate:</b>	<b>\$286,650</b>
--------------------------------	------------------

<b>GOVERNMENTAL CENTER WEST</b>
---------------------------------

1 N UNIVERSITY DRIVE                      2                      1  
 PLANTATION

#1(\$350),#2(\$200),#12(\$200),#25(3X\$200),#26(4100),#29(\$200),#30(\$200),#31(\$200),#39(4X\$2000),#40(2X\$2500),#83(\$200),#85(3X\$2000),#86(\$200)	\$21,450
Other - Provide compliant table	\$2,500
Other - Provide directional signage that complies with legibility requirements.	\$75

<b>Facility Cost Estimate:</b>	<b>\$24,025</b>
--------------------------------	-----------------

**GREATER FORT LAUDERDALE CONVENTION AND VISITORS BUREAU - ADMINISTRATIVE**

100 E BROWARD BLVD, SUITE 2 7  
FORT LAUDERDALE

#5(\$5000),#9(\$2500),#15(\$1000),#19(\$200),#25(2X\$200),#42(\$500),#70(\$400) \$10,000

<b>Facility Cost Estimate:</b>	<b>\$10,000</b>
--------------------------------	-----------------

**HISTORICAL COMMISSION**

151 SW 2 ST 2 7  
FORT LAUDERDALE

#19(\$200),#25(\$200),#54(\$200) \$600  
Other - Remove cabinet. - (Operational) \$0

<b>Facility Cost Estimate:</b>	<b>\$600</b>
--------------------------------	--------------

**JUVENILE ASSESSMENT CENTER**

2600 SW 4 AVENUE 1 7  
FORT LAUDERDALE

#1(\$350),#13(2X\$2000),#19(\$200),#25(\$200),#42(\$500),#54(\$200),#68(\$400) \$5,850  
Other - Have staff ensure toilet paper is available. \$400  
Other - Repair stall door. \$250

<b>Facility Cost Estimate:</b>	<b>\$6,500</b>
--------------------------------	----------------

<b>LANIER JAMES EDUCATION CENTER</b>	School board property
--------------------------------------	-----------------------

1050 NW 7 COURT                    2                    8  
HALLANDALE

#1(\$350),#13(2x\$2000),#19(2x\$200),#25(2x\$200),#40(\$2500)                    \$0  
Other - Mount signs at 60 inches to centerline on the latch-side of the door.

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>LIBRARY - AFRICAN AMERICAN RESEARCH</b>
--------------------------------------------

2650 NW 6TH STREET                    2                    7  
FORT LAUDERDALE

#1(\$350),#13(\$2000),#26(2X\$100)                    \$2,550  
Other - Place oversized books flat on bottom shelf so that they do not protrude into the circulation path. - (Operational)                    \$0  
Other - Replace soap dispensers                    \$300

<b>Facility Cost Estimate:</b>	<b>\$2,850</b>
--------------------------------	----------------

<b>LIBRARY - ALVIN SHERMAN</b>
--------------------------------

3100 RAY FERRERO JR BLVD                    2                    7  
DAVIE

#8(\$200),#15(\$1000),#25(2X\$200),#26(\$100),#29(\$200),#30(\$200),#21(\$200), #39(\$2000)                    \$4,300

<b>Facility Cost Estimate:</b>	<b>\$4,300</b>
--------------------------------	----------------

**LIBRARY - BEACH BRANCH**

221 POMPANO BEACH BLVD      2      4  
 POMPANO BRACH

#19(\$200),#39(\$2000)	\$2,200
Structural - Provide new accessible restroom.	\$87,405

<b>Facility Cost Estimate:</b>	<b>\$89,605</b>
--------------------------------	-----------------

**LIBRARY - CARVER RANCHES**

4735 SW 18 ST      2      8  
 WEST PARK

#1(\$350),#999(\$100),#999(\$0)	\$350
Other - Remove shelves from back of toilet seats.	\$100
Other - Unlock gate next to bus stop.	\$0

<b>Facility Cost Estimate:</b>	<b>\$450</b>
--------------------------------	--------------

**LIBRARY - CENTURY PLAZA**

1890 W HILLSBORO BLVD      2      2  
 DEERFIELD BEACH

#1(\$250),#15(\$1000),#44(\$4500),#70(\$400),#73(\$1200),#75(\$200)	\$5,650
Other - Clear off accessible check-out counter.	\$0



<b>LIBRARY - DEERFIELD BEACH</b>
----------------------------------

837 E HILLSBORO BLVD                    2                    4  
 DEERFIELD BEACH

#9(\$2500),#25(\$200),#39(\$2000) \$4,700

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisles that are at least 5 feet wide. \$1,200

<b>Facility Cost Estimate:</b>	<b>\$5,900</b>
--------------------------------	----------------

<b>LIBRARY - FORT LAUDERDALE BRANCH (HOLIDAY PARK)</b>
--------------------------------------------------------

1300 E SUNRISE BLVD.                    2                    7  
 FORT LAUDERDALE

#1(\$350),#4(\$1000),#5(\$5000),#7(\$5000),#15(\$1000),#18(\$600),#25(\$200),#26(\$100),#39(\$2000),#44(\$2500),#60(\$5000),#62(\$500),#73(\$1200),#75(\$200) \$24,650

Other - Retrofit doorway. \$7,200

<b>Facility Cost Estimate:</b>	<b>\$31,850</b>
--------------------------------	-----------------

<b>LIBRARY - GALT OCEAN MILE</b>	Leased at Non-County Cost
----------------------------------	---------------------------

3403 GALT OCEAN DR                    2                    4  
 FORT LAUDERDALE

#1(\$350),#25(\$200),#54(\$200),#62(\$500),#70(\$400) \$0

Other - Clear off accessible counter. \$0

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>LIBRARY - HALLANDALE</b>	Leased County Cost: Non-renewal 9-3
-----------------------------	-------------------------------------

300 S FEDERAL HWY                    2                    6  
HALLANDALE

#1(\$350),#25(\$200),#39(\$2000),#54(\$200),#60(\$5000),#70(\$400)                    \$8,150

<b>Facility Cost Estimate:</b>	<b>\$8,150</b>
--------------------------------	----------------

<b>LIBRARY - IMPERIAL POINT</b>	
---------------------------------	--

5985 NORTH FEDERAL HWY            2                    4  
FORT LAUDERDALE

#1(\$350),#13(\$2000),#55(\$200)                    \$2,550

<b>Facility Cost Estimate:</b>	<b>\$2,550</b>
--------------------------------	----------------

<b>LIBRARY - LAUDERDALE LAKES</b>	Leased County Cost
-----------------------------------	--------------------

3521 NW 43 AVE                    2                    9  
LAUDERDALE LAKES

#1(\$350),#18(\$600),#25(2X\$200),#55(\$200),#58(\$2350),#60(\$5000),#62(\$500), #67(\$450),#72(\$1200)                    \$11,050

Other - Place large books parallel to circulation path on bottom shelf.                    \$0

Other - Retrofit door.                    \$9,000

Other - Tighten threshold edge.                    \$100

<b>Facility Cost Estimate:</b>	<b>\$20,150</b>
--------------------------------	-----------------

**LIBRARY - LAUDERHILL**

6399 W OAKLAND PARK BLVD      2      1  
 LAUDERHILL

#1(\$350),#26(2X\$100),#44(\$2500)      \$3,050

Other - Place large books parallel to circulation path on bottom shelf.      \$0

**Facility Cost Estimate:      \$3,050**

**LIBRARY - LAUDERHILL MALL**

Leased - No renewal 9-30-2008

4257 NW 12 ST      2      9  
 LAUDERHILL

#1(\$350),#26(2X\$100),#44(\$2500)      \$32,450

Other - Clear low counter space and keep it clear.      \$0

**Facility Cost Estimate:      \$32,450**

**LIBRARY - MAIN**

100 S ANDREWS AVE      2      7  
 FORT LAUDERDALE

#8(3X\$300),#18(8X\$300),#25(\$250),#32(2X\$100),#40(\$2500),#49(9X\$800),#53(8X\$150),#69(10X\$200),#71(14X\$400),#86(12X\$300)      \$25,800

Other - Informational signage at retail display      \$100

Other - Lower raised character on hoistway's entrance (2)      \$300

Other - Lower the urinal rim (4)      \$6,000

Other - New accessible lavatory counter area	\$2,500
Other - Provide a new accessible podium	\$1,000
Other - Provide a new display case counter	\$3,000
Other - Provide accessible handrails (7)	\$37,100
Other - Provide accessible signage - passenger loading zone	\$5,000
Other - Provide accessible symbol signage at the vision impaired computer station	\$100
Other - Provide an emergency communication system (9)	\$36,000
Other - Provide directional signage to direct people with disabilities to use the ramp route (5)	\$500
Other - Provide electric door opener (4)	\$12,000
Other - Provide informational signage - north entrance	\$250
Other - Provide new stall compartment (24)	\$72,000
Other - Provide new accessible stall compartment (8)	\$48,000
Other - Provide new door frame and enlarge opening (8)	\$12,000
Other - Provide paper towel dispenser	\$400
Other - Provide wall mounted handrails	\$21,420
Other - Reconstruct concrete pad areas to accommodate wheelchair at auditorium	\$19,500
Other - Reconstruct curb ramps (3)	\$6,000
Other - Reconstruct ramp to provide adequate landing (9)	\$13,500
Other - Reinstall and raise the existing drinking fountain (7)	\$6,100
Other - Relocate electric hand-dryer and provide panel at existing opening (5)	\$4,500

Other - Relocate sanitary napkin dispenser	\$400
Other - Relocate semi-recessed trash receptacle (5)	\$2,600
Other - Repair existing electric door opener	\$300
Other - Retrofit a portion of the book check-out counter and provide accessibility symbol signage	\$1,500
Other - Retrofit pedestrian book drop off	\$1,200
Other - Retrofit service transaction display counter at cashier area	\$1,200
Other- Relocate baby changing station (2)	\$800

<b>Facility Cost Estimate:</b>	<b>\$341,070</b>
--------------------------------	------------------

**LIBRARY - MARGATE**

5810 PARK DRIVE                      2                      2  
MARGATE

#15(4X\$1000),#19(\$200)                      \$1,200

<b>Facility Cost Estimate:</b>	<b>\$1,200</b>
--------------------------------	----------------

**LIBRARY - NORTH LAUDERDALE**

6901 KIMBERLY BLVD                      2                      9  
NORTH LAUDERDALE

#1(\$350),#26(\$100),#70(\$400)                      \$3,350

Other - Install sanitary napkin dispenser no more than 36 inches from the back wall.                      \$250



#1(\$350),#23(\$2500),#25(2X\$200),#67(\$450),#73(\$1200),#85(\$2000) \$6,900

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisles that are at least 5 feet wide. \$1,600

<b>Facility Cost Estimate:</b>	<b>\$8,500</b>
--------------------------------	----------------

<b>LIBRARY - POMPANO BEACH</b>	Leased County Cost
--------------------------------	--------------------

1213 E ATLANTIC BLVD                    2                    2  
 POMPANO BEACH

#1(\$350),#8(\$200),#19(\$200),#39(\$2000),#54(3X\$200),#62(\$500),#70(\$400) \$4,250

Other - Reconfigure stall. \$11,000

Other - Relocate hand dryers so that they are out of the circulation path. \$250

<b>Facility Cost Estimate:</b>	<b>\$15,500</b>
--------------------------------	-----------------

<b>LIBRARY - RIVERLAND</b>
----------------------------

2710 DAVIE BLVD                    2                    7  
 FORT LAUDERDALE

#1(\$350),#3(\$5000),#26(\$100) \$5,450

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisles that are at least 5 feet wide. \$1,200

<b>Facility Cost Estimate:</b>	<b>\$6,650</b>
--------------------------------	----------------

**LIBRARY - SOUTH WEST REGIONAL**

16835 SHERIDAN STREET            2            8  
PEMBROKE PINES

#1(\$350),#25(\$200),#39(\$2000),#999(\$200),#999(\$0)            \$2,550  
Other - Place materials within reach range, preferably 48 inches.            \$0  
Other - Replace latch.            \$200

**Facility Cost Estimate:            \$2,750**

**LIBRARY - STIRLING ROAD**

3151 STIRLING ROAD            2            7  
HOLLYWOOD

#1(\$350),#25(\$200)            \$550  
Other - Repair faucet            \$550

**Facility Cost Estimate:            \$1,100**

**LIBRARY - SUNRISE**

10550 W OAKLAND PARK BLV            2            3  
SUNRISE

#1(\$350),#25(\$200)            \$550  
Other - Repair stall latch.            \$200

**Facility Cost Estimate:            \$750**

<b>LIBRARY - SUNSET STRIP</b>	Leased Non-County Cost
-------------------------------	------------------------

6600 SUNSET STRIP                    2                    9  
 SUNRISE

#1(\$350),#13(\$2000),#19(\$200),#26(2X\$100)                    \$0

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>LIBRARY - TAMARAC</b>	
--------------------------	--

8701 W COMMERCIAL BLVD            2                    3  
 TAMARAC

#1(\$350),#25(\$200),#44(\$2500)                    \$3,050

Other - Keep accessible counter clear - (Operational)                    \$0

<b>Facility Cost Estimate:</b>	<b>\$3,050</b>
--------------------------------	----------------

<b>LIBRARY - TYRONE BRYANT</b>	
--------------------------------	--

2230 NW 21 AVE                    2                    9  
 FORT LAUDERDALE

#1(\$350),#25(\$200),#44(\$2500),#60(\$5000),#62(\$500),#73(\$1200)                    \$9,750

Other - Mount sign on latch side of the door 60 inches to centerline.                    \$75

Other - Mount toilet paper no more than 36 inches from the back wall.                    \$200

<b>Facility Cost Estimate:</b>	<b>\$10,025</b>
--------------------------------	-----------------

<b>LIBRARY - WEST ATLANTIC</b>	Leased Non-County Cost
--------------------------------	------------------------

10641 W ATLANTIC BLVD            2            3  
CORAL SPRINGS

#1(\$350),#19(\$200),#25(\$200),#54(\$200),#62(\$500),#70(\$400)            \$0

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>LIBRARY - WEST REGIONAL</b>	New library opened since assessment
--------------------------------	-------------------------------------

8601 W BROWARD BLVD            2            1  
PLANTATION

#1(\$350),#25(2X\$200),#28(\$25000),#60(\$5000),#62(\$500),#67(\$450),#70(\$400), #75(\$200)            \$0

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>LIBRARY - WESTON</b>
-------------------------

4205 BONAVENTURE BLVD            2            8  
WESTON

#1(\$350),#10(\$3000),#25(\$200),#44(\$2500),#53(\$200),#85(\$2000)            \$8,250

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisles that are at least 5 feet wide.            \$3,200

<b>Facility Cost Estimate:</b>	<b>\$11,450</b>
--------------------------------	-----------------









Other - Install compliant/accessible signage that will notify people of the availability of a listening system.	\$75
Other - Install the toilet paper dispenser so that it is not more than 36" from the rear wall.	\$200
Other - Install the toilet paper dispenser so that it is not more than 36" from the rear wall.	\$200
Other - Provide a removable chair in the jury box.	\$10,620
Other - Provide a table that is at least 27" high (bottom), 30" wide, and 19" deep.	\$2,500
Other - Provide accessible self-closing valve time at both sinks.	\$525
Other - Provide accessible/compliant handrails with the proper extensions.	\$47,475
Other - Provide an electric door opener at both restrooms doors in lieu of door maneuvering clearances at the corridor side.	\$5,500
Other - Provide Compliant and accessible tables.	\$2,500
Other - Provide compliant/accessible directional signage.	\$75
Other - Provide compliant/accessible emergency intercom for the elevator.	\$7,100
Other - Provide compliant/accessible handrails.	\$125
Other - Provide compliant/accessible tables.	\$2,500

	Facility Cost Estimate:	\$166,145
--	-------------------------	-----------

**NORTH REGIONAL HEALTH CENTER (HUGES BUILDING)**

205 NW 6 AVENUE  
POMPANO BEACH

#1(\$350),#25(2X\$200),#26(3X\$100),#29(\$200),#30(\$200),#31(2X\$200),#40(\$2500),#48(\$3000),#49(\$5000),#51(\$200),#54(\$200),#55(\$200),#68(\$400)	\$13,350
Other - Install an emergency intercom that is identified with Braille and raised letters on the outside of the box.	\$7,100
Other - Remove the clutter.	\$0

<b>Facility Cost Estimate:</b>	<b>\$20,450</b>
--------------------------------	-----------------

<b>NORTH REGIONAL HEALTH CENTER (HUNTER BUILDING)</b>
-------------------------------------------------------

601 W ATLANTIC BLVD                      1                      9  
POMPANO BEACH

#2(\$200),#3(\$5000),#18(2X\$600),#25(\$200),#26(2X\$100),#29(\$200),#30(\$200),#31(2X\$200),#40(\$2500),#48(\$3000),#49(\$5000),#51(\$200),#53(\$200)#54(\$200),#55(\$200),#62(\$500),#68(\$400),#70(\$400),#74(\$4000)	\$24,200
Other - Install an emergency intercom that is identified with Braille and raised letters on the outside of the box.	\$7,100
Other - Raised toilet seat.	\$1,000
Other - Replace the fountain (entirely) with a compliant and accessible fountain.	\$1,500
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with an access aisle that is at least 5 feet wide	\$1,600

<b>Facility Cost Estimate:</b>	<b>\$35,400</b>
--------------------------------	-----------------



**OUR HOUSE**

408 NE 4TH STREET                    1                    7  
FORT LAUDERDALE

#1(\$350),#12(2X\$200),#31(2X\$200),#54(\$200),#55(\$200),#59(\$5000),#67(\$450),#70(\$400)                    \$7,200

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.                    \$800

Other - Re-stripe the parking lot so that designated accessible space(s) are the closest to an accessible entrance.                    \$800

**Facility Cost Estimate:                    \$8,800**

**PERSONNEL - ANNEX B**

115 SOUTH ANDREWS AV                    2                    7  
FORT LAUDERDALE

#10(2X\$3000),#18(\$600),#29(\$200),#31(\$200)                    \$7,000

**Facility Cost Estimate:                    \$7,000**

**PROPERTY APPRAISER EXTENSION**

101 SW 1 AVE                    3                    7  
FORT LAUDERDALE

#5(\$5000),#18(\$600),#19(2X\$200),#25(\$200),#54(\$200),#62(\$500),#63(\$1000),#68(\$400),#70(\$400),#74(\$4000)                    \$12,700

**Facility Cost Estimate:                    \$12,700**

<b>PUBLIC DEFENDER</b>
------------------------

412 SE 6TH STREET                    2                    7  
 FORT LAUDERDALE

#19(\$200),#39(\$2000),#59(\$5000)                    \$7,200

<b>Facility Cost Estimate:</b>	<b>\$7,200</b>
--------------------------------	----------------

<b>READING CENTER - HOLLYWOOD BEACH</b>	Leased Non-County Cost
-----------------------------------------	------------------------

1301 S. OCEAN DRIVE                    2                    6  
 HOLLYWOOD

#1(\$350),#25(\$200),#26(\$100),#40(\$2500),#67(\$450)                    \$0

<b>Facility Cost Estimate:</b>	<b>\$0</b>
--------------------------------	------------

<b>SEXUAL ASSAULT CENTER</b>
------------------------------

400 NE 4 ST                    1                    7  
 FORT LAUDERDALE

#1(\$350),#9(\$2500),#10(\$3000),#18(\$600),#19(\$200),#26(\$100),#29(\$200),#30(\$200),#31(2X\$200),#39(\$2000),#53(200),#54(\$200),#55(\$200),#62(\$500),#67(\$450),#68(\$400),#70(\$400),#86(\$200)                    \$15,200

One in every eight designated accessible spaces, but not less than one, shall be designated as van accessible.                    \$350

Other - 51a. Add raised seat.                    \$1,000

Other - Re-stripe the lot so that it has at least two compliant/accessible designated parking spaces with at least one of the spaces having the "van accessible" designation with compliant signage. \$800

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisles that are at least 5 feet wide. \$800

<b>Facility Cost Estimate:</b>	<b>\$18,150</b>
--------------------------------	-----------------

<b>SOUTH BROWARD FIELD OFFICE</b>
-----------------------------------

7999 W PEMBROKE ROAD            1            6  
 PEMBROKE PINES

#1(\$350),#12(\$200),#18(2X\$600),#19(\$200),#29(\$200),#30(\$200),#31(2X\$200),#39(\$2000),#54(\$200),#55(\$200),#60(\$5000),#62(\$500),#67(\$450),#70(\$400),#86(\$200) \$11,700

<b>Facility Cost Estimate:</b>	<b>\$11,700</b>
--------------------------------	-----------------

<b>SOUTH FAMILY SUCCESS CENTER</b>
------------------------------------

4733 SW 18 ST                    1            8  
 HOLLYWOOD

#4(1000),#8(\$200),#31(\$200),#40(\$2500),#53(\$200),54(\$200),#55(\$200),#60(\$5000),#62(\$500),#68(\$400) \$10,400

<b>Facility Cost Estimate:</b>	<b>\$10,400</b>
--------------------------------	-----------------

**SOUTH REGIONAL COURTHOUSE**

3550 HOLLYWOOD BLVD  
HOLLYWOOD

2

6

\$1(\$350),#3(2X\$5000),#5(3X\$5000),#7(8X\$200),#19(2X\$200),#24(35X\$200),#29(\$200),#30(11X\$200),#33(3X\$500),#38(3X\$200),#39(10X\$2000),#40(\$2500),#44(8X\$2500),#45(2X\$2500),#49(2X\$5000),#51(2X\$200),#52(2X\$7100),#54(2X\$200),#55(3X\$200),#58(\$2X\$2350),#60(8X\$5	\$176,400
Other - Install a toilet seat to be in compliance - 17 - 19".	\$1,000
Other - Install compliant toilet seat.	\$1,000
Other - Install lavatory and countertop at correct height.	\$2,500
Other - Install lavatory and countertop at correct height.	\$2,500
Other - Install signage at 60" to centerline.	\$75
Other - Install signage at correct height.	\$75
Other - Mount alarm 80 inches high.	\$500
Other - Mount toilet paper dispenser no further than 36 inches from back wall.	\$200
Other - Mount toilet paper no further than 36 inches from back wall.	\$200
Other - Mount toilet paper no further than 36 inches from back wall.	\$200
Other - Place signage on latch side of the door, 60 inches to centerline.	\$75
Other - Provide accessible lavatory and countertop at correct height.	\$2,500
Other - Provide Compliant pay telephone.	\$1,000

Other - provide compliant pay telephones.	\$1,000
Other - Provide compliant pay telephones.	\$1,000
Other - Provide compliant pay telephones.	\$1,000
Other - Provide new accessible lavatory - lavatory countertop at correct height.	\$2,500
Other - Provide new accessible lavatory countertop at correct height.	\$2,500
Other - provide new compliant faucet hardware and self closing valve time at accessible lavatory.	\$525
Other - Provide new compliant faucet hardware and self-closing valve time at accessible lavatory.	\$525
Other - Provide new robe hook at 60" high.	\$50
Other - provide water pipes protection.	\$150
Other - Relocate sanitary napkin disposal at correct height	\$250
Other - Relocate toilet paper dispenser no further than 36" from back wall.	\$200
Other - Relocate toilet paper dispenser no further than 36" from back wall.	\$200
Other - relocate toilet paper dispenser no further than 36" from back wall.	\$200
Other - Repair fountain to ensure adequate water flow height.	\$150
Other - Repair fountain to ensure adequate water flow height.	\$150
Other - repair fountain to ensure adequate water flow height.	\$150
Other - Repair fountain to ensure adequate water flow height.	\$150
Other - Retrofit door	\$9,000



#1(\$350),#18(\$600),#19(\$200),#54(\$200),#62(\$500),#67(\$450),  
#70(\$400) \$2,700

<b>Facility Cost Estimate:</b>	<b>\$2,700</b>
--------------------------------	----------------

**TRAFFIC ENGINEERING BUILDING**

2300 W COMMERCIAL BLVD            3            9  
FORT LAUDERDALE

#1(\$350),#40(\$2500) \$2,850

<b>Facility Cost Estimate:</b>	<b>\$2,850</b>
--------------------------------	----------------

**VINNETTE CAROL THEATER**

503 SE 6 ST                            3            7  
FORT LAUDERDALE

#3(\$5000),#15(\$1000),#19(\$200),#25(\$200),#62(\$500),#69(\$10  
50) \$7,950

<b>Facility Cost Estimate:</b>	<b>\$7,950</b>
--------------------------------	----------------

**VOTING EQUIPMENT WAREHOUSE**

529 SW 2 AVE                        3            7  
FORT LAUDERDALE

#1(\$350),#2(\$200),#18(\$600),#54(\$200),#62(\$500),#999(\$200) \$1,850

<b>Facility Cost Estimate:</b>	<b>\$1,850</b>
--------------------------------	----------------

**WATER AND WASTE WATER SERVICES ENGINEERING DIVISION**

2555 W COPANS ROAD                    1                    2  
 POMPANO BEACH

#1(\$350),#18(\$600),#19(2X\$200),#25(\$200),#29(\$200),#52(\$7100),#54(\$200)                    \$9,050

**Facility Cost Estimate:                    \$9,050**

**WEST REGIONAL COURTHOUSE**

100 N PINE ISLAND RD                    2                    1  
 PLANTATION

#19(2X\$200),#23(\$2500),#25(3X\$200),#28(2X\$25000),#29(4X\$200),#30(4X\$200),#31(4X\$200),#33(2X\$500),#40(7X\$2500),#44(\$2500),#48(\$3000),#49(\$5000), #85(\$2000)                    \$86,900

Other - Designate the proportionate number of wheelchair seating to the capacity seating with the appropriate sign/marker. Provide a removable chair in the jury box whose space should adhere to regulations.                    \$10,620

Other - Designate the proportionate number of wheelchair seats to the capacity seating with the appropriate sign/marker. Provide a removable chair in the jury box.                    \$10,620

Other - Designate the proportionate number of wheelchair seats to the capacity seating identified with the appropriate sign/marker. Provide wheelchair access to the bench platform by moving furniture, etc.                    \$26,550

Other - Install compliant/accessible handrails and extensions (at top and bottom) on both sides of stairs.                    \$125

Other - Provide a compliant and accessible emergency intercom system.                    \$7,100

Other - Provide a compliant and accessible emergency intercom system.	\$7,100
Other - Provide a removable chair in the jury box with the proper clear space.	\$10,620
Other - Provide an alternate space that is at least 5' x 5' wide with a portable microphone so a person in a wheel chair may testify from a recessed seating position.	\$2,600
Other - Provide/Adjust character plates so that they are between 1" and 48" high (up to 54" if a side reach is possible).	\$350

<b>Facility Cost Estimate:</b>		<b>\$162,585</b>
<b>Public Works Cost Estimate:</b>	<b>\$3,015,615</b>	

## Port Everglades Structural and Programmatic Details Cost Estimates

Facility Name	Priority	District	Cost Estimates
---------------	----------	----------	----------------

<b>PORT EVERGLADES - ADMINISTRATION</b>			
-----------------------------------------	--	--	--

1850 ELLER DRIVE HOLLYWOOD	3	6	<b>Recommendations</b> #25(2X\$200), #26(\$100), #54(2X\$200),#60(\$5000),#62(\$500),#70(\$400) Other - Replace latch slide. Other - Mount toilet paper dispenser no further than 36 inches from rear wall. Other - Correct curb ramp slope to meet ADAG/Florida Accessibility code and include a detectable warning surface. Other - Move accessible spaces closer to the entrance and restripe parking lot to meet the required dimensions. Other - Correct the slope/incline to meet ADAC/Florida accessibility code. Other - Total	\$6,800 \$150 \$400     \$136,500
-------------------------------	---	---	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------

	<b>Facility Cost Estimate:</b>	<b>\$143,850</b>
--	--------------------------------	------------------

<b>PORT EVERGLADES - BUILDING 1 (TERMINAL)</b>			
------------------------------------------------	--	--	--

1800 SE 18 STREET FORT LAUDERDALE	3	4	<b>Recommendations</b> #39(\$2000), #48(\$3000), #55(2X\$200),#60(\$5000),#62(\$500), #70(\$400) Other - Install latch handle Other - Install latch handle Other - Fix volume control	\$11,300 \$150 \$150 \$500
--------------------------------------	---	---	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------

	<b>Facility Cost Estimate:</b>	<b>\$12,100</b>
--	--------------------------------	-----------------

**PORT EVERGLADES - BUILDING 2 (TERMINAL)**

1801 SE 20 STREET                      3                      4  
FORT LAUDERDALE

Recommendations #15(\$1000), #25(\$200),#39(\$2000), #49(\$5000),#60(\$5000), #62(\$500),                      \$14,900  
#68(2X\$400), #70(\$400)

**Facility Cost Estimate:                      \$14,900**

**PORT EVERGLADES - BUILDING 4 (TERMINAL)**

1800 SE 20 STREET                      3                      4  
FORT LAUDERDALE

Recommendations #25(\$200),#39(\$2000), #55(\$200),#60(\$5000)                      \$7,400  
Other - Install signs 60 inches to centerline                      \$250

**Facility Cost Estimate:                      \$7,650**

**PORT EVERGLADES - BUILDING 18 (TERMINAL)**

1901 SE 32 STREET                      3                      4  
HOLLYWOOD

Recommendations #19(\$200), #25(\$200), #39(\$2000), #54(\$200), #60(\$5000), #75(\$200)                      \$7,800

**Facility Cost Estimate:                      \$7,800**

**PORT EVERGLADES - BUILDING 19 (TERMINAL)**

2019 ELLER DRIVE                      3                      4  
HOLLYWOOD

Recommendations #25(\$200),#39(\$2000), #55(\$200),#60(\$5000),#68(\$400),                      \$10,400  
#70(\$400),#75(\$200), #77(\$2000)

**Facility Cost Estimate:                      \$10,400**

**PORT EVERGLADES - BUILDING 21 (TERMINAL)**

2021 ELLER DRIVE  
HOLLYWOOD

3 4

**Recommendations** #25(\$200),#39(\$2000), #70(\$400) \$2,600  
Other - Remove urinal partition which interferes with stall door swing. \$250

**Facility Cost Estimate: \$2,850**

**PORT EVERGLADES - BUILDING 22 (TERMINAL)**

2022 ELLER DRIVE  
HOLLYWOOD

3 4

**Recommendations** #18(\$600), #19(\$200), #25(2X\$200), #30(\$200), #39(\$2000), #54(\$200), \$4,100  
#62(\$500)

**Facility Cost Estimate: \$4,100**

**PORT EVERGLADES - BUILDING 24 (TERMINAL)**

2024 ELLER DRIVE  
HOLLYWOOD

3 4

**Recommendations** #18(\$600), #19(\$200), #25(\$200), #48(\$3000), #49(\$5000), #54(\$200), \$14,800  
#60(\$5000), #68(\$400), #73(\$200)

**Facility Cost Estimate: \$14,800**

**PORT EVERGLADES - BUILDING 25 (TERMINAL)**

2025 ELLER DRIVE  
HOLLYWOOD

3 6

**Recommendations** #45(\$2500), #49(\$5000), #54(\$200), #60(\$5000), #62(\$500), #70(\$400), \$14,000  
#75(2X\$200)

**Facility Cost Estimate: \$14,000**

**PORT EVERGLADES - BUILDING 26 (TERMINAL)**

2026 ELLER DRIVE  
HOLLYWOOD

3 6

**Recommendations** #1(\$350), #2(\$200), #39(\$2000), #54(\$200), #59(\$5000), #60(\$5000), #62(\$500), #68(\$400), #73(\$200), #75(\$200) \$14,050  
Other - Repair stall latch \$150

**Facility Cost Estimate: \$14,200**

**PORT EVERGLADES - BUILDING 29 (TERMINAL)**

2200 SE 35 STREET  
FORT LAUDERDALE

3 6

**Recommendations** #1(\$350), #2(\$200), #19(\$200), #60(\$5000), #70(\$400), #75(\$200) \$6,350  
Other - Signage should be at 60 inches centerline on lineage. \$250  
Other - Replace with or provide additional accessible dispensers. \$450

**Facility Cost Estimate: \$7,050**

**PORT EVERGLADES - BUILDING 611 (OFFICE)**

2550 EISENHOWER BLVD  
FORT LAUDERDALE

3 4

**Recommendations** #1(\$350), #15(\$1000), #17(\$2000), #19(\$200), #25(\$200), #54(\$200), #62(\$500) \$4,450  
Other - Lower toilet cover dispensers \$750

**Facility Cost Estimate: \$5,200**

**PORT EVERGLADES - MIDPORT PARKING GARAGE**

2020 ELLER DRIVE  
HOLLYWOOD

3 4

**Recommendations** #2(\$200), #48(\$3000) \$3,200

**Facility Cost Estimate: \$3,200**

**PORT EVERGLADES - NORTHPORT PARKING GARAGE**

2000 EISENHOWER BLVD                    3                    4  
HOLLYWOOD

Recommendations #2(4X\$200), #8(\$200), #51(\$200), #52(2X\$4000)                    \$9,200

**Facility Cost Estimate:**                    **\$9,200**

**PORT EVERGLADES - PUBLIC SAFETY OFFICES**

1901 ELLER DRIVE                    3                    4  
HOLLYWOOD

Recommendations #1(\$350), #15(\$1000), #19(\$200), #25(2X\$200), #30(\$200),#39(\$2000),  
#54(\$200), #70(\$400)                    \$4,750

**Facility Cost Estimate:**                    **\$4,750**

**Port Everglades Cost Estimate                    \$276,050**

## Parks & Recreation Structural and Programmatic Details Cost Estimates

Facility Name	Priority	District	Cost Estimates
---------------	----------	----------	----------------

<b>PARKS ADMINISTRATION BUILDING - NORTH</b>
----------------------------------------------

950 NW 38 ST OAKLAND PARK	3	9	<b>Recommendations</b> #1(\$200), #2(\$200), #3(\$5000), #5(\$5000), #12(\$200), #18(3X\$200), #19(\$200), #25(\$200), #28(\$5000), #32(\$200), #44(\$2000), #53(\$200), #54(\$200), #55(\$200), #60(\$5000), #62(\$500), #70(\$400) Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$25,300  \$1,000
------------------------------	---	---	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------

<b>Facility Cost Estimate:</b>	<b>\$26,300</b>
--------------------------------	-----------------

<b>PARKS - BOATERS PARK</b>
-----------------------------

DANIA BEACH CUT OFF CANAL DANIA BEACH	1	7	<b>Recommendations</b> #26(\$100)  Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	\$100 \$800
------------------------------------------	---	---	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------

<b>Facility Cost Estimate:</b>	<b>\$900</b>
--------------------------------	--------------

<b>PARKS - BOULEVARD GARDENS PARK</b>
---------------------------------------

304 NW 28 WAY FORT LAUDERDALE	3	7	<b>Recommendations</b> #1(\$200), #28(\$5000), #54(\$200), #55(\$200), #69(\$400) Install Directional Signage	\$6,000 \$0
----------------------------------	---	---	------------------------------------------------------------------------------------------------------------------	----------------

Other - 22a. Adjust the closers so that they are at the compliant height of 80" above the floor.	\$200
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000

<b>Facility Cost Estimate:</b>	<b>\$7,200</b>
--------------------------------	----------------

<b>PARKS - BRIAN PICCOLLO PARK</b>
------------------------------------

9501 SHERIDAN ST                      1                      5  
 COOPER CITY

<b>Recommendations</b> #1(5X\$200), #3(\$5000), #4(\$1000), #8(\$200), #12(\$200), #19(5X\$200), #23(\$200), #28(\$5000), #29(\$200), #30(\$200), #31(\$200), #62(4X\$500), #67(\$200), #70(4X\$400), #75(\$200), #80(\$500), #86(\$200)	\$18,300
Move or remove partitions to allow for an area of at least 5 feet by 5 feet	\$50,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet	\$50,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet	\$50,000
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$1,000
Other - Provide compliant signage mounted above 80" with 3" letters, with	\$200
Other - Implement a plan to ensure that the accessible surface around the play components is swept clean of the sand throughout the day.	\$75,000
Other - Re-stripe the lot to put the space that was relocated to where it was originally so a patron will not have to travel behind parked cars to the	\$1,000
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$1,000
Other - Remove/relocate the object preventing access to the bell.	\$0
Other - Provide an accessible route to and surface under the play area.	75000
Other - Install a transfer platform/ramp to the elevated play components that is accessible and compliant.	\$100,000
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with 5 foot wide access aisles.	\$1,000

<b>Facility Cost Estimate:</b>	<b>\$422,500</b>
--------------------------------	------------------

**PARKS - CB SMITH PARK**

900 N FLAMINGO RD  
PEMBROKE PINES

1

5

<b>Recommendations</b>	#2(\$200), #3(2X\$5000), #5(2X\$5000), #8(\$200), #12(\$200), #18(\$200), #19(3X\$200), #23(\$200), #25(3X\$200), #29(\$1200), #30(\$200), #31(\$200), #40(\$2000), #53(2X\$200), #54(\$200), #55(\$200), #62(\$500), #63(\$200), #64(\$0), #67(\$200), #70(2X\$400), #80(\$500)	\$28,800
	Add accessible signage, placed to the side of the door, 60 inches to centerline.	\$400
	Add accessible signage, placed to the side of the door, 60 inches to centerline.	\$400
	Move or remove partitions to allow for an area of at least 5 feet by 5 feet	\$320,000
	Add grab bars.	\$2,000
	Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.	\$50,000
	Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	\$2,000
	Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$2,000
	Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$1,000
	Other - Install the toilet paper dispenser so that it is not more than 36" from the rear wall.	\$200
	Other - Install a stall door with compliant handles/latch inside and out that is operable with a closed fist.	\$500
	Other - Install the toilet paper dispenser so that it is not more than 36" from the rear wall.	\$200
	Other - Provide an additional battery pack.	\$500
	Other - Provide a call button that alerts employee that a patron wishes to use the pool lift.	\$0
	Other - Re-stripe the lot so that it has at least two compliant and accessible designated parking spaces with at least one of the spaces having the "van accessible" designation with compliant signage.	\$2,000

<b>Facility Cost Estimate:</b>	<b>\$410,000</b>
--------------------------------	------------------

**PARKS - CRYSTAL LAKE**

3299 NE 3RD AVENUE 3 2  
POMPANO BEACH

**Recommendations** #86(\$200) \$200  
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisles that are at least 5 foot wide. \$1,000

**Facility Cost Estimate: \$1,200**

**PARKS - DEERFIELD ISLAND PARK**

1720 DEERFIELD ISLAND 1 4  
DEERFIELD BEACH

**Recommendations** #1(\$200), #5(#5000), #9(\$200), #10(\$3000), #12(\$200), #17(\$2000), \$16,500  
#25(\$200), #26(\$100), #28(\$5000), #31(\$200), #69(\$400)  
Provide compliant sign \$400  
Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers. \$400  
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide. \$1,000

**Facility Cost Estimate: \$18,300**

**PARKS - DELEVOE PARK**

2520 N.W. 6TH STREET 2 7  
FORT LAUDERDALE

**Recommendations** #1(\$200), #19(2X\$200), #23(2X\$200), #25(\$200) \$1,200  
Install Directional sign. \$0  
Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers. \$400

Other - Fill in the holes/drop-offs with dirt, mulch, etc. so that they are even with the sidewalk surface.	\$0
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$1,000
Other - 55a. Provide a compliant and accessible soap dispenser.	\$50
Other - Provide a cane detectable barrier on each side at floor level.	\$200

<b>Facility Cost Estimate:</b>	<b>\$2,850</b>
--------------------------------	----------------

<b>PARKS - EASTERLIN PARK</b>
-------------------------------

1000 NW 38 ST	2	9
OAKLAND PARK		

<b>Recommendations #1(\$200), #19(\$200), #53(\$200), #59(\$500), #62(\$500)</b>	\$1,600
Remove obstacles.	\$400
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing. (Recommended for	\$400,000
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000

<b>Facility Cost Estimate:</b>	<b>\$403,000</b>
--------------------------------	------------------

<b>PARKS - FERN FOREST PARK</b>
---------------------------------

201 LYONS ROAD SOUTH	2	2
COCONUT CREEK		

<b>Recommendations #1(\$200), #2(\$200), #74(\$4000)</b>	\$4,400
Adjust door closer to the required 8.5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	\$0
	\$0
Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.	\$100,000
Replace with or provide additional accessible dispensers.	\$0

Lower or tilt down the mirror.	\$0
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000

<b>Facility Cost Estimate:</b>	<b>\$105,400</b>
--------------------------------	------------------

<b>PARKS - FRANKLIN PARK</b>
------------------------------

2501 FRANKLIN DRIVE	2	7
FORT LAUDERDALE		

<b>Recommendations #26(\$100)</b>	\$100
-----------------------------------	-------

Provide directional signage with the International Symbol of Accessibility	\$0
Adjust door closer to the required 8.5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	\$400

Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	\$400
Other - Provide computer stations that are at least 27" high (bottom), 30" wide, and 19" deep.	\$5,000

<b>Facility Cost Estimate:</b>	<b>\$5,900</b>
--------------------------------	----------------

<b>PARKS - HILLSBORO PINELAND PARK</b>
----------------------------------------

5591 NW 74 PLACE	3	2
COCONUT CREEK		

<b>Recommendations #1(\$200), #5(\$5000)</b>	\$5,200
----------------------------------------------	---------

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000
-----------------------------------------------------------------------------------------------------------------------	---------

<b>Facility Cost Estimate:</b>	<b>\$6,200</b>
--------------------------------	----------------

<b>PARKS - HOLLYWOOD NORTH BEACH PARK</b>
-------------------------------------------

3601 N OCEAN DR	2	6
-----------------	---	---

HOLLYWOOD

Recommendations #1(\$200), #2(\$200), #26(\$100)

\$500

**Facility Cost Estimate: \$500**

**PARKS - LAFAYETTE HART PARK**

2851 NW 8TH ROAD 2 7  
FORT LAUDERDALE

Recommendations #12(\$200), #25(\$200), #26(\$100), #29(\$200), #53(\$200), #54(\$200), #55(\$200), #70(\$400) \$1,700  
Adjust height of railings. \$10,000  
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing. \$200,000  
Other - 24a., 25a., 26a. Provide a compliant and accessible sign. \$200

**Facility Cost Estimate: \$211,900**

**PARKS - LEWIS CHISM PARK**

2620 NW 8TH STREET 3 7  
FORT LAUDERDALE

Recommendations #26(\$100) \$100

**Facility Cost Estimate: \$100**

**PARKS - MARKHAM PARK**

16001 W SR84 1 5  
SUNRISE

Recommendations #1(\$200), #3(\$5000), #8(2X\$200), #12(\$200), #19(5X\$200), #25(11X\$200), #26(\$200), #32(6X\$200), #40(\$2000), #53(9X\$200), #54(7X\$200), #55(7X\$200), #60(\$5000), #62(6X\$500), #69(\$400), #70(8X\$400) \$28,600  
Install Directional sign. \$0  
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing. (Recommended CIP) \$60,000

Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$60,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$200,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$200,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$60,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$200,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$60,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.(Recommended CIP)	\$1,000
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$200
Other - Adjust door closer so that the door takes at least 3 seconds to close or replace the closer with new compliant/accessible closers.	\$200
Other - Install the toilet paper dispenser so that it is not more than 36" from the rear wall.	\$500
Other - Install a stall door with compliant handles/latch inside and out that is operable with a closed fist.	\$500

<b>Facility Cost Estimate:</b>	<b>\$871,000</b>
--------------------------------	------------------

<b>PARKS - MCTYRE PARK</b>
----------------------------

3500 SW 56 AVE	3	8		
PEMBROKE PARK			<b>Recommendations #19(2X\$200),</b>	<b>\$400</b>

Install Directional sign.	\$400
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing.	\$75,000
Lower tilt the mirrir	\$800
Other - Install a compliant/accessible surface underneath the play area components that is firm, stable, and slip resistant.	\$75,000

<b>Facility Cost Estimate:</b>	<b>\$151,600</b>
--------------------------------	------------------

<b>PARKS - PLANTATION HERITAGE PARK</b>
-----------------------------------------

11S FIGTREE LANE                    2                    7  
 PLANTATION

<b>Recommendations</b> #2(\$200), #12(2X\$200), #18(\$200), #19(\$200), #23(\$200),#26(\$100), #28(\$5000), #53(\$200),#62(\$500), #74(\$4000), #75(\$200)	\$11,200
One in every eight designated accessible spaces, but not less than one, shall be designated as van accessible.	\$1,600
	\$0
Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	
Other - Provide a cane detectable barrier on each side at floor level.	\$200
Other - 51a. Add a raised seat.	\$200
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000

<b>Facility Cost Estimate:</b>	<b>\$14,200</b>
--------------------------------	-----------------

<b>PARKS - QUIET WATERS PARK</b>
----------------------------------

401 S POWERLINE RD                    1                    2  
 DEERFIELD BEACH

<b>Recommendations</b> #1(2X\$200),#5(3X\$5000), #8(2X\$200), #10(\$3000), #17(\$2000), #19(\$200), #25(4X\$200), #28(4X5000), #31(2X\$200), #32(\$200), #33(\$500), #39(\$2000),#40(\$2000),#53(\$200), #54(2X\$200), #55(2X\$200), #69(\$400)	\$48,300
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------

Add signs, and place so that they are not obstructed by cars.	\$800
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$1,000
Other - Implement a plan to ensure that the accessible surface around the play components is swept clean of the sand throughout the day.	\$75,000
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.	\$1,000
Other - Adjust the door closer.	\$200

<b>Facility Cost Estimate:</b>	<b>\$126,300</b>
--------------------------------	------------------

<b>PARKS - ROOSEVELT GARDENS</b>
----------------------------------

2800 NW 11TH ST	3	9	
FORT LAUDERDALE			

**Recommendations**

<b>Facility Cost Estimate:</b>	
--------------------------------	--

<b>PARKS - SECRET WOODS NATURE CENTER</b>
-------------------------------------------

2701 SR84	2	7	
DANIA BEACH			

<b>Recommendations</b> 31(\$200), #5(\$5000), #12(\$200), #26(\$100),#53(\$200), #54(\$200), #80(\$500)	\$6,400  \$400
---------------------------------------------------------------------------------------------------------	----------------------

Adjust door closer to the required 5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.

Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000
-----------------------------------------------------------------------------------------------------------------------	---------

<b>Facility Cost Estimate:</b>	<b>\$7,800</b>
--------------------------------	----------------

<b>PARKS - SNAKE WARRIOR ISLAND</b>
-------------------------------------

3600 SW 62 AVE	3	8	
MIRAMAR			

**Recommendations**



3700 TURTLE RUN BLVD  
CORAL SPRINGS

3

1

<b>Recommendations</b> #1(\$200), #17(\$2000), #60(\$5000)	\$7,200
Adjust door closer to the required 8.5 lbf. If door closer cannot be adjusted to compliance, then replace the closer with new accessible closers.	\$400
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000

<b>Facility Cost Estimate:</b>	<b>\$8,600</b>
--------------------------------	----------------

<b>PARKS - TOPEEKEEGEE PARK</b>
---------------------------------

3300 N PARK RD  
HOLLYWOOD

1

6

<b>Recommendations</b> #1(\$200), #12(\$200), #19(4X\$200), #32(2X\$200), #40(\$2000), #54(3X\$200), #55(2X\$200), #62(2X\$500), #69(\$400), #70(3X\$400), #74(\$4000),#77(\$2000)	\$13,200
Adjust height of railings. (Recommended CIP)	\$20,000
Install Directional sign.	\$0
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing. (Two new restroom bldgs. @ campground )	\$720,000
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing. (New restroom bldg. @ beach area)	\$250,000
Other - Install new accessible/compliant controls.	\$3,000
Other - Provide a pool lift that is compliant and accessible.	\$0
Other - Install a stall door that is operable inside and out with a closed fist.	\$500
Other - Install a compliant/accessible surface underneath the play area components that is firm, stable, and slip resistant.	\$75,000
Other - Install a transfer platform/ramp to the elevated play components that is accessible and compliant.	\$125,000

<b>Facility Cost Estimate:</b>	<b>\$1,206,700</b>
--------------------------------	--------------------

**PARKS - TRADEWINDS PARK**

3600 W SAMPLE RD                    1                    2  
 COCONUT CREEK

<b>Recommendations</b> #1(\$200), #3(3X\$5000), #4 (2X\$1000), #5(2X\$5000), #6(\$5000),	\$36,800
Add signs, and place so that they are not obstructed by cars.	\$800
Add signs, and place so that they are not obstructed by cars.	\$800
Provide directional signage with the International Symbol of Accessibility	\$2,000
Other - Re-stripe the parking lot making the accessible spaces at least 12	\$1,000
Other - Re-stripe the parking lot making the accessible spaces at least 12	\$1,000
Other - Re-stripe the parking lot making the accessible spaces at least 12	\$1,000
Other - Implement a plan to ensure that the accessible surface around	\$0

<b>Facility Cost Estimate:</b>	<b>\$43,400</b>
--------------------------------	-----------------

**PARKS - TREE TOPS PARK**

3900 SW 100 AVE                    1                    7  
 DAVIE

<b>Recommendations</b> #1(3X\$200), #5(\$5000), #25(\$200), #41(\$2000), #69(\$400)	\$8,200
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with an access aisle of at least 5 foot wide.	\$1,000
Other - Install a partition with a stall door opening that is at least 32" wide.	\$500
Other - Provide an alternate route to the stage (e.g., a ramp, etc.);	\$10,000
Provide railings on both sides of the stairs with extension (compliant) at	

<b>Facility Cost Estimate:</b>	<b>\$19,700</b>
--------------------------------	-----------------

**PARKS - VISTA VIEW PARK**

3601 SW 142 AVE                    1                    5  
 DAVIE

<b>Recommendations</b> #1(\$200), #5(\$5000),	\$5,400
Adjust height of railings.	\$50,000

Relocate the railings.	\$0
Add railings.	\$0
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with a 5 foot wide access aisle.	\$1,000
Other - Install new compliant and accessible controls.	\$4,000

<b>Facility Cost Estimate:</b>	<b>\$60,400</b>
--------------------------------	-----------------

<b>PARKS - WEST LAKE PARK</b>
-------------------------------

751 SHERIDAN ST HOLLYWOOD	1	6		
<b>Recommendations</b> #1(\$200), #2(\$200), #5(\$5000), #8(\$200), #9(\$200), #12(\$200), #19(\$200), #25(\$200), #54(\$200), #74(\$4000), #75(\$200)				\$10,800
Install Directional sign.				\$0
Move or remove partitions to allow for an area of at least 5 feet by 5 feet or 48 inches by 69 inches, clear of the door swing. (Recommended for				\$90,000
Provide an auxiliary table near the main counter.				\$2,000
				\$200
Other - Place a planter or other cane-detectable barrier on each side at flo				
Other - Re-stripe the parking lot making the accessible spaces at least 12 feet wide with access aisle that are at least 5 feet wide.				\$1,000
Other - Install compliant/accessible handrails and extensions (at the top and bottom) on both sides.				\$2,000

<b>Facility Cost Estimate:</b>	<b>\$106,000</b>
--------------------------------	------------------

<b>PARKS - WOODMONT PINELAND</b>
----------------------------------

7250 NW 80 AVENUE TAMARAC	3	3		
<b>Recommendations</b> #1(\$200), #2(\$200)				\$400

<b>Facility Cost Estimate:</b>	<b>\$400</b>
--------------------------------	--------------

	<b>Submitted Contingency:</b>	<b>\$200,000</b>
--	-------------------------------	------------------

---

<b>Parks &amp; Recreation Cost Estimate</b>	<b>\$4,521,000</b>
---------------------------------------------	--------------------

---

## Operational Cost Estimates

NOTE: This document contains the estimated costs associated with the operational recommendations to address barriers to accessibility. Operational recommendations are defined as adjustments and/or modifications which can be implemented at the Program/Agency level by moving/rearranging furnishings, implementing a procedure, ect. These recommendations must be completed within one year of receipt of

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
<b>COMMUNITY SERVICES</b>						
18	ANIMAL CARE & REGULATION	ANIMAL CARE AND REGULATION - NORTH	\$0		12/29/2006	Yes
19	ANIMAL CARE & REGULATION	ANIMAL CARE AND REGULATION - SOUTH	\$0		10/20/2006	Yes
20	ADMINISTRATION	GOVERNMENTAL CENTER EAST	\$100		1/31/2007	Yes
21	CONSUMER AFFAIRS	GOVERNMENTAL CENTER ANNEX	\$0		1/15/2007	Yes
22	CULTURAL DIVISION	LIBRARY - MAIN	\$0		10/1/2006	Yes
23	EXTENSION EDUCATION	EXTENSION EDUCATION SERVICE	\$0		10/19/2006	Yes
24	LIBRARIES	LIBRARY - AFRICAN AMERICAN RESEARCH	\$800		3/30/2007	Yes
25	LIBRARIES	LIBRARY - ALVIN SHERMAN Note: This was rejected because the library is owned and operated by Nova Southeastern University. The county provides capital and operating funds, therefore have a shared responsibility to operate the facility.				No
26	LIBRARIES	LIBRARY - BEACH BRANCH	\$0		10/20/2006	Yes
27	LIBRARIES	LIBRARY - CARVER RANCHES	\$0		10/20/2006	Yes
28	LIBRARIES	LIBRARY - CENTURY PLAZA	\$2,000		6/29/2007	Yes
29	LIBRARIES	LIBRARY - COLLIER CITY	\$800		3/30/2007	Yes
30	LIBRARIES	LIBRARY - DANIA BEACH	\$9,400		3/30/2007	Yes
31	LIBRARIES	LIBRARY - DAVIE COOPER CITY	\$2,500		3/30/2007	Yes
32	LIBRARIES	LIBRARY - DEERFIELD BEACH	\$0		10/20/2006	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
33	LIBRARIES	LIBRARY - FORT LAUDERDALE BRANCH (HOLIDAY PARK)				No
		<p>Note: This was rejected because the recommendation is to move the program when the lease expires in 2008. This is a policy decision of the Board and they recently rejected staff's recommendation to close this library. It is uncertain, at this time, if the decision to close when the lease expires will be made; however, in the interim, staff has been directed to provide space for a non-profit library and expanded space for Art Serve. The library will be undergoing a renovation to accommodate this expansion, therefore, we are requesting that the ADA team provide an appropriate evaluation of the site so that any ADA recommendations can be considered during the renovation.</p>				
34	LIBRARIES	LIBRARY - GALT OCEAN MILE	\$1,500		3/30/2007	Yes
35	LIBRARIES	LIBRARY - HALLANDALE	\$0		10/20/2006	Yes
36	LIBRARIES	LIBRARY - IMPERIAL POINT	\$1,000		9/28/2007	Yes
37	LIBRARIES	LIBRARY - LAUDERDALE LAKES	\$250		6/29/2007	Yes
38	LIBRARIES	LIBRARY - LAUDERHILL	\$3,000		9/28/2007	Yes
39	LIBRARIES	LIBRARY - LAUDERHILL MALL	\$0		10/20/2006	Yes
40	LIBRARIES	LIBRARY - MAIN	\$0		10/20/2006	Yes
41	LIBRARIES	LIBRARY - MARGATE	\$800		6/29/2007	Yes
42	LIBRARIES	LIBRARY - NORTH LAUDERDALE	\$3,000		9/28/2007	Yes
43	LIBRARIES	LIBRARY - NORTH REGIONAL	\$0		10/20/2006	Yes
44	LIBRARIES	LIBRARY - NORTH WEST POMPAÑO	\$0		10/20/2006	Yes
45	LIBRARIES	LIBRARY - NORTH WEST REGIONAL	\$0		10/20/2006	Yes
46	LIBRARIES	LIBRARY - PEMBROKE PINES	\$10,000		9/28/2007	Yes
47	LIBRARIES	LIBRARY - POMPAÑO BEACH	\$0		10/20/2006	Yes
48	LIBRARIES	LIBRARY - RIVERLAND	\$0		10/20/2006	Yes
49	LIBRARIES	LIBRARY - SOUTH WEST REGIONAL	\$800		9/28/2007	Yes
50	LIBRARIES	LIBRARY - STIRLING ROAD	\$0		10/20/2006	Yes
51	LIBRARIES	LIBRARY - SUNRISE	\$1,000		9/28/2007	Yes
52	LIBRARIES	LIBRARY - SUNSET STRIP	\$2,000		9/28/2006	Yes
53	LIBRARIES	LIBRARY - TAMARAC	\$800		9/28/2006	Yes
54	LIBRARIES	LIBRARY - TYRONE BRYANT	\$0		10/20/2006	Yes
55	LIBRARIES	LIBRARY - WEST ATLANTIC	\$0		10/20/2006	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
56	LIBRARIES	LIBRARY - WEST REGIONAL				No
Note: Rejected because new West Reginal Library will be opening in 2007 and the old library torn down.						
57	LIBRARIES	LIBRARY - WESTON	\$800		9/28/2007	Yes
58	LIBRARIES	READING CENTER - HOLLYWOOD	\$0		10/20/2006	Yes
62	PARKS & RECREATION	CENTRAL DISTRICT PARKS	\$100		3/30/2007	Yes
63	PARKS & RECREATION	PARKS - BOATERS PARK	\$0		10/20/2006	Yes
64	PARKS & RECREATION	PARKS - BOULEVARD GARDENS PARK	\$0		10/20/2006	Yes
65	PARKS & RECREATION	PARKS - BRIAN PICCOLLO PARK	\$0		3/30/2007	Yes
66	PARKS & RECREATION	PARKS - CB SMITH PARK	\$500		6/29/2007	Yes
67	PARKS & RECREATION	PARKS - CRYSTAL LAKE	\$0		10/20/2007	Yes
68	PARKS & RECREATION	PARKS - DEERFIELD ISLAND PARK	\$0		12/29/2006	Yes
69	PARKS & RECREATION	PARKS - DELEVOE PARK	\$0		10/20/2006	Yes
70	PARKS & RECREATION	PARKS - EASTERLIN PARK	\$0		10/20/2006	Yes
71	PARKS & RECREATION	PARKS - FERN FOREST PARK	\$0		12/29/2006	Yes
72	PARKS & RECREATION	PARKS - FRANKLIN PARK	\$0		1/31/2007	Yes
73	PARKS & RECREATION	PARKS - HILLSBORO PINELAND PARK	\$0		10/20/2006	Yes
74	PARKS & RECREATION	PARKS - HOLLYWOOD NORTH BEACH	\$0		10/20/2006	Yes
75	PARKS & RECREATION	PARKS - LAFAYETTE HART PARK	\$0		12/29/2006	Yes
76	PARKS & RECREATION	PARKS - LEWIS CHISM PARK	\$0		10/20/2006	Yes
77	PARKS & RECREATION	PARKS - MARKHAM PARK	\$0		12/29/2006	Yes
78	PARKS & RECREATION	PARKS - MCTYRE PARK	\$0		12/29/2006	Yes
79	PARKS & RECREATION	PARKS - PLANTATION HERITAGE PARK	\$0		10/20/2006	Yes
80	PARKS & RECREATION	PARKS - QUIET WATERS PARK	\$0		10/20/2006	Yes
81	PARKS & RECREATION	PARKS - ROOSEVELT GARDENS	\$0		10/20/2006	Yes
82	PARKS & RECREATION	PARKS - SECRET WOODS NATURE	\$1,000		8/31/2007	Yes
83	PARKS & RECREATION	PARKS - SNAKE WARRIOR ISLAND	\$0		10/20/2006	Yes
84	PARKS & RECREATION	PARKS - SUN VIEW PARK	\$2,700		8/31/2007	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
85	PARKS & RECREATION	PARKS - TALL CYPRESS	\$0		10/20/2006	Yes
86	PARKS & RECREATION	PARKS - TOPEEKEEGEE PARK	\$0		12/29/2006	Yes
87	PARKS & RECREATION	PARKS - TRADEWINDS PARK	\$0		10/20/2006	Yes
88	PARKS & RECREATION	PARKS - TREE TOPS PARK	\$0		12/29/2006	Yes
89	PARKS & RECREATION	PARKS - VISTA VIEW PARK	\$0		10/20/2006	Yes
90	PARKS & RECREATION	PARKS - WEST LAKE PARK	\$0		12/29/2006	Yes
91	PARKS & RECREATION	PARKS - WOODMONT PINELAND	\$0		10/20/2006	Yes
92	PARKS & RECREATION	PARKS ADMINISTRATION BUILDING - NORTH	\$0		10/20/2006	Yes
<b>Estimated Department Totals:</b>			<b>\$44,850</b>	<b>\$0</b>		

<b>COUNTY ADMINISTRATION</b>						
93	COUNTY ADMINISTRATOR	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
94	EMERGENCY MANAGEMENT AGENCY	EMERGENCY OPERATIONS CENTER	\$0		6/29/2007	Yes
95	GREATER FORT LAUDERDALE CONVENTION AND VISITORS	CONVENTION CENTER	\$0		6/29/2007	Yes
96	GREATER FORT LAUDERDALE CONVENTION AND VISITORS	GREATER FORT LAUDERDALE CONVENTION AND VISITORS BUREAU	\$0		6/29/2007	Yes
97	OFFICE OF ECONOMIC DEVELOPMENT	GOVERNMENTAL CENTER ANNEX	\$0		1//31/2007	Yes
98	OFFICE OF ECONOMIC DEVELOPMENT	GOVERNMENTAL CENTER EAST	\$0		1//31/2007	Yes
99	OFFICE OF EQUAL OPPORTUNITY	GOVERNMENTAL CENTER ANNEX	\$0		1/31/2007	Yes
101	OFFICE OF EQUAL OPPORTUNITY	GOVERNMENTAL CENTER EAST	\$0		1/31/2007	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
100	OFFICE OF MANAGEMENT AND BUDGET	GOVERNMENTAL CENTER EAST	\$0		2/28/2007	Yes
102	OFFICE OF PUBLIC AND GOVERNMENTAL RELATION	GOVERNMENTAL CENTER EAST	\$0		2/28/2007	Yes
103	OFFICE OF PUBLIC COMMUNICATIONS	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
59	OFFICE OF TRANSPORTAION	MASS TRANSIT ADMINISTRATION				No
<p>Note: This building is not open to the public nor is the counter a workstation for employees. It is an informational booth where bus operators go to receive their work schedules and keys to buses. Therefore, it does not fall under 4.32.4 (Height of Work Surfaces) of the Uniform Federal Accessibility Standards or 4.32.4 (Height of Tables or Counters) of the ADA Accessibility Guidelines.</p>						
60	OFFICE OF TRANSPORTAION	MASS TRANSIT MAIN TERMINAL	\$25,000		9/28/2007	Yes
61	OFFICE OF TRANSPORTAION	MASS TRANSIT TRANSFER FACILITY	\$0		10/20/2006	Yes
<b>Estimated Department Totals:</b>			<b>\$25,000</b>	<b>\$0</b>		

**COUNTY COMMISSION**

104	COUNTY ATTORNEY	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
106	COUNTY AUDITOR	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
107	COUNTY COMMISSION (BOARD MEMBERS)	GOVERNMENTAL CENTER EAST	\$0		10/25/2007	Yes
108	HISTORICAL COMMISSION	HISTORICAL COMMISSION	\$0		6/29/2007	Yes
<b>Estimated Department Totals:</b>			<b>\$0</b>	<b>\$0</b>		

**ENVIRONMENTAL PROTECTION**

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
109	AIR QUALITY	ENVIRONMENTAL MONITORING FACILITY	\$0		10/25/2006	Yes
110	AIR QUALITY	GOVERNMENTAL CENTER WEST	\$0		10/25/2006	Yes
111	BIOLOGICAL RESOURCES	GOVERNMENTAL CENTER WEST	\$0		10/25/2006	Yes
112	ENVIRONMENTAL MONITORING	ENVIRONMENTAL MONITORING FACILITY	\$0		10/25/2006	Yes
113	ENVIRONMENTAL PROTECTION ADMIN	GOVERNMENTAL CENTER WEST	\$0		10/25/2006	Yes
114	POLLUTION PREVENT.& REMEDIATION	GOVERNMENTAL CENTER WEST	\$0		10/25/2006	Yes
115	WATER RESOURCES	GOVERNMENTAL CENTER WEST	\$0		10/25/2006	Yes
<b>Estimated Department Totals:</b>			<b>\$0</b>	<b>\$0</b>		

#### **FINANCE AND ADMINISTRATIVE SERVICES**

116	ACCOUNTING	GOVERNMENTAL CENTER EAST				
117	COUNTY RECORDS	GOVERNMENTAL CENTER EAST				
118	COUNTY RECORDS	NORTH REGIONAL COURTHOUSE				
119	FINANCE AND ADMINISTRATIVE SERVICES - ADMIN	GOVERNMENTAL CENTER EAST				
120	HUMAN RESOURCES	EMPLOYMENT ASSISTANCE PROGRAM (HUMAN RESOURCES)				
121	HUMAN RESOURCES	GOVERNMENTAL CENTER EAST				
122	HUMAN RESOURCES	PERSONNEL - ANNEX B				
123	OFFICE OF INFORMATION	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
124	PURCHASING	GOVERNMENTAL CENTER EAST				
125	PURCHASING	NORTH REGIONAL COURTHOUSE				
126	REVENUE COLLECTIONS	GOVERNMENTAL CENTER ANNEX				
127	REVENUE COLLECTIONS	GOVERNMENTAL CENTER EAST				
128	REVENUE COLLECTIONS	SOUTH REGIONAL COURTHOUSE				
129	REVENUE COLLECTIONS	TAG AGENCY				
130	REVENUE COLLECTIONS	WEST REGIONAL COURTHOUSE				

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
131	RISK MANAGEMENT	GOVERNMENTAL CENTER ANNEX				
132	RISK MANAGEMENT	GOVERNMENTAL CENTER EAST				
133	SUPPORT ENFORCEMENT	MIDRISE OFFICE				
<b>Estimated Department Totals:</b>			<b>\$0</b>	<b>\$0</b>		

### HUMAN SERVICES

134	CHILDREN'S SERVICES ADMINISTRATION	FAMILY SUCCESS ADMINISTRATION DIVISION		\$0	9/30/2008	Yes
135	CHILDREN'S SERVICES ADMINISTRATION	GOVERNMENTAL CENTER ANNEX		\$3,500	9/30/2008	Yes
136	CHILDREN'S SERVICES ADMINISTRATION	OUR HOUSE		\$3,000	9/30/2008	Yes
137	CHILDREN'S SERVICES ADMINISTRATION	SEXUAL ASSAULT CENTER		\$6,000	9/30/2008	Yes
138	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	CENTRAL HOMELESS SHELTER	\$0		12/14/2006	Yes
139	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	FORT LAUDERDALE HEALTH CENTER		\$5,000	9/30/2008	Yes
140	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	FORT LAUDERDALE SATELLITE CENTER (HUMAN SERVICES)	\$0		12/14/2006	Yes
141	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	NORTH REGIONAL HEALTH CENTER (HUGHES BUILDING)	\$0		12/14/2008	Yes
142	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	NORTH REGIONAL HEALTH CENTER (HUNTER BUILDING)		\$5,000	9/30/2008	Yes
143	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	NORTH WEST HEALTH CENTER AIDS CLINIC	\$0		12/16/2006	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
144	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	SOUTH BROWARD FIELD OFFICE	\$0		12/14/2006	Yes
145	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES	SOUTH REGIONAL HEALTH CENTER	\$100		1/30/2007	Yes
146	ELDERLY & VETERANS SERVICES	FAMILY SUCCESS ADMINISTRATION		\$4,000	9/30/2008	Yes
147	ELDERLY & VETERANS SERVICES	NORTH REGIONAL COURTHOUSE		\$1,000	9/30/2008	Yes
148	ELDERLY & VETERANS SERVICES	SOUTH REGIONAL COURTHOUSE		\$2,000	9/30/2008	Yes
149	FAMILY SUCCESS ADMINISTRATION	FAMILY SUCCESS ADMINISTRATION				
150	FAMILY SUCCESS ADMINISTRATION	NORTH FAMILY SUCCESS CENTER	\$0		12/29/2006	Yes
151	FAMILY SUCCESS ADMINISTRATION	NORTH WEST FAMILY SUCCESS CENTER	\$0		11/30/2006	Yes
152	FAMILY SUCCESS ADMINISTRATION	SOUTH FAMILY SUCCESS CENTER	\$0		11/13/2006	Yes
153	HOMELESS INITIATIVE PARTNERSHIP	CENTRAL HOMELESS SHELTER	\$100		1/31/2007	Yes
154	HOMELESS INITIATIVE PARTNERSHIP	GOVERNMENTAL CENTER EAST	\$100		1/31/2007	Yes
155	HOMELESS INITIATIVE PARTNERSHIP	NORTH HOMELESS ASSISTANCE CENTER	\$100		1/31/2007	Yes
156	MEDICAL EXAMINER TRAUMA PROGRAM DEVELOPMENT RESEARCH & EVALUATION	MEDICAL EXAMINER GOVERNMENTAL CENTER ANNEX	\$4,000		9/1/2008	Yes
158	SUBSTANCE ABUSE & HEALTH CARE SERVICE	BROWARD ADDICTION RECOVERY CENTER - BOOHER BUILDING	\$250		1/31/2007	Yes
159	SUBSTANCE ABUSE & HEALTH CARE SERVICE	BROWARD ADDICTION RECOVERY CENTER - CENTRAL			9/30/2008	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
160	SUBSTANCE ABUSE & HEALTH CARE SERVICE	BROWARD ADDICTION RECOVERY CENTER - DAVIE		\$10,000	9/30/2008	Yes
161	SUBSTANCE ABUSE & HEALTH CARE SERVICE	BROWARD ADDICTION RECOVERY CENTER - SOUTH	\$50		1/30/2007	Yes
162	SUBSTANCE ABUSE & HEALTH CARE SERVICE	CASE MANAGEMENT SERVICES (HUMAN SERVICES)	\$0		12/13/2006	Yes
163	SUBSTANCE ABUSE & HEALTH CARE SERVICE	GOVERNMENTAL CENTER EAST		\$10,000	9/30/2008	Yes
164	SUBSTANCE ABUSE & HEALTH CARE SERVICE	MENTAL HEALTH		\$5,000	9/30/2008	Yes
165	SUBSTANCE ABUSE & HEALTH CARE SERVICE	NORTH REGIONAL HEALTH CENTER (HUGHES BUILDING)		\$5,000	9/30/2008	Yes
<b>Estimated Department Totals:</b>			<b>\$4,700</b>	<b>\$59,500</b>		

<b>OTHER GOVERNMENT ENTITIES</b>						
166	LEGISLATIVE DELEGATION	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
167	PLANNING COUNCIL	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
168	VINNETTE CAROL THEATER	VINNETTE CAROL THEATER				
<b>Estimated Department Totals:</b>			<b>\$0</b>	<b>\$0</b>		

<b>PORT EVERGLADES</b>						
	PORT EVERGLADES	PORT EVERGLADES - PUBLIC SAFETY	\$0		6/29/2007	Yes
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 611				
	PORT EVERGLADES	PORT EVERGLADES - MIDPORT				
	PORT EVERGLADES	PORT EVERGLADES - NORTHPORT				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 26	\$0		6/29/2007	Yes
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 29				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 4	\$0		6/29/2007	Yes
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 22	\$0		6/29/2007	Yes

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 24				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 25				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 19				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 2	\$0		6/29/2007	Yes
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 21	\$0		6/29/2007	Yes
	PORT EVERGLADES	PORT EVERGLADES -				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 1				
	PORT EVERGLADES	PORT EVERGLADES - BUILDING 18	\$0		6/29/2007	Yes
<b>Estimated Department Totals:</b>			<b>\$0</b>	<b>\$0</b>		

<b>PUBLIC WORKS &amp; TRANSPORTATION</b>						
------------------------------------------	--	--	--	--	--	--

190	CONSTRUCTION MANAGEMENT	GOVERNMENTAL CENTER ANNEX	\$0		6/29/2007	Yes
191	FACILITIES MANAGEMENT ADMINISTRATION	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
192	FACILITIES MANAGEMENT MAINTENANCE	JUVENILE ASSESSMENT CENTER				
193	FACILITIES MANAGEMENT OPERATIONS	GOVERNMENTAL CENTER EAST	\$0		6/29/2007	Yes
216	FACILITIES MANAGEMENT OPERATIONS	GOVERNMENTAL CENTER ANNEX				
217	FACILITIES MANAGEMENT OPERATIONS	GOVERNMENTAL CENTER WEST	\$0		6/29/2007	Yes
194	FLEET SERVICES	GOVERNMENTAL CENTER EAST				
195	GENERAL SERVICES	GOVERNMENTAL CENTER EAST				
196	HIGHWAY CONST. &	GOVERNMENTAL CENTER WEST		\$200	3/1/2007	Yes
197	HIGHWAY CONST. & ENGINEERING	WATER AND WASTE WATER SERVICES ENGINEERING DIVISION				
198	PROJECT MANAGEMENT AND CONSTRUCTION	GOVERNMENTAL CENTER ANNEX				
199	PUBLIC WORKS ADMINISTRATION	GOVERNMENTAL CENTER WEST				

#	Program/Agency	Facility	Capital Budget Approved	Estimated Capital Budget Request	Target Completion Date	Department Accepted Recommendations
200	REAL PROPERTY - PUBLIC	GOVERNMENTAL CENTER EAST		\$0	6/29/2007	Yes
201	SEAPORT CONST. & PLANNING	PORT EVERGLADES - ADMINISTRATION				
202	TRAFFIC ENGINEERING	TRAFFIC ENGINEERING BUILDING				
203	WASTE & RECYCLING SERVICES	GOVERNMENTAL CENTER WEST		\$0	6/29/2007	Yes
204	WATER & WASTEWATER SERVICES	WATER AND WASTE WATER SERVICES				No
Note: No operational recommendations to accept; rejected non-structural recommendations.						
205	WATER & WASTEWATER SERVICES	WATER AND WASTE WATER SERVICES ENGINEERING DIVISION		\$1,000	6/29/2007	Yes
<b>Estimated Department Totals:</b>			<b>\$1,000</b>	<b>\$200</b>		

<b>URBAN PLANNING &amp; REDEVELOPMENT</b>						
211	BUILDING CODE SERVICES	BUILDING CODE SERVICES				
212	PERMIT AND LICENSING	GOVERNMENTAL CENTER ANNEX				
213	HOUSING AND COMMUNITY DEVELOPMENT	HOUSING AND COMMUNITY DEVELOPMENT				
214	TRANSPORTATION PLANNING	GOVERNMENTAL CENTER EAST				
215	URBAN PLANNING AND REDEVELOPMENT ADMIN	GOVERNMENTAL CENTER EAST		\$0	6/29/2007	Yes
<b>Estimated Department Totals:</b>			<b>\$0</b>	<b>\$0</b>		

**Summary Totals**

<b>Final Estimated Total</b>	<b>\$75,550</b>	<b>\$59,700</b>
<b>Total Funds Available</b>	<b>\$75,550</b>	

**Total Estimated Amount that Needs to be Requested** **\$59,700**

## Operational Recommendations

#	Program/Agency	Location	Question	Barrier	Recommendation
<b>COMMUNITY SERVICES</b>					
18	ANIMAL CARE & REGULATION ANIMAL CARE AND REGULATION - NORTH	The phone	If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one?	Pay phone does not have the required clear floor space.	Move furnishings and other obstructions.
		Interior rooms and spaces	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
19	ANIMAL CARE & REGULATION ANIMAL CARE AND REGULATION - SOUTH	Stray cats' room	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		Stray cats room	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		The reach and play areas	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
20	ADMINISTRATION GOVERNMENTAL CENTER EAST				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Room 427 Community Services	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
21	CONSUMER AFFAIRS GOVERNMENTAL CENTER ANNEX	Assistant Supervisor's Office  Consumer Relations Analyst office #1.   Consumer Relations Analyst office #2.   Consumer Relations Analyst office #3.   Consumer Relations Analyst office #3.   Conference Room	Is the accessible route to all public spaces at least 36 inches wide?  Is the accessible route to all public spaces at least 36 inches wide?   Is the accessible route to all public spaces at least 36 inches wide?   Are all the aisles and pathways to materials and services at least 36 inches wide?   Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.  Furnishings, partitions, or other obstructions interfere with clear wall space.   Furnishings, partitions, or other obstructions interfere with clear wall space.   Aisles and pathways to materials and services are not 36 inches wide.   Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.  Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.   Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.   Rearrange furnishings and fixtures to clear aisles.   Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Conference Room.	If provided, do signs and room numbers designating permanent rooms and spaces where services are provided comply with the following signage requirements?• Signs mounted with centerline 60 inches from floor.• Mounted on wall adjacent to latch side of door, or as close as possible.• Raised characters, sized between 5/8 and 2 inches high, with high contrast ( for room numbers, rest rooms, exits)• Braille text of the same information.• If pictogram is used, it must be accompanied by raised characters and Braille	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
21	CONSUMER AFFAIRS GOVERNMENTAL CENTER ANNEX	Supervisor's Office.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
23	EXTENSION EDUCATION EXTENSION EDUCATION SERVICE	Soda machine	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Unisex Restroom	Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? (A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)	Restroom door entry configuration does not provide adequate maneuvering space for a person using a wheelchair.	Rearrange furnishings such as chairs and trash cans.
		Conference Room #1	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Kitchen Door	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Hallway by Unisex Restroom (empty public phone box)	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.

#	Program/Agency	Location	Question	Barrier	Recommendation
	LIBRARY - AFRICAN AMERICAN RESEARCH	CD rack	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
25	LIBRARIES LIBRARY - ALVIN SHERMAN	Elevators, all floors.  ATM machine, 1st floor in hallway by Connections Cafe.	Are the call buttons in the hallway no higher than 42 inches  In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Furnishings, partitions, or other obstructions interfere with clear wall space.  Obstacles are not cane detectable.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.  Install furnishings, planters , or other cane detectable barriers underneath.
28	LIBRARIES LIBRARY - CENTURY PLAZA				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Book return along entrance by sidewalk.	Can all objects protruding into the circulation paths be detected by a person with a visual disability using a cane? In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 80 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
		Book aisles along wall.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		CD-rack	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
29	LIBRARIES LIBRARY - COLLIER CITY	CD rack-library interior.	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.

#	Program/Agency	Location	Question	Barrier	Recommendation
29	LIBRARIES LIBRARY - COLLIER CITY	Book display holders at the end of book stacks.	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
30	LIBRARIES LIBRARY - DANIA BEACH	Aisle to Tutor room reduced by security station.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Aisles between book stacks contain unattended carts	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Computer lab entrance	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		CD rack in front area	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
31	LIBRARIES LIBRARY - DAVIE COOPER CITY				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Water fountain near front entrance.	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.
		First book aisle	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Fire Extinguisher by Community Room	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
33	LIBRARIES LIBRARY - FORT LAUDERDALE BRANCH (HOLIDAY PARK)	Study carrels on main floor area.	Are knee spaces at accessible tables at least 27 inches high, 30 inches wide, and 19 inches deep?	Space for wheelchair seating has not been provided.	Rearrange tables to allow room for wheelchairs in seating areas throughout the area.
33	LIBRARIES LIBRARY - FORT LAUDERDALE BRANCH (HOLIDAY PARK)	Water fountain in lobby next to auditorium	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.
34	LIBRARIES LIBRARY - GALT OCEAN MILE				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Sidewalk to entrance	Can all objects protruding into the circulation paths be detected by a person with a visual disability using a cane? In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 80 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.	Obstacles are not cane detectable.	Install furnishings, planters, or other cane detectable barriers underneath.
36	LIBRARIES LIBRARY - IMPERIAL POINT	Front lobby to book stacks	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Front door control box	Can all objects protruding into the circulation paths be detected by a person with a visual disability using a cane? In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 80 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
37	LIBRARIES LIBRARY - LAUDERDALE LAKES	Fire extinguisher in book stack aisles.	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
	LIBRARIES LIBRARY - LAUDERHILL				

#	Program/Agency	Location	Question	Barrier	Recommendation
38		Exterior book drop-off.	Can all objects protruding into the circulation paths be detected by a person with a visual disability using a cane? In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 80 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
41	LIBRARIES LIBRARY - MARGATE	CD rack on main library floor	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
42	LIBRARIES LIBRARY - NORTH LAUDERDALE	Interior book return	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
46	LIBRARIES				

#	Program/Agency	Location	Question	Barrier	Recommendation
	LIBRARY - PEMBROKE PINES	Book stacks	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
46	LIBRARIES LIBRARY - PEMBROKE PINES	The water fountain	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.
47	LIBRARIES LIBRARY - POMPANO BEACH	Thermostat in hallway to Auditorium	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
47	LIBRARIES LIBRARY - POMPANO BEACH	Business Service Room	Are public spaces on an accessible route of travel?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		Book stacks	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
49	LIBRARIES LIBRARY - SOUTH WEST REGIONAL				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Book display holders on shelves, CD-racks	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
51	LIBRARIES LIBRARY - SUNRISE	Pay phone in front lobby of building	If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one?	Pay phone does not have the required clear floor space.	Move furnishings and other obstructions.
52	LIBRARIES LIBRARY - SUNSET STRIP	Areas between book stacks by restrooms	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Water fountain inside library.	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.
53	LIBRARIES LIBRARY - TAMARAC	CD-rack in library lobby.	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.

#	Program/Agency	Location	Question	Barrier	Recommendation
56	LIBRARIES LIBRARY - WEST REGIONAL	CD-racks	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
		Reference stacks	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
57	LIBRARIES LIBRARY - WESTON	CD-rack, book display holders	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
		Between the study tables and carrels	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
62	PARKS & RECREATION CENTRAL DISTRICT PARKS	The door leading to the back offices and conference room	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		The conference room	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		In the hallway leading to the restrooms	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		The restrooms	Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? (A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)	Restroom door entry configuration does not provide adequate maneuvering space for a person using a wheelchair.	Rearrange furnishings such as chairs and trash cans.
65	PARKS & RECREATION PARKS - BRIAN PICCOLLO PARK	Piccolo Baseball checkout counter	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
66	PARKS & RECREATION PARKS - CB SMITH PARK	The CB Smith Park Concession	Are there ramps, lifts, or elevators to all public levels?	There is not direct access to all public levels.	Relocate the services to an accessible area upon request. Patrons must be informed of this policy.
68	PARKS & RECREATION PARKS - DEERFIELD ISLAND PARK				

#	Program/Agency	Location	Question	Barrier	Recommendation
		The office	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		The office	Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
70	PARKS & RECREATION PARKS - EASTERLIN PARK	The office counters	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
71	PARKS & RECREATION PARKS - FERN FOREST PARK	The tables at the entrance to the shelter	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
72	PARKS & RECREATION PARKS - FRANKLIN PARK	The game room	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		The weight room	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
75	PARKS & RECREATION PARKS - LAFAYETTE HART PARK	The weight room	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		In front of the recreation center's restrooms	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
77	PARKS & RECREATION PARKS - MARKHAM PARK	The public phone at the skeet range	If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one?	Pay phone does not have the required clear floor space.	Move furnishings and other obstructions.
78	PARKS & RECREATION PARKS - MCTYRE PARK				

#	Program/Agency	Location	Question	Barrier	Recommendation
		The restrooms' garbage cans	Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? (A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)	Restroom door entry configuration does not provide adequate maneuvering space for a person using a wheelchair.	Rearrange furnishings such as chairs and trash cans.
79	PARKS & RECREATION PARKS - PLANTATION HERITAGE PARK	The fountain	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.
		The boat/bike rental counter	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
80	PARKS & RECREATION PARKS - QUIET WATERS PARK	the Quiet Waters Lifeguard Office	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		the Quiet Waters Lifeguard Office	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
82	PARKS & RECREATION PARKS - SECRET WOODS NATURE CENTER				

#	Program/Agency	Location	Question	Barrier	Recommendation
84	PARKS & RECREATION PARKS - SUN VIEW PARK	The interior seating for lectures	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles between fixed seating are not at least 36 inches wide.	Rearrange chairs or tables to provide 36 inch isles.
86	PARKS & RECREATION PARKS - TOPEEKEEGEE PARK	The water fountain in the office/recreation center	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.
88	PARKS & RECREATION PARKS - TREE TOPS PARK	Topeegeekeegee Park Administration - southwest areas, located next to pavilion 3	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
90	PARKS & RECREATION PARKS - WEST LAKE PARK	Tree Tops Administration restrooms	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		The picnic tables at the shelter	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

<b>COUNTY ADMINISTRATION</b>
------------------------------

93	COUNTY ADMINISTRATOR GOVERNMENTAL CENTER EAST	Reception area, Room 409H - conference room, Room 409F - County Administrator's Office	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Reception area, Room 409H - conference room, Room 409F - County Administrator's Office	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Receptio counter	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
97	OFFICE OF ECONOMIC DEVELOPMENT GOVERNMENTAL CENTER ANNEX				

#	Program/Agency	Location	Question	Barrier	Recommendation
98	OFFICE OF ECONOMIC DEVELOPMENT GOVERNMENTAL CENTER EAST	Entrance door to open area - Room 540A.	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Passage aisles to offices.	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Offices #1-4	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Exit door.	Can the alternate accessible entrance be used independently?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
98	OFFICE OF ECONOMIC DEVELOPMENT GOVERNMENTAL CENTER EAST	Real Property/Land Acquisition.	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Office of Economic Development.	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
99	OFFICE OF EQUAL OPPORTUNITY GOVERNMENTAL CENTER ANNEX	Conference Rooms: A680 & A640	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
99	OFFICE OF EQUAL OPPORTUNITY GOVERNMENTAL CENTER EAST				

#	Program/Agency	Location	Question	Barrier	Recommendation
		The pathway from the waiting areas to the receptionist and services	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
100	OFFICE OF MANAGEMENT AND BUDGET GOVERNMENTAL CENTER EAST	Room 404.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
102	OFFICE OF PUBLIC AND GOVERNMENTAL RELATION GOVERNMENTAL CENTER EAST	Room 406	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
103	OFFICE PUBLIC COMMUNICATIONS GOVERNMENTAL CENTER EAST	Public Communications - room 516 reception counter	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
59	OFFICE OF TRANSPORTATION MASS TRANSIT ADMINISTRATION	Public Communications - room 516	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Near the elevator Operations building 3	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
60	OFFICE OF TRANSPORTATION MASS TRANSIT MAIN TERMINAL	Bus Drop-off area ( Vertical sign protrudes in circulation path).	Can all objects protruding into the circulation paths be detected by a person with a visual disability using a cane?In order to be detected using a cane, an object must be within 27 inches of the ground. Objects hanging or mounted overhead must be higher than 80 inches to provide clear head room. It is not necessary to remove objects that protrude less than 4 inches from the wall.	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
		Ticketing Counter	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
		Ticketing Counter	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.

#	Program/Agency	Location	Question	Barrier	Recommendation
---	----------------	----------	----------	---------	----------------

		Telephone	Is the location of the text telephone identified by accessible signage bearing the international TTY Symbol?	TTY has not been provided.	Install a TTY.
--	--	-----------	--------------------------------------------------------------------------------------------------------------	----------------------------	----------------

<b>COUNTY COMMISSION</b>					
--------------------------	--	--	--	--	--

106	COUNTY AUDITOR GOVERNMENTAL CENTER EAST	County Auditor room 520 receptionist counter	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
107	COUNTY COMMISSION (BOARD MEMBERS) GOVERNMENTAL CENTER EAST	Room 416,414, 412, 410, and 437C	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
	Commissioners Administration Offices		Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		Room 416, Room 414, Room 412, Room 410, Room 437C	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.

#	Program/Agency	Location	Question	Barrier	Recommendation
		County Administration Offices counter	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
108	HISTORICAL COMMISSION HISTORICAL COMMISSION	Room 422 Commissioners' chambers	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		Room 422 Commissioners' chambers	Are the aisles between fixed seating at least 36 inches wide?	Aisles between fixed seating are not at least 36 inches wide.	Rearrange chairs or tables to provide 36 inch isles.
		Restrooms: Men's & Women's	Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? (A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)	Restroom door entry configuration does not provide adequate maneuvering space for a person using a wheelchair.	Rearrange furnishings such as chairs and trash cans.

**ENVIRONMENTAL PROTECTION**

#	Program/Agency	Location	Question	Barrier	Recommendation
---	----------------	----------	----------	---------	----------------

112	ENVIRONMENTAL MONITORING ENVIRONMENTAL MONITORING FACILITY	Trailer 3 - Women room entrance area.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
-----	---------------------------------------------------------------	---------------------------------------------	------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------	-------------------------------------

<b>FINANCE AND ADMINISTRATIVE SERVICES</b>					
--------------------------------------------	--	--	--	--	--

117	COUNTY RECORDS GOVERNMENTAL CENTER EAST	County Records Value Adjustment - Area by the information desk	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
	Room 119 Public Records	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?		Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
	Rooms 200 A and B Valua Adjustment Board Hearing	Are all the aisles and pathways to materials and services at least 36 inches wide?		Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
	County Records Value Adjustment	Is the accessible route to all public spaces at least 36 inches wide?		Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.

119	FINANCE AND ADMINISTRATIVE SERVICES - ADMIN GOVERNMENTAL CENTER EAST				
-----	-------------------------------------------------------------------------	--	--	--	--

#	Program/Agency	Location	Question	Barrier	Recommendation
		The door to the Administrator's Office, door to Director's CFO office the service counters	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
120	HUMAN RESOURCES EMPLOYMENT ASSISTANCE PROGRAM (HUMAN RESOURCES)	The offices:	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
121	HUMAN RESOURCES GOVERNMENTAL CENTER EAST	Finance and Administrative Services Gov. Center East Human Resources room 509	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
123	OFFICE OF INFORMATION TECHNOLOGY GOVERNMENTAL CENTER EAST	Room #325	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Room #325	Does the Door have at least 32 inches clear opening?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Room #325	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Room #325	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
124	PURCHASING GOVERNMENTAL CENTER EAST	Agents' cubicles (1st, 2nd, 4th, 5th, 6th, and 7th cubicles)	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
	Purchasing Division Room 212 (staff)		Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.

#	Program/Agency	Location	Question	Barrier	Recommendation
		the door to the conference room	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Supervisor's Office	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		the service counter encroaches into the pathway to the conference room Purchasing Division	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
125	PURCHASING NORTH REGIONAL COURTHOUSE	Broward County Surplus Warehouse Purchasing Division	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
126	REVENUE COLLECTIONS GOVERNMENTAL CENTER ANNEX	Conference room.	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Supervisor's Office.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Supervisor's Office.	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Assistan't Office.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Assistant's Office.	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
128	REVENUE COLLECTIONS SOUTH REGIONAL COURTHOUSE	West door-west side	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
130	REVENUE COLLECTIONS WEST REGIONAL COURTHOUSE	Sanction Rope Lanes	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
131	RISK MANAGEMENT GOVERNMENTAL CENTER ANNEX	Entrance - A510.	Does the entrance door have at least 32 inches clear opening? (for a double door, at least one 32-inch leaf)	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.

#	Program/Agency	Location	Question	Barrier	Recommendation
132	RISK MANAGEMENT GOVERNMENTAL CENTER EAST	Manager's office- Room A510.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Governmental Center East- Risk Management Room 210	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Governmental Center East- Risk Management Room 210	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
133	SUPPORT ENFORCEMENT MIDRISE OFFICE	Governmental Center East Risk Management Room 210	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room and spaces - Support enforcement.	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
<b>HUMAN SERVICES</b>					

135 CHILDREN'S SERVICES ADMINISTRATION

#	Program/Agency	Location	Question	Barrier	Recommendation
	GOVERNMENTAL CENTER ANNEX	Main Entrance door- Room A360	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room A360	Are the aisles between fixed seating at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room B360	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room C360	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room D360	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room D360.	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Cubicle Office.	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
136	CHILDREN'S SERVICES ADMINISTRATION OUR HOUSE	Throughout the entire facility:	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
136	CHILDREN'S SERVICES ADMINISTRATION OUR HOUSE				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Throughout the entire facility:	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
137	CHILDREN'S SERVICES ADMINISTRATION SEXUAL ASSAULT CENTER	Rooms and spaces.	Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
137	CHILDREN'S SERVICES ADMINISTRATION SEXUAL ASSAULT CENTER	Rooms and Spaces	Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
139	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES FORT LAUDERDALE HEALTH CENTER	2nd floor Environmental Engineering room.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
142	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES NORTH REGIONAL HEALTH CENTER (HUNTER BUILDING)	1st and 2nd floor	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.

#	Program/Agency	Location	Question	Barrier	Recommendation
		The pay phone on the 1st floor.	If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one?	Pay phone does not have the required clear floor space.	Move furnishings and other obstructions.
		2nd floor waiting room #2.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		1st floor WIC services counseling rooms, 2nd floor waiting room #2, 2nd floor pediatric clinic exam rooms, 2nd floor Children's Dental Clinic.	Is the accessible route to all public spaces at least 36 inches wide?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
145	DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES SOUTH REGIONAL HEALTH CENTER	South Regional Health Center	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
147	ELDERLY & VETERANS SERVICES NORTH REGIONAL COURTHOUSE				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Elderly and Veteran Services Division - 2nd level (north entrance door, reception area north entrance door to office, staff offices, Office Veterans Service Officer II, Conference room	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
148	ELDERLY & VETERANS SERVICES SOUTH REGIONAL COURTHOUSE	Veteran Service Office II-South wall east side door  Information pamphlet bookcase in waiting area. Veteran Service Office II South wall east side door	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?  Are all the aisles and pathways to materials and services at least 36 inches wide?  Do doors into public spaces have at least a 32-inch clear opening?	Furnishings, partitions, or other obstructions interfere with clear wall space.  Aisles and pathways to materials and services are not 36 inches wide.  Door does not have a least a 32 inch clear opening.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.  Rearrange furnishings and fixtures to clear aisles.  Meet clients in an accessible office or conference room.

#	Program/Agency	Location	Question	Barrier	Recommendation
	Veteran Service Office II-West	wall door	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
	Veteran Service Office II- West	wall door	Do doors into public spaces have at least a 32-inch clear opening?	Door does not have a least a 32 inch clear opening.	Meet clients in an accessible office or conference room.
	Veteran Service Office II- Hall	Door	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
	Veterans Service Office II- Hall	door	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
	Veteran Service Office I- Northwest corner		On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
	Veteran Service Office I Northwest corner		Do doors into public spaces have at least a 32-inch clear opening?	Door does not have a least a 32 inch clear opening.	Meet clients in an accessible office or conference room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Veteran Service Office I Southwest corner	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Veteran Service Office I- Southwest corner	Do doors into public spaces have at least a 32-inch clear opening?	Door does not have a least a 32 inch clear opening.	Meet clients in an accessible office or conference room.
		Service Counter window in lobby.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Reception area to offices corridor	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Reception area to offices corridor.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
149	FAMILY SUCCESS ADMINISTRATION FAMILY SUCCESS ADMINISTRATION DIVISION	Entrance.	Is the route at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Conference room (north door to corridor).	Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? (A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		The counters at Elderly Services, Childcare Licensing lobby, Childcare registration, secretary/Reception counters.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Interior door to Day program.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Pathway to elderly services and hearing room.	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
150	FAMILY SUCCESS ADMINISTRATION NORTH FAMILY SUCCESS CENTER	Social Services.	Is the accessible route to all public spaces at least 36 inches wide?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
150	FAMILY SUCCESS ADMINISTRATION NORTH FAMILY SUCCESS CENTER	Social services.	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
153	HOMELESS INITIATIVE PARTNERSHIP CENTRAL HOMELESS SHELTER	2nd floor Women's Dormitory.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		2nd Floor Administration, 2nd Floor Family Dormitory, 2nd Floor Screening Area, 2nd Floor Behavior Healthcare Services Room 341, 2nd Floor Women's Dormitory Room 344, 2nd Floor Men's Dormitory 1 & 2 Rooms 358 & 366.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		2nd Floor Case Management, 2nd Floor Behavior Healthcare Services Room 341.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
154	HOMELESS INITIATIVE PARTNERSHIP GOVERNMENTAL CENTER EAST	Room 516 Homeless Initiative Partnership	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
154	HOMELESS INITIATIVE PARTNERSHIP GOVERNMENTAL CENTER EAST				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Room 516 Homeless Initiative Partnership boxes blocking pathway to offices	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
155	HOMELESS INITIATIVE PARTNERSHIP NORTH HOMELESS ASSISTANCE CENTER	South side of the facility restrooms.	Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, or is there a stall that is less accessible but that provides greater access than a typical stall (either 36 by 69 inches or 48 by 69 inches)?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
		Aisles and pathways at St. Laurence intake administrator's office, case management, the classrooms and client services.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Aisles and pathways at St. Laurence Intake administrator's office, case management, classrooms and client services.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
		Aisles and pathways at St. Laurence intake administrator's office, social worker volunteer room and case management.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
157	PROGRAM DEVLOP.,RESEARCH & EVAL. GOVERNMENTAL CENTER ANNEX	Vestibule entrance door Room 300-B Room 300-C Room 300-D Room-E	Is there at least 18 inches of clear wall space on the pull side of the door, next to the handle? Are all the aisles and pathways to materials and services at least 36 inches wide? Are all the aisles and pathways to materials and services at least 36 inches wide? Are all the aisles and pathways to materials and services at least 36 inches wide? Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space. Furnishings, partitions, or other obstructions interfere with clear wall space. Furnishings, partitions, or other obstructions interfere with clear wall space. Furnishings, partitions, or other obstructions interfere with clear wall space. Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space. Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space. Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space. Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space. Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Room-F	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room-G	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Room-F	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
158	SUBSTANCE ABUSE & HEALTH CARE SERV. BROWARD ADDICTION RECOVERY CENTER - BOOHER BUILDING	The public phones	If there are four or more public phones in the building, is one of the phones equipped with a text telephone (TTY)?	TTY has not been provided.	Install a TTY.
159	SUBSTANCE ABUSE & HEALTH CARE SERV. BROWARD ADDICTION RECOVERY CENTER - CENTRAL				

#	Program/Agency	Location	Question	Barrier	Recommendation
		<p>The Administration Office doors (exterior) are 28-½" wide; the Outpatient Service door (exterior) is 28-½" wide; the Access Services door (exterior) is 30" wide; and the Non-Residential Day Treatment entrance doors (exterior) are 29-½" wide.</p>	<p>Does the entrance door have at least 32 inches clear opening? (for a double door, at least one 32-inch leaf)</p>	<p>Door does not have a least a 32 inch clear opening.</p>	<p>Meet clients in an accessible office or conference room.</p>
160	SUBSTANCE ABUSE & HEALTH CARE SERV.	The Group room doorways (interior) are 28" wide.	Does the Door have at least 32 inches clear opening?	Door does not have a least a 32 inch clear opening.	Meet clients in an accessible office or conference room.
	BROWARD ADDICTION RECOVERY CENTER - DAVIE	The reception area counter	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
		The pathway to the restroom	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Acessiible routes to public spaces	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
		Through out the facility	Is there a 5-foot circle or a T-shaped space for a person using a wheelchair to reverse direction?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
161	SUBSTANCE ABUSE & HEALTH CARE SERV. BROWARD ADDICTION RECOVERY CENTER - SOUTH	The public phone	If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one?	Pay phone does not have the required clear floor space.	Move furnishings and other obstructions.
163	SUBSTANCE ABUSE & HEALTH CARE SERV. GOVERNMENTAL CENTER EAST	Substance Abuse Healthcare Services- Room #303	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
163	SUBSTANCE ABUSE & HEALTH CARE SERV. GOVERNMENTAL CENTER EAST	Substance Abuse Healthcare Services- Room #303	Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.
164	SUBSTANCE ABUSE & HEALTH CARE SERV. MENTAL HEALTH				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Rm. 104 A/B, Patient rooms, Group therapy room: Restraining rooms.	Are all the aisles and pathways to materials and services at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
164	SUBSTANCE ABUSE & HEALTH CARE SERV. MENTAL HEALTH	Room 104 A/B, Patients rooms, Restraining rooms, Group therapy room: Rm. 104 A/B	Are all the aisles and pathways to materials and services at least 36 inches wide?	Furnishings, such as tables, chairs, display racks, vending machines and counters reduce the accessible route to public spaces.	Move furnishings to make more room.
165	SUBSTANCE ABUSE & HEALTH CARE SERV. NORTH REGIONAL HEALTH CENTER (HUGES BUILDING)	The small lab located on the 2nd floor, Counseling room #168, Eligibility rooms(2nd floor), The X-Ray room on the 1st floor, and the 1st floor Immunization room.	Is the accessible route to all public spaces at least 36 inches wide?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
165	SUBSTANCE ABUSE & HEALTH CARE SERV. NORTH REGIONAL HEALTH CENTER (HUGES BUILDING)				

#	Program/Agency	Location	Question	Barrier	Recommendation
		The small lab locate on the 2nd floor, counseling room #168, Eligibility rooms (2nd floor), X-ray room on the 1st floor, and the 1st floor Immunization room.	Are public spaces on an accessible route of travel?	Furniture or other obstacles reduce the required wheelchair maneuvering space.	Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.

**OTHER GOVERNMENT ENTITIES**

166	LEGISLATIVE DELEGATION GOVERNMENTAL CENTER EAST	Reception Counter.	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Aisles and pathways to materials and services are not 36 inches wide.	Rearrange furnishings and fixtures to clear aisles.
167	PLANNING COUNCIL GOVERNMENTAL CENTER EAST	Planning Council-Room #307.	On the "pull" side of the door, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair or crutches can get near to open the door?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.

**PUBLIC WORKS & TRANSPORTATION**

190	CONSTRUCTION MANAGEMENT GOVERNMENTAL CENTER ANNEX	Entrance Door - Room A550.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
-----	------------------------------------------------------	----------------------------	-----------------------------------------------------------------------	---------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------

#	Program/Agency	Location	Question	Barrier	Recommendation
		Conference Room.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Project Manager's Office	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Assistant Director's Office.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Exit Door.	Is the accessible route to all public spaces at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
		Main Entrance.	Is the route at least 36 inches wide?	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
191	FACILITIES MANAGEMENT ADMINISTRATION GOVERNMENTAL CENTER EAST	receptionist counter Offices 514A, B, D, E , and F	In circulation paths through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding less than 4 inches from the wall)?	Obstacles are not cane detectable.	Install furnishings, planters , or other cane detectable barriers underneath.
193	FACILITIES MANAGEMENT OPERATIONS GOVERNMENTAL CENTER EAST				

#	Program/Agency	Location	Question	Barrier	Recommendation
		Fifth floor Women's restroom	Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? (A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5 foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.)	Furnishings, partitions, or other obstructions interfere with clear wall space.	Relocate, remove and maintain furnishings, partitions, or other obstructions away from the clear wall space.
217	FACILITIES MANAGEMENT OPERATIONS GOVERNMENTAL CENTER WEST	The Telephones	If there are four or more public phones in the building, is one of the phones equipped with a text telephone (TTY)?	TTY has not been provided.	Install a TTY.
200	REAL PROPERTY - PUBLIC WORKS GOVERNMENTAL CENTER EAST	Room 326.	Are there ramps, lifts, or elevators to all public levels?	There is not direct access to all public levels.	Relocate the services to an accessible area upon request. Patrons must be informed of this policy.
205	WATER & WASTEWATER SERVICES WATER AND WASTE WATER SERVICES ENGINEERING DIVISION	Service Counter Customer Service	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.
		Service Counter Engineering	Are the tops of tables or counters between 28 and 34 inches high?	Counter top is too high	Make a clipboard available to the public.

#	Program/Agency	Location	Question	Barrier	Recommendation
		Costumer Service - Water Fountain	Is there at least one fountain with clear floor space of at least 30 by 48 inches in front?	Furnishings interfere with the Drinking Fountain clear floor space.	Clear more room by rearranging or removing furnishings.

**URBAN PLANNING & REDEVELOPMENT**

215

URBAN PLANNING AND REDEVELOPMENT ADMIN  
GOVERNMENTAL CENTER EAST

room 329A.

Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?

Furniture or other obstacles reduce the required wheelchair maneuvering space.

Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.

Administration Cubicle.

Is there a 5-foot circle or T-shaped space for turning a wheelchair completely?

Furniture or other obstacles reduce the required wheelchair maneuvering space.

Rearrange the furniture or remove obstacles to allow a 5- foot circle or a T-shaped space for a person using a wheelchair to reverse direction.

Administration Area.

Are all the aisles and pathways to materials and services at least 36 inches wide?

Aisles and pathways to materials and services are not 36 inches wide.

Rearrange furnishings and fixtures to clear aisles.

**Auxiliary Aids and Services Cost Estimates by Program**

	TTY*	Braille Embosser and Software**	Sign Language Interpreters' and Other Contract Services***
--	------	---------------------------------	------------------------------------------------------------

**COMMUNITY SERVICES**

ADMINISTRATION			\$11,740
ANIMAL CARE & REGULATION	ANIMAL CARE AND REGULATION - NORTH	\$684	
	ANIMAL CARE AND REGULATION - SOUTH	\$684	
CONSUMER AFFAIRS	GOVERNMENTAL CENTER ANNEX	\$684	
CULTURAL DIVISION	LIBRARY - MAIN	\$684	
EXTENSION EDUCATION	EXTENSION EDUCATION SERVICE	\$684	
LIBRARIES	LIBRARY - AFRICAN AMERICAN RESEARCH	\$684	
	LIBRARY - ALVIN SHERMAN	\$684	
	LIBRARY - BEACH BRANCH	\$684	
	LIBRARY - CARVER RANCHES	\$684	
	LIBRARY - CENTURY PLAZA	\$684	
	LIBRARY - COLLIER CITY	\$684	
	LIBRARY - DANIA BEACH	\$684	
	LIBRARY - DAVIE COOPER CITY	\$684	
	LIBRARY - DEERFIELD BEACH	\$684	
	LIBRARY - FT LAUDERDALE BRANCH(HOLIDAY PARK)	\$684	
	LIBRARY - GALT OCEAN MILE	\$684	
	LIBRARY - HALLANDALE	\$684	
	LIBRARY - IMPERIAL POINT	\$684	
	LIBRARY - LAUDERDALE LAKES	\$684	
	LIBRARY - LAUDERHILL	\$684	
	LIBRARY - LAUDERHILL MALL	\$684	

		TTY*	Braille Embosser and Software**	Sign Language Interpreters' and Other Contract Services***
	LIBRARY - NORTH LAUDERDALE	\$684		
	LIBRARY - NORTH WEST POMPANO	\$684		
	LIBRARY - NORTH WEST REGIONAL	\$684		
	LIBRARY - PEMBROKE PINES	\$684		
	LIBRARY - POMPANO BEACH	\$684		
	LIBRARY - RIVERLAND	\$684		
	LIBRARY - SOUTH WEST REGIONAL	\$684		
	LIBRARY - STIRLING ROAD	\$684		
	LIBRARY - SUNRISE	\$684		
	LIBRARY - SUNSET STRIP	\$684		
	LIBRARY - TAMARAC	\$684		
	LIBRARY - TYRONE BRYANT	\$684		
	LIBRARY - WEST ATLANTIC	\$684		
	LIBRARY - WESTON	\$684		
	READING CENTER - HOLLYWOOD BEACH	\$684		
PARKS & RECREATION				
	PARKS - BRIAN PICCOLLO PARK	\$684		
	PARKS - CB SMITH PARK	\$684		
	PARKS - MARKHAM PARK	\$684		
	PARKS - QUIET WATERS PARK	\$684		
	PARKS - SECRET WOODS NATURE CENTER	\$684		
	PARKS - TOPEEKEEGEE PARK	\$684		
<b>Department Total</b>		<b>\$28,728</b>	<b>\$11,740</b>	<b>\$40,468</b>
<b>COUNTY ADMINISTRATION</b>				
COUNTY ADMINISTRATOR	GOVERNMENTAL CENTER EAST	\$684		
EMERGENCY MANAGEMENT AGENCY	EMERGENCY OPERATIONS CENTER	\$684		
OFFICE OF EQUAL OPPORTUNITY*			\$11,740	
Civil Rights	GOVERNMENTAL CENTER ANNEX	\$684		

		TTY*	Braille Embosser and Software**	Sign Language Interpreters' and Other Contract Services***	
Small Business	GOVERNMENTAL CENTER ANNEX	\$684			
Internal Investigations & Oversight	GOVERNMENTAL CENTER EAST	\$684		\$100,000	
PUBLIC COMMUNICATIONS	GOVERNMENTAL CENTER EAST	\$684	\$11,740		
OFFICE OF TRANSPORTATION	MASS TRANSIT ADMINISTRATION (ADA Specialist)	\$684			
	MASS TRANSIT MAIN TERMINAL	\$684			
	MASS TRANSIT TRANSFER FACILITY	\$684			
<b>Department Total</b>		<b>\$6,156</b>	<b>\$23,480</b>	<b>\$100,000</b>	<b>\$129,636</b>
<b>COUNTY COMMISSION</b>					
COUNTY COMMISSION (BOARD MEMBERS)	GOVERNMENTAL CENTER EAST	\$684			
HISTORICAL COMMISSION	HISTORICAL COMMISSION	\$684			
<b>Department Total</b>		<b>\$1,368</b>	<b>\$0</b>		<b>\$1,368</b>
<b>ENVIRONMENTAL PROTECTION</b>					
	ENVIRONMENTAL MONITORING FACILITY	\$684			
	GOVERNMENTAL CENTER WEST	\$684			
<b>Department Total</b>		<b>\$1,368</b>	<b>\$0</b>		<b>\$1,368</b>
<b>FINANCE AND ADMINISTRATIVE SERVICES</b>					
ADMINISTRATION			\$11,740		
COUNTY RECORDS	GOVERNMENTAL CENTER EAST	\$684			
HUMAN RESOURCES	EMPLOYMENT ASSISTANCE PROGRAM	\$684			
	GOVERNMENTAL CENTER EAST	\$684			
	PERSONNEL - ANNEX B	\$684			
REVENUE COLLECTIONS	GOVERNMENTAL CENTER ANNEX	\$684			
	GOVERNMENTAL CENTER EAST	\$684			
	SOUTH REGIONAL COURTHOUSE	\$684			
	TAG AGENCY	\$684			
	WEST REGIONAL COURTHOUSE	\$684			
SUPPORT ENFORCEMENT	MIDRISE OFFICE	\$684			

	TTY*	Braille Embosser and Software**	Sign Language Interpreters' and Other Contract Services***
<b>Department Total</b>	<b>\$6,840</b>	<b>\$11,740</b>	<b>\$18,580</b>

**HUMAN SERVICES**

ADMINISTRATION			\$11,740
CHILDREN'S SERVICES ADMINISTRATION	FAMILY SUCCESS ADMINISTRATION DIVISION	\$684	\$11,740
	GOVERNMENTAL CENTER ANNEX	\$684	
	OUR HOUSE	\$684	
	SEXUAL ASSAULT CENTER (HOTLINE)	\$684	
ELDERLY & VETERANS SERVICES	FAMILY SUCCESS ADMINISTRATION DIVISION	\$684	\$11,740
	NORTH REGIONAL COURTHOUSE	\$684	
	SOUTH REGIONAL COURTHOUSE	\$684	
FAMILY SUCCESS ADMINISTRATION	FAMILY SUCCESS ADMINISTRATION DIVISION		
	NORTH FAMILY SUCCESS CENTER	\$684	\$11,740
	NORTH WEST FAMILY SUCCESS CENTER	\$684	\$11,740
	SOUTH FAMILY SUCCESS CENTER	\$684	\$11,740
HOMELESS INITIATIVE PARTNERSHIP	CENTRAL HOMELESS SHELTER	\$684	
	GOVERNMENTAL CENTER EAST	\$684	
	NORTH HOMELESS ASSISTANCE CENTER	\$684	
MEDICAL EXAMINER TRAUMA SERVICES	MEDICAL EXAMINER	\$684	
SUBSTANCE ABUSE & HEALTH CARE SERV.	BROWARD ADDICTION RECOVERY CENTER-BOOHER	\$684	\$11,740
	BROWARD ADDICTION RECOVERY CENTER CENTRAL	\$684	\$11,740
	BROWARD ADDICTION RECOVERY CENTER - DAVIE	\$684	\$11,740
	BROWARD ADDICTION RECOVERY CENTER - SOUTH	\$684	\$11,740

		TTY*	Braille Embosser and Software**	Sign Language Interpreters' and Other Contract Services***	
	CASE MANAGMENT SERVICES (HUMAN SERVICES)	\$684			
	GOVERNMENTAL CENTER EAST	\$684			
	MENTAL HEALTH	\$684			
	NORTH REGIONAL HEALTH CENTER (HUGES BLDG)	\$684			
<b>Department Total</b>		<b>\$15,048</b>	<b>\$117,400</b>		<b>\$132,448</b>
<b>PORT EVERGLADES</b>					
	PORT EVERGLADES      PORT EVERGLADES - ADMINISTRATION	\$684			
<b>Department Total</b>		<b>\$684</b>	<b>\$0</b>		<b>\$684</b>
<b>PUBLIC WORKS &amp; TRANSPORTATION</b>					
	TRAFFIC ENGINEERING      TRAFFIC ENGINEERING BUILDING	\$684			
<b>Department Total</b>		<b>\$684</b>	<b>\$0</b>		<b>\$684</b>
<b>URBAN PLANNING &amp; REDEVELOPMENT</b>					
	BUILDING CODE SERVICES      BUILDING CODE SERVICES	\$684			
	PERMIT AND LICENSING	\$684			
<b>Department Total</b>		<b>\$1,368</b>	<b>\$0</b>		<b>\$1,368</b>
<b>Total Estimated Cost</b>		<b>\$62,244</b>	<b>\$164,360</b>	<b>\$100,000</b>	<b>\$326,604</b>

**NOTE:**

\* **TTY Estimated Cost (\$684)** = TTY (\$499) + Instruction Video (\$15) + Phone line (\$170)

\*\* **Braille Estimated Cost (\$11,740)** = Hardware (\$10, 995) + S/H (\$150) + Single User License (\$595)

\*\*\* **Other Contract Services** may include Readers, and/or Braille transcription services for publications/materials that can not be produced in house due to the complex format (i.e. Graphs, Tables, Mathematical Equations etc.).

---

## Training Subject Areas

---

Type of Training	Target Audience
Bus Stops and Route Accessibility Issues	ADA Specialist and Transportation Engineers
Emerging Issues in Accessible Fixed Route Services	ADA Specialist and Transportation Supervisors and Managers
Paratransit Best Practices	Transportation Supervisors and Managers
Court Accessibility	Architects, Engineers and Facility Managers
Program and Facility Accessibility	County Architects, Engineers and Facility Managers
Accessibility Standards for Building Construction	County Architects, Engineers and Facility Managers
TTY/Relay Training	Front Line Personnel
Communication with Individuals with Disabilities	Front Line Personnel
Employment Provisions of the ADA	Human Resources Representatives and Officers
Interplay between the Title I of the ADA , FMLA and Worker's Compensation	Human Resources Representatives, and Risk Management Supervisors
Emergency Preparedness and the ADA	Human Services Supervisors and Managers, Emergency Management Employees
Parks and Outdoor Environment Accessibility	Parks and Recreation Managers
Website Accessibility	Staff responsible for website development
Service Animals/ Emotional Support Animals and the ADA	Supervisors and Managers

## Program List By Department

*Department* **BROWARD COUNTY SHERIFF**

**Agency / Program** BROWARD SHERIFF OFFICE

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
1 BROWARD EMERGENCY SERVICES BUILDING 2601 W BROWARD BLVD FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
2 BROWARD SHERIFF OFFICE - DISTRICT 5 200 NE 27 AVENUE FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
3 JUVENILE ASSESSMENT CENTER 2600 SW 4 AVENUE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
4 LANIER JAMES EDUCATION CENTER 1050 NW 7 COURT HALLANDALE	8	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for BROWARD SHERIFF OFFICE (4 detail records)

Subtotal for BROWARD COUNTY SHERIFF (4 detail records)

*Department* **CLERK OF COURT**

**Agency / Program** ADMINISTRATIVE OFFICES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
5 CLERK OF COURT ARCHIVES 529 SW 2 AVE FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

6	MAIN COURTHOUSE 201 SE 6TH ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
7	NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
8	SOUTH REGIONAL COURTHOUSE 3550 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
9	WEST REGIONAL COURTHOUSE 100 N PINE ISLAND RD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for ADMINISTRATIVE OFFICES (5 detail records)

**Agency / Program** COURTS

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
10 MAIN COURTHOUSE 201 SE 6TH ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
11 NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
12 SOUTH REGIONAL COURTHOUSE 3550 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
13 WEST REGIONAL COURTHOUSE 100 N PINE ISLAND RD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for COURTS (4 detail records)

**Agency / Program** PUBLIC DEFENDER

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
14 MIDRISE OFFICE 540 SE 3 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

15	PUBLIC DEFENDER 412 SE 6TH STREET FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
----	---------------------------------------------------------	---	--------------------------	--------------------------	---	--------------------------

Subtotal for PUBLIC DEFENDER (2 detail records)

**Agency / Program** STATE ATTORNEY

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
16	STATE ATTORNEY 16 SE 6 ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
17	WEST REGIONAL COURTHOUSE 100 N PINE ISLAND RD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for STATE ATTORNEY (2 detail records)

Subtotal for CLERK OF COURT (13 detail records)

*Department* **COMMUNITY SERVICES**

**Agency / Program** ANIMAL CARE & REGULATION

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
18	ANIMAL CARE AND REGULATION - NORTH 3100 NW 19 TERR POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
19	ANIMAL CARE AND REGULATION - SOUTH 1871 SW 40TH ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for ANIMAL CARE & REGULATION (2 detail records)

**Agency / Program** COMMUNITY SERVICES ADMINISTRATION

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
20	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for COMMUNITY SERVICES ADMINISTRATION (1 detail record)

**Agency / Program** CONSUMER AFFAIRS

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
21 GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for CONSUMER AFFAIRS (1 detail record)

**Agency / Program** CULTURAL DIVISION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
22 LIBRARY - MAIN 100 S ANDREWS AVE FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>

Subtotal for CULTURAL DIVISION (1 detail record)

**Agency / Program** EXTENSION EDUCATION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
23 EXTENSION EDUCATION SERVICE 3245 COLLEGE AVE DAVIE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for EXTENSION EDUCATION (1 detail record)

**Agency / Program** LIBRARIES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
24 LIBRARY - AFRICAN AMERICAN RESEARCH 2650 NW 6TH STREET FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>

25 LIBRARY - ALVIN SHERMAN 3100 RAY FERRERO JR BLVD DAVIE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
-----------------------------------------------------------------	---	--------------------------	--------------------------	---	-------------------------------------

26	LIBRARY - BEACH BRANCH 221 POMPANO BEACH BLVD POMPANO BRACH	4	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
27	LIBRARY - CARVER RANCHES 4735 SW 18 ST WEST PARK	8	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
28	LIBRARY - CENTURY PLAZA 1890 W HILLSBORO BLVD DEERFIELD BEACH	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
29	LIBRARY - COLLIER CITY 2800 NW 9 CT POMPANO BEACH	9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
30	LIBRARY - DANIA BEACH 255 E. DANIA BEACH BLVD DANIA BEACH	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
31	LIBRARY - DAVIE COOPER CITY 4600 SW 82 AVE DAVIE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
32	LIBRARY - DEERFIELD BEACH 837 E HILLSBORO BLVD DEERFIELD BEACH	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
33	LIBRARY - FORT LAUDERDALE BRANCH (HOL 1300 E SUNRISE BLVD. FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
34	LIBRARY - GALT OCEAN MILE 3403 GALT OCEAN DR FORT LAUDERDALE	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
35	LIBRARY - HALLANDALE 300 S FEDERAL HWY HALLANDALE	6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
36	LIBRARY - IMPERIAL POINT 5985 NORTH FEDERAL HWY FORT LAUDERDALE	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
37	LIBRARY - LAUDERDALE LAKES 3521 NW 43 AVE LAUDERDALE LAKES	9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
38	LIBRARY - LAUDERHILL 6399 W OAKLAND PARK BLVD LAUDERHILL	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>

39	LIBRARY - LAUDERHILL MALL 4257 NW 12 ST LAUDERHILL	9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
40	LIBRARY - MAIN 100 S ANDREWS AVE FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
41	LIBRARY - MARGATE 5810 PARK DRIVE MARGATE	2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
42	LIBRARY - NORTH LAUDERDALE 6901 KIMBERLY BLVD NORTH LAUDERDALE	9	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
43	LIBRARY - NORTH REGIONAL 1100 COCONUT CREEK BLVD COCONUT CREEK	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
44	LIBRARY - NORTH WEST POMPAÑO 1580 NW 3 AVE POMPAÑO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
45	LIBRARY - NORTH WEST REGIONAL 3151 N UNIVERSITY DRIV CORAL SPRINGS	3	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
46	LIBRARY - PEMBROKE PINES 955 NW 129 AVE PEMBROKE PINES	5	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
47	LIBRARY - POMPAÑO BEACH 1213 E ATLANTIC BLVD POMPAÑO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
48	LIBRARY - RIVERLAND 2710 DAVIE BLVD FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
49	LIBRARY - SOUTH WEST REGIONAL 16835 SHERIDAN STREET PEMBROKE PINES	8	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
50	LIBRARY - STIRLING ROAD 3151 STIRLING ROAD HOLLYWOOD	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
51	LIBRARY - SUNRISE 10550 W OAKLAND PARK BLVD SUNRISE	3	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>

52	LIBRARY - SUNSET STRIP 6600 SUNSET STRIP SUNRISE	9	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
53	LIBRARY - TAMARAC 8701 W COMMERCIAL BLVD TAMARAC	3	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
54	LIBRARY - TYRONE BRYANT 2230 NW 21 AVE FORT LAUDERDALE	9	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
55	LIBRARY - WEST ATLANTIC 10641 W ATLANTIC BLVD CORAL SPRINGS	3	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
56	LIBRARY - WEST REGIONAL 8601 W BROWARD BLVD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
57	LIBRARY - WESTON 4205 BONAVENTURE BLVD WESTON	8	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
58	READING CENTER - HOLLYWOOD BEACH 1301 S. OCEAN DRIVE HOLLYWOOD	6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for LIBRARIES (35 detail records)

**Agency / Program**    PARKS & RECREATION

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
59	CENTRAL DISTRICT PARKS 2555 NW 21ST AVENUE FORT LAUDERDALE	9	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
60	PARKS - BOATERS PARK DANIA BEACH CUT OFF CANAL DANIA BEACH	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input checked="" type="checkbox"/>
61	PARKS - BOULEVARD GARDENS PARK 304 NW 28 WAY FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>
62	PARKS - BRIAN PICCOLLO PARK 9501 SHERIDAN ST COOPER CITY	5	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>

63	PARKS - CB SMITH PARK 900 N FLAMINGO RD PEMBROKE PINES	5	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
64	PARKS - CRYSTAL LAKE 3299 NE 3RD AVENUE POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>
65	PARKS - DEERFIELD ISLAND PARK 1720 DEERFIELD ISLAND DEERFIELD BEACH	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input checked="" type="checkbox"/>
66	PARKS - DELEVOE PARK 2520 N.W. 6TH STREET FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
67	PARKS - EASTERLIN PARK 1000 NW 38 ST OAKLAND PARK	9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
68	PARKS - FERN FOREST PARK 201 LYONS ROAD SOUTH COCONUT CREEK	2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
69	PARKS - FRANKLIN PARK 2501 FRANKLIN DRIVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
70	PARKS - HILLSBORO PINELAND PARK 5591 NW 74 PLACE COCONUT CREEK	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input checked="" type="checkbox"/>
71	PARKS - HOLLYWOOD NORTH BEACH PARK 3601 N OCEAN DR HOLLYWOOD	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
72	PARKS - LAFAYETTE HART PARK 2851 NW 8TH ROAD FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input checked="" type="checkbox"/>
73	PARKS - LEWIS CHISM PARK 2620 NW 8TH STREET FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>
74	PARKS - MARKHAM PARK 16001 W SR84 SUNRISE	5	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input checked="" type="checkbox"/>
75	PARKS - MCTYRE PARK 3500 SW 56 AVE PEMBROKE PARK	8	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input checked="" type="checkbox"/>

76	PARKS - PLANTATION HERITAGE PARK 11S FIGTREE LANE PLANTATION	9	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
77	PARKS - QUIET WATERS PARK 401 S POWERLINE RD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
78	PARKS - ROOSEVELT GARDENS 2800 NW 11TH ST FORT LAUDERDALE	9	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>
79	PARKS - SECRET WOODS NATURE CENTER 2701 SR84 DANIA BEACH	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
80	PARKS - SNAKE WARRIOR ISLAND 3600 SW 62 AVE MIRAMAR	8	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>
81	PARKS - SUN VIEW PARK 1500 SW 42ND AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input checked="" type="checkbox"/>
82	PARKS - TALL CYPRESS 3700 TURTLE RUN BLVD CORAL SPRINGS	1	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>
83	PARKS - TOPEEKEEGEE PARK 3300 N PARK RD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
84	PARKS - TRADEWINDS PARK 3600 W SAMPLE RD COCONUT CREEK	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
85	PARKS - TREE TOPS PARK 3900 SW 100 AVE DAVIE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
86	PARKS - VISTA VIEW PARK 3601 SW 142 AVE DAVIE	5	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
87	PARKS - WEST LAKE PARK 751 SHERIDAN ST HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	1	<input checked="" type="checkbox"/>
88	PARKS - WOODMONT PINELAND 7250 NW 80 AVENUE TAMARAC	3	<input type="checkbox"/>	<input type="checkbox"/>	3	<input checked="" type="checkbox"/>

89	PARKS ADMINISTRATION BUILDING - NORTH 950 NW 38 ST OAKLAND PARK	9	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
----	-----------------------------------------------------------------------	---	--------------------------	--------------------------	---	--------------------------

Subtotal for PARKS & RECREATION (31 detail records)

Subtotal for COMMUNITY SERVICES (72 detail records)

<i>Department</i>	<b>COUNTY ADMINISTRATION</b>
-------------------	------------------------------

**Agency / Program** COUNTY ADMINISTRATOR

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
90 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for COUNTY ADMINISTRATOR (1 detail record)

**Agency / Program** EMERGENCY MANAGEMENT AGENCY

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
91 EMERGENCY OPERATIONS CENTER 201 NW 84TH AV PLANTATION	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for EMERGENCY MANAGEMENT AGENCY (1 detail record)

**Agency / Program** GREATER FORT LAUDERDALE CONVENTION AND VISITORS

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
92 CONVENTION CENTER 1950 EISENHOWER BLVD FORT LAUDERDALE	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
93 GREATER FORT LAUDERDALE CONVENTION 100 E BROWARD BLVD, SUITE 200 FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for GREATER FORT LAUDERDALE CONVENTION AND VISITORS (2 detail records)

**Agency / Program** OFFICE OF ECONOMIC DEVELOPMENT

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
94 GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
95 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for OFFICE OF ECONOMIC DEVELOPMENT (2 detail records)

**Agency / Program** OFFICE OF EQUAL OPPORTUNITY

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
96 GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
97 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for OFFICE OF EQUAL OPPORTUNITY (2 detail records)

**Agency / Program** OFFICE OF MANAGEMENT AND BUDGET

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
98 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for OFFICE OF MANAGEMENT AND BUDGET (1 detail record)

**Agency / Program** OFFICE OF PUBLIC & GOVERNMENTAL RELATION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
---------------------	---------------------	--------------	------------	----------------	-----------------------------

99	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
----	---------------------------------------------------------------------	---	-------------------------------------	-------------------------------------	---	--------------------------

Subtotal for OFFICE OF PUBLIC & GOVERNMENTAL RELATION (1 detail record)

**Agency / Program** OFFICE OF TRANSPORTATION

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
100	MASS TRANSIT ADMINISTRATION 3201 COPANS RD POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
101	MASS TRANSIT MAIN TERMINAL 101 N.W. 1ST AVENUE FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
102	MASS TRANSIT TRANSFER FACILITY 100 N PINE ISLAND RD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for OFFICE OF TRANSPORTATION (3 detail records)

**Agency / Program** PUBLIC COMMUNICATIONS

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
103	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PUBLIC COMMUNICATIONS (1 detail record)

Subtotal for COUNTY ADMINISTRATION (14 detail records)

*Department* **COUNTY COMMISSION**

**Agency / Program** COUNTY ATTORNEY

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
104	GOVERNMENTAL CENTER EAST 3RD FLOOR 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>

105	GOVERNMENTAL CENTER EAST 4TH FLOOR 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
-----	-------------------------------------------------------------------------------	---	--------------------------	--------------------------	--------------------------

Subtotal for COUNTY ATTORNEY (2 detail records)

**Agency / Program** COUNTY AUDITOR

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report
106 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for COUNTY AUDITOR (1 detail record)

**Agency / Program** COUNTY COMMISSION (BOARD MEMBERS)

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report
107 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for COUNTY COMMISSION (BOARD MEMBERS) (1 detail record)

**Agency / Program** HISTORICAL COMMISSION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report
108 HISTORICAL COMMISSION 151 SW 2 ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for HISTORICAL COMMISSION (1 detail record)

Subtotal for COUNTY COMMISSION (5 detail records)

*Department* **ENVIRONMENTAL PROTECTION**

**Agency / Program** AIR QUALITY

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report

109	ENVIRONMENTAL MONITORING FACILITY 3211 COLLEGE AVE DAVIE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
110	GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for AIR QUALITY (2 detail records)

**Agency / Program** BIOLOGICAL RESOURCES

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
111	GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for BIOLOGICAL RESOURCES (1 detail record)

**Agency / Program** ENVIRONMENTAL MONITORING

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
112	ENVIRONMENTAL MONITORING FACILITY 3211 COLLEGE AVE DAVIE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for ENVIRONMENTAL MONITORING (1 detail record)

**Agency / Program** ENVIRONMENTAL PROTECTION ADMIN

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
113	GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for ENVIRONMENTAL PROTECTION ADMIN (1 detail record)

**Agency / Program** POLLUTION PREVENTION AND REMEDIATION

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
--	---------------------	---------------------	--------------	------------	----------------	-----------------------------

114	GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
-----	----------------------------------------------------------------	---	--------------------------	--------------------------	---	--------------------------

Subtotal for POLLUTION PREVENTION AND REMEDIATION (1 detail record)

**Agency / Program** WATER RESOURCES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report
115 GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for WATER RESOURCES (1 detail record)

Subtotal for ENVIRONMENTAL PROTECTION (7 detail records)

*Department* **FINANCE AND ADMINISTRATIVE SERVICES**

**Agency / Program** ACCOUNTING

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report
116 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for ACCOUNTING (1 detail record)

**Agency / Program** COUNTY RECORDS

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has
					Special Features Report
117 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
118 NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for COUNTY RECORDS (2 detail records)

**Agency / Program** FINANCE & ADMINISTRATIVE SERVICES ADMIN

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
119 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for FINANCE & ADMINISTRATIVE SERVICES ADMIN (1 detail record)

**Agency / Program** HUMAN RESOURCES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
120 EMPLOYMENT ASSISTANCE PROGRAM (HUM 1317 SE 4 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
121 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
122 PERSONNEL - ANNEX B 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for HUMAN RESOURCES (3 detail records)

**Agency / Program** OFFICE OF INFORMATION TECHNOLOGY

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
123 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for OFFICE OF INFORMATION TECHNOLOGY (1 detail record)

**Agency / Program** PURCHASING

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
---------------------	---------------------	--------------	------------	----------------	-----------------------------

124	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
125	NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PURCHASING (2 detail records)

**Agency / Program** REVENUE COLLECTION

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
126	GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
127	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
128	SOUTH REGIONAL COURTHOUSE 3550 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
129	TAG AGENCY 815 NE 13 ST FORT LAUDERDALE	9	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
130	WEST REGIONAL COURTHOUSE 100 N PINE ISLAND RD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for REVENUE COLLECTION (5 detail records)

**Agency / Program** RISK MANAGEMENT

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
131	GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
132	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for RISK MANAGEMENT (2 detail records)

**Agency / Program** SUPPORT ENFORCEMENT

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
133 MIDRISE OFFICE 540 SE 3 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for SUPPORT ENFORCEMENT (1 detail record)

Subtotal for FINANCE AND ADMINISTRATIVE SERVICES (18 detail records)

<i>Department</i>	<b>HUMAN SERVICES</b>
-------------------	-----------------------

**Agency / Program** CHILDREN'S SERVICES ADMINISTRATION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
134 FAMILY SUCCESS ADMINISTRATION DIVISION 2995 N DIXIE HIGHWAY OAKLAND PARK	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
135 GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
136 OUR HOUSE 408 NE 4TH STREET FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
137 SEXUAL ASSAULT CENTER 400 NE 4 ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for CHILDREN'S SERVICES ADMINISTRATION (4 detail records)

**Agency / Program** DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
138 CENTRAL HOMELESS SHELTER 920 NW 7 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>

139	FORT LAUDERDALE HEALTH CENTER 2421-A SW 6 AVE FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
140	FORT LAUDERDALE SATELLITE CENTER (HU 333 SW 28 ST FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
141	NORTH REGIONAL HEALTH CENTER (HUGES 205 NW 6 AVENUE POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
142	NORTH REGIONAL HEALTH CENTER (HUNTER 601 W ATLANTIC BLVD POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
143	NORTH WEST HEALTH CENTER AIDS CLINIC 624 NW 15 WAY FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
144	SOUTH BROWARD FIELD OFFICE 7999 W PEMBROKE ROAD PEMBROKE PINES	6	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
145	SOUTH REGIONAL HEALTH CENTER 4105 PEMBROKE RD HOLLYWOOD	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for DEPARTMENT OF HEALTH (STATE) CONTRACTED SERVICES (8 detail records)

**Agency / Program** ELDERLY & VETERANS SERVICES

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
146	FAMILY SUCCESS ADMINISTRATION DIVISION 2995 N DIXIE HIGHWAY OAKLAND PARK	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
147	NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD HOLLYW DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
148	SOUTH REGIONAL COURTHOUSE 3550 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for ELDERLY & VETERANS SERVICES (3 detail records)

**Agency / Program** FAMILY SUCCESS ADMINISTRATION

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
149	FAMILY SUCCESS ADMINISTRATION DIVISION 2995 N DIXIE HIGHWAY OAKLAND PARK	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
150	NORTH FAMILY SUCCESS CENTER 2011 NW 3 AVE POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
151	NORTH WEST FAMILY SUCCESS CENTER 10077 NW 29 ST CORAL SPRINGS	3	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
152	SOUTH FAMILY SUCCESS CENTER 4733 SW 18 ST HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for FAMILY SUCCESS ADMINISTRATION (4 detail records)

**Agency / Program** HOMELESS INITIATIVE PARTNERSHIP

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
153	CENTRAL HOMELESS SHELTER 920 NW 7 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
154	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
155	NORTH HOMELESS ASSISTANCE CENTER 1700 BLOUNT ROAD POMPANO BEACH	9	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for HOMELESS INITIATIVE PARTNERSHIP (3 detail records)

**Agency / Program** MEDICAL EXAMINER TRAUMA SERVICES

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
--	----------------------------	----------------------------	---------------------	-------------------	-----------------------	------------------------------------

156	MEDICAL EXAMINER 5301 SW 31 AVE DANIA BEACH	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
-----	---------------------------------------------------	---	--------------------------	-------------------------------------	---	--------------------------

Subtotal for MEDICAL EXAMINER TRAUMA SERVICES (1 detail record)

**Agency / Program** PROGRAM DEVELOPMENT RESEARCH & EVALUATION

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
157	GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PROGRAM DEVELOPMENT RESEARCH & EVALUATION (1 detail record)

**Agency / Program** SUBSTANCE ABUSE & HEALTH CARE SERVICES

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
158	BROWARD ADDICTION RECOVERY CENTER - 3275 NW 99 WAY CORAL SPRINGS	3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
159	BROWARD ADDICTION RECOVERY CENTER - 1011 SW 2 CT FORT LAUDERDALE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
160	BROWARD ADDICTION RECOVERY CENTER - 4175 DAVIE ROAD DAVIE	7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
161	BROWARD ADDICTION RECOVERY CENTER - 5701 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
162	CASE MANAGMENT SERVICES (HUMAN SERVI 4200 NW 16 ST LAUDERHILL	9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>
163	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
164	MENTAL HEALTH 2677 NW 19 ST FORT LAUDERDALE	9	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>

165	NORTH REGIONAL HEALTH CENTER (HUGES 205 NW 6 AVENUE POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
-----	-------------------------------------------------------------------------	---	--------------------------	--------------------------	---	--------------------------

Subtotal for SUBSTANCE ABUSE & HEALTH CARE SERVICES (8 detail records)

Subtotal for HUMAN SERVICES (32 detail records)

<i>Department</i>	<b><i>OTHER GOVERNMENT ENTITIES</i></b>
-------------------	-----------------------------------------

**Agency / Program** LEGISLATIVE DELEGATION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
166 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for LEGISLATIVE DELEGATION (1 detail record)

**Agency / Program** PLANNING COUNCIL

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
167 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PLANNING COUNCIL (1 detail record)

**Agency / Program** VINNETTE CAROL THEATER

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
168 VINNETTE CAROL THEATER 503 SE 6 ST FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>

Subtotal for VINNETTE CAROL THEATER (1 detail record)

Subtotal for OTHER GOVERNMENT ENTITIES (3 detail records)

<i>Department</i>	<b><i>PORT EVERGLADES</i></b>
-------------------	-------------------------------

**Agency / Program** PORT EVERGLADES

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
169	PORT EVERGLADES - ADMINISTRATION 1850 ELLER DRIVE HOLLYWOOD	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
170	PORT EVERGLADES - BUILDING 1 (TERMINAL) 1800 SE 18 STREET FORT LAUDERDALE	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
171	PORT EVERGLADES - BUILDING 18 (TERMINAL) 1901 SE 32 STREET HOLLYWOOD	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
172	PORT EVERGLADES - BUILDING 19 (TERMINAL) 2019 ELLER DRIVE HOLLYWOOD	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
173	PORT EVERGLADES - BUILDING 2 (TERMINAL) 1801 SE 20 STREET FORT LAUDERDALE	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
174	PORT EVERGLADES - BUILDING 21 (TERMINAL) 2021 ELLER DRIVE HOLLYWOOD	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
175	PORT EVERGLADES - BUILDING 22 (TERMINAL) 2022 ELLER DRIVE HOLLYWOOD	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
176	PORT EVERGLADES - BUILDING 24 (TERMINAL) 2024 ELLER DRIVE HOLLYWOOD	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
177	PORT EVERGLADES - BUILDING 25 (TERMINAL) 2025 ELLER DRIVE HOLLYWOOD	4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
178	PORT EVERGLADES - BUILDING 26 (TERMINAL) 2026 ELLER DRIVE HOLLYWOOD	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>
179	PORT EVERGLADES - BUILDING 29 (TERMINAL) 2200 SE 35 STREET FORT LAUDERDALE	6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3	<input type="checkbox"/>

180	PORT EVERGLADES - BUILDING 4 (TERMINAL) 1800 SE 20 STREET FORT LAUDERDALE	4	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
181	PORT EVERGLADES - BUILDING 611 (OFFICE) 2550 EISENHOWER BLVD FORT LAUDERDALE	4	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
182	PORT EVERGLADES - MIDPORT PARKING GAR 2020 ELLER DRIVE HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
183	PORT EVERGLADES - NORTHPORT PARKING G 2000 EISENHOWER BLVD HOLLYWOOD	4	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
184	PORT EVERGLADES - PUBLIC SAFETY OFFICES 1901 ELLER DRIVE HOLLYWOOD	4	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>

Subtotal for PORT EVERGLADES (16 detail records)

Subtotal for PORT EVERGLADES (16 detail records)

*Department* **PROPERTY APPRAISER**

**Agency / Program** PROPERTY APPRAISER

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
185	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
186	GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
187	NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
188	PROPERTY APPRAISER EXTENSION 101 SW 1 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
189	SOUTH REGIONAL COURTHOUSE 3550 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PROPERTY APPRAISER (5 detail records)

Subtotal for PROPERTY APPRAISER (5 detail records)

*Department* **PUBLIC WORKS AND TRANSPORTATION**

**Agency / Program** CONSTRUCTION MANAGEMENT

Service Location(s)	Commission District	Priority		Has Special Features Report
		Programmatic	Structural	
190 GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2 <input type="checkbox"/>

Subtotal for CONSTRUCTION MANAGEMENT (1 detail record)

**Agency / Program** FACILITIES MANAGEMENT ADMINISTRATION

Service Location(s)	Commission District	Priority		Has Special Features Report
		Programmatic	Structural	
191 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2 <input type="checkbox"/>

Subtotal for FACILITIES MANAGEMENT ADMINISTRATION (1 detail record)

**Agency / Program** FACILITIES MANAGEMENT MAINTENANCE

Service Location(s)	Commission District	Priority		Has Special Features Report
		Programmatic	Structural	
192 JUVENILE ASSESSMENT CENTER 2600 SW 4TH AVE. FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1 <input type="checkbox"/>

Subtotal for FACILITIES MANAGEMENT MAINTENANCE (1 detail record)

**Agency / Program** FACILITIES MANAGEMENT OPERATIONS

Service Location(s)	Commission District	Priority		Has Special Features Report
		Programmatic	Structural	
193 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2 <input type="checkbox"/>

Subtotal for FACILITIES MANAGEMENT OPERATIONS (1 detail record)

**Agency / Program** FLEET SERVICES

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
194	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for FLEET SERVICES (1 detail record)

**Agency / Program** GENERAL SERVICES

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
195	GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for GENERAL SERVICES (1 detail record)

**Agency / Program** HIGHWAY CONSTRUCTION AND ENGINEERING

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
196	GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
197	WATER AND WASTE WATER SERVICES ENGIN 2555 W COPANS ROAD POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for HIGHWAY CONSTRUCTION AND ENGINEERING (2 detail records)

**Agency / Program** PROJECT MANAGEMENT AND CONSTRUCTION

	<b>Service Location(s)</b>	<b>Commission District</b>	<b>Programmatic</b>	<b>Structural</b>	<b>Priority Group</b>	<b>Has Special Features Report</b>
198	GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PROJECT MANAGEMENT AND CONSTRUCTION (1 detail record)

**Agency / Program** PUBLIC WORKS ADMINISTRATION

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
199 GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PUBLIC WORKS ADMINISTRATION (1 detail record)

**Agency / Program** REAL PROPERTY - PUBLIC WORKS

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
200 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for REAL PROPERTY - PUBLIC WORKS (1 detail record)

**Agency / Program** SEAPORT CONSTRUCTION AND PLANNING

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
201 PORT EVERGLADES - ADMINISTRATION 1850 ELLER DRIVE HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>

Subtotal for SEAPORT CONSTRUCTION AND PLANNING (1 detail record)

**Agency / Program** TRAFFIC ENGINEERING

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
202 TRAFFIC ENGINEERING BUILDING 2300 W COMMERCIAL BLVD FORT LAUDERDALE	9	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>

Subtotal for TRAFFIC ENGINEERING (1 detail record)

**Agency / Program** WASTE AND RECYCLING SERVICES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
203 GOVERNMENTAL CENTER WEST 1 N UNIVERSITY DRIVE PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for WASTE AND RECYCLING SERVICES (1 detail record)

**Agency / Program** WATER AND WASTEWATER SERVICES

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
204 WATER AND WASTE WATER SERVICES 3701 N SR 7 LAUDERDALE LAKES	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>
205 WATER AND WASTE WATER SERVICES ENGIN 2555 W COPANS ROAD POMPANO BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for WATER AND WASTEWATER SERVICES (2 detail records)

Subtotal for PUBLIC WORKS AND TRANSPORTATION (16 detail records)

<i>Department</i>	<b><i>SUPERVISOR OF ELECTIONS</i></b>
-------------------	---------------------------------------

**Agency / Program** ELECTIONS SUPERVISOR

Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
206 GOVERNMENTAL CENTER EAST 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>
207 NORTH REGIONAL COURTHOUSE 1600 W HILLSBORO BLVD DEERFIELD BEACH	2	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>
208 SOUTH REGIONAL COURTHOUSE 3550 HOLLYWOOD BLVD HOLLYWOOD	6	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

209	VOTING EQUIPMENT WAREHOUSE 529 SW 2 AVE FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>
210	WEST REGIONAL COURTHOUSE 100 N PINE ISLAND RD PLANTATION	1	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for ELECTIONS SUPERVISOR (5 detail records)

Subtotal for SUPERVISOR OF ELECTIONS (5 detail records)

*Department* **URBAN PLANNING AND REDEVELOPMENT**

**Agency / Program** BUILDING CODE SERVICES

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
211	BUILDING CODE SERVICES 955 S FED HIWAY FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>

Subtotal for BUILDING CODE SERVICES (1 detail record)

**Agency / Program** HOUSING AND COMMUNITY DEVELOPMENT

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
212	HOUSING AND COMMUNITY DEVELOPMENT 110 NE 3RD ST, SUITE 300 FORT LAUDERDALE	7	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for HOUSING AND COMMUNITY DEVELOPMENT (1 detail record)

**Agency / Program** PERMIT & LICENSING

	Service Location(s)	Commission District	Programmatic	Structural	Priority Group	Has Special Features Report
213	GOVERNMENTAL CENTER ANNEX 115 SOUTH ANDREWS AV FORT LAUDERDALE	7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>

Subtotal for PERMIT & LICENSING (1 detail record)

